

General Disclaimer


One or more of the Following Statements may affect this Document

- This document has been reproduced from the best copy furnished by the organizational source. It is being released in the interest of making available as much information as possible.
- This document may contain data, which exceeds the sheet parameters. It was furnished in this condition by the organizational source and is the best copy available.
- This document may contain tone-on-tone or color graphs, charts and/or pictures, which have been reproduced in black and white.
- This document is paginated as submitted by the original source.
- Portions of this document are not fully legible due to the historical nature of some of the material. However, it is the best reproduction available from the original submission.

(NASA-CR-159607) SIMWEST: A SIMULATION
MODEL FOR WIND AND PHOTOVOLTAIC ENERGY
STORAGE SYSTEMS (CDC USER'S MANUAL), VOLUME
1 Final Report (Boeing Computer Services,
Inc., Seattle, Wash.) 486 P HC A21/MF A01

G3/61 Unclass
35949

For
U.S. DEPARTMENT OF ENERGY
Division of Energy Storage Systems
Washington, D.C. 20545
Under Interagency Agreement EX-76-A-31-1026



FOREWORD

This report documents the CDC version of the SIMWEST computer programs developed by Boeing Computer Services Company under NASA Contract DEN3-42, "An Expanded System Simulation Model for Solar Energy Storage". The SIMWEST codes were originally developed for simulation of wind energy storage systems. The current version of these codes also includes solar-photovoltaic energy systems modeling. This project was conducted under the sponsorship of the Division of Energy Storage Systems, DOE, under the direction of Dr. G. C. Chang, and was administered by the NASA-Lewis Research Center Thermal and Mechanical Storage Section with Mr. L. H. Gordon and Mr. R. H. Beach as Project Managers.

This report is in two volumes.

- I. CDC User's Manual
- II. CDC Program Descriptions

The Boeing principal investigator for this project was Dr. A. W. Warren. Major contributors in the development of SIMWEST were Dr. R. W. Edsinger, Dr. J. D. Burroughs, and Dr. Y. K. Chan.

PRECEDING PAGE BLANK NOT FILMED

TABLE OF CONTENTS

	<u>Page</u>
REFERENCES	xvii
1.0 INTRODUCTION	1
1.1 SIMWEST OVERVIEW	1
1.2 SIMWEST LIBRARY	2
1.2.1 Storage Subsystems	7
1.2.2 Logic Components	12
1.3 SIMWEST OUTPUT	13
1.4 TESTING	15
1.5 PROGRAM USAGE	17
2.0 MODEL GENERATION	19
2.1 MODEL DESCRIPTION	20
2.1.1 Phrases and Delimiters	22
2.1.2 Command Phrases	24
2.2 NAMING CONVENTION	33
2.2.1 Variable, Parameter, and Table Naming Convention	33
2.3 MODEL SCHEMATIC	34
2.3.1 Standard Schematic Form	36
2.3.2 Input Quantity Labeling	36
2.3.3 Component Connection Paths	36
2.3.4 Additional Pages	38
2.3.5 Guidelines for Schematic Layout	38
2.4 WARNING MESSAGES	38
2.5 MODEL GENERATION LIMITATIONS	41
3.0 SIMULATION PROGRAM	43
3.1 MODEL INPUT DATA	43
3.1.1 Scalar Data	43
3.1.2 Tabular Data	44
3.2 INITIAL CONDITION AND INTEGRATION CONTROLS	46
3.3 INITIAL CONDITION STORAGE COMANDS	47
3.4 SIMULATION COMMANDS	47

CONTENTS (Continued)

	<u>Page</u>
3.5 PLOT DESIGNATION COMMANDS	50
3.6 ITERATION AND DIAGNOSTIC CONTROL	52
3.7 DEFINE COMMANDS	54
3.8 FUNCTION SCAN COMMANDS	55
3.9 EXAMPLE OUTPUT	56
4.0 JOB CONTROL PROCEDURES	59
4.1 JOB ENVIRONMENT	59
4.2 SIMWEST PROGRAM EXECUTION	59
4.3 FILE MAINTENANCE AND LIBRARY UPDATES	67
5.0 DIAGNOSTICS	75
5.1 WARNING MESSAGES	75
5.2 DIAGNOSTIC MESSAGES FOR LIBRARY COMPONENTS	77
6.0 CREATION OF NEW LIBRARY COMPONENTS	81
6.1 LIBRARY COMPONENT CODING	81
6.1.1 Component Call Sequence	81
6.1.2 Additions and Modifications to Component Library	88
6.1.3 Coding Conventions	88
6.2 FILOAD PROGRAM	92
6.2.1 FILOAD Program Commands	92
6.2.2 Input Name Lists	95
6.2.3 Output Name Lists	97
6.2.4 Table Name Lists	98
7.0 LIBRARY COMPONENT DESCRIPTIONS	101
7a. INPUT/OUTPUT NAME LISTS	101
7b. INPUT PARAMETER SPECIFICATION	101
7c. COMPONENT LOGIC	102
7d. UNITS	103
7.1 ADMITTANCE	105
7.2 TEST FUNCTION GENERATOR	111
7.3 BATTERY	113
7.4 BURNER	120

AD
AF
BA
BN

CONTENTS (Continued)

		<u>Page</u>
7.5 COST MONITOR	CM	126
7.6 COMPRESSOR (PNEUMATIC)	CO	131
7.7 PNEUMATIC STORAGE VESSEL (CONSTANT PRESSURE)	CS	138
7.8 ENVIRONMENTAL DATA (TMY TAPE)	ED	147
7.9 FLYWHEEL/CLUTCH	FL	160
7.10 FRESNEL LENS SOLAR COLLECTOR	FO	170
7.11 FLAT PLATE SOLAR COLLECTOR	FP	185
7.12 ONE DIMENSION TABLE LOOKUP	FU	197
7.13 TWO DIMENSION TABLE LOOKUP	FV	199
7.14 AC INDUCTION GENERATOR	GE	201
7.15 FIXED RATIO TRANSMISSION	GR	206
7.16 HISTOGRAM	HG	211
7.17 HYDRO STORAGE VESSEL	HS	214
7.18 HYDRAULIC TURBINE	HT	222
7.19 ADIABATIC HEAT EXCHANGER	HX	228
7.20 ADIABATIC HEAT EXCHANGER - DISCHARGING CYCLE	HY	246
7.21 INTEGRATOR WITH SATURATION	IT	249
7.22 DC-AC INVERTER	IV	251
7.23 FIRST ORDER LAG	LA	256
7.24 LEAD LAG	LL	258
7.25 ELECTRICAL LOAD	LO	260
7.26 MULTIPLY AND ADD	MA	265
7.27 MULTIPLY, DIVIDE, AND ADD	MB	267
7.28 MULTIPLY AND ADD	MC	269
7.29 AC INDUCTION MOTOR	MO	271
7.30 POWER ACCUMULATOR	PA	277
7.31 POWER DIVIDER	PD	286
7.32 PRIORITY INTERRUPT	PI	295
7.33 HYDRAULIC PUMP	PU	297
7.34 SOLAR-PHOTOVOLTAIC ARRAY	PV	303
7.35 AC-DC RECTIFIER	RE	316
7.36 RANDOM NUMBERS	RN	321

CONTENTS (Continued)

		<u>Page</u>
7.37 SATURATION FUNCTION	SA	323
7.38 SOLAR ORIENTATION	SO	325
7.39 SINGLE POLE SWITCH	SW	334
7.40 TWO POLE SWITCH	SX	336
7.41 THREE POLE SWITCH	SY	338
7.42 FOUR POLE SWITCH	SZ	340
7.43 SECOND ORDER TRANSFER FUNCTION	TF	342
7.44 TIME CONVERSION	TI	344
7.45 THERMAL LOAD	TL	346
7.46 AMBIENT TEMPERATURE	TP	351
7.47 VARIABLE RATIO TRANSMISSION	TR	356
7.48 THERMAL STORAGE CHAMBER	TS	361
7.49 TURBINE (PNEUMATIC)	TU	371
7.50 UTILITY	UT	377
7.51 WIND	WD	382
7.52 TURBINE/GENERATOR	WP	387
7.53 WIND TURBINE	WT	391
8.0 WIND GENERATION AND STORAGE EXAMPLES		397
8.1 BATTERY STORAGE MODEL		397
8.2 FLYWHEEL STORAGE MODEL		407
8.3 HYDRO AND THERMAL STORAGE MODEL		415
8.4 PNEUMATIC STORAGE MODEL		425
9.0 SOLAR-PHOTOVOLTAIC EXAMPLES		435
9.1 PHOTOVOLTAIC MODEL TEST CASE		437
9.2 FLAT PLATE COLLECTOR MODEL		437
9.3 FRESNEL LENS COLLECTOR MODEL AND INCREMENTAL COSTS		442
APPENDIX: UTILITY SUBROUTINES		457

LIST OF FIGURES

	<u>Page</u>
1.1-1 SIMWEST Program Organization	3
1.2-1 Pneumatic Storage Subsystem	8
1.2-2 Pumped Hydro Storage Subsystem	9
1.2-3 Flywheel Storage	10
1.2-4 Battery Storage	10
1.2-5 Thermal Storage	11
1.2-6 Example of Power Divider and Accumulator Use	14
1.3-1 Cost Monitor Output for Fresnel Lens Model	16
2.1-1 Analyst's Sketch of Wind Turbine Model Schematic	21
2.1-2 Lineprinter-Drawn Wind Turbine Model Schematic	23
2.2-1 Character Assignment Input/Output or Table Name	35
2.3-1 Component Connection Paths	37
3.6 Typical Diagnostic Output	53
3.9 Sample Printer Output	57
4.2-1 Job Control Procedure 'EASYM'	61
4.2-2 Job Control Procedure 'EASY'	63
4.2-3 Job Control Procedure 'EASYA'	65
4.2-4 Job Control Procedure 'EASYB'	66
4.3-1 Job Control Procedure 'FORMOD'	69
4.3-2 Job Control Procedure 'FORMODG'	71
4.3-3 Job Control Procedure 'FILOAD'	72
4.3-4 Job Control Procedure 'LIST'	72
6.1-1 Sample Component Code - WP	89
6.1-2 Sample Component Code - GE	90
6.2-1 List of Standard Component Symbols	94
7.0 Sample Connections for Logic Components	104
7.1 Admittance Network Model	105
7.3 Battery Circuit Diagram	113
7.7 Constant Pressure Air Storage	139
7.8 TMY Tape Format	152
7.10-1 Equivalent Thermal Network for Fresnel Lens Collector	171

LIST OF FIGURES (Continued)

	<u>Page</u>
7.10-2 Fresnel Lens Thermal Model	171
7.11-1 Physical Diagram of Flat Plate Collector	186
7.11-2 Equivalent Thermal Network for Flat Plate Collector	186
7.15 Fixed Gear Power Loss	206
7.19-1 Koutz - Glendenning Adiabatic Compressed Air Storage Scheme (Single-Stage Heat-of-Compression Storage)	229
7.19-2 Enthalpy - Temperature Diagram for HX	231
7.19-3 Storage Temperature Versus Tube Length	231
7.22 Inverter Functional Diagram	251
7.35 Rectifier Functional Diagram	316
7.38 Solar Orientation Angles	327
7.47 Transmission Model - Lookup Table	356
7.48 Temperature - Enthalpy Diagram	363
7.52 Output Power Versus Wind Velocity	387
7.53 Generalized Machine Power Output Performance	394
8.1-1 Battery Storage Example	398
8.1-2 Battery Model Input Data	399
8.1-3 Battery Model Schematic	400
8.1-4 Input Data for Battery Simulation	401
8.1-5 Cost Monitor Output for Battery Model	403
8.1-6 Wind Profile for Battery Simulation	404
8.1-7 Wind Power Supplied to Load	405
8.1-8 Battery Potential Energy Storage	406
8.2-1 Flywheel Storage Example	408
8.2-2 Flywheel Model Input Data	407
8.2-3 Flywheel Model Schematic	409
8.2-4 Flywheel Simulation Data	411
8.2-5 Wind Power Supplied to Flywheel Storage	412
8.2-6 Flywheel Kinetic Energy Storage	413
8.2-7 Flywheel Model Cost Monitor Output	414
8.3-1 Hydro and Thermal Storage Example	416

LIST OF FIGURES (Continued)

	<u>Page</u>
8.3-2 Hydro and Thermal Model Input Data	415
8.3-3 Hydro and Thermal Model Schematic	417
8.3-4 Hydro and Thermal Simulation Data	419
8.3-5 Hydro Reservoir Energy Storage	420
8.3-6 Percent Cumulative Load Delivered	421
8.3-7 Thermal Energy Storage	422
8.3-8 Percent Cumulative Thermal Load Delivered	423
8.3-9 Ambient Temperature Simulation Over One Week	424
8.4-1 Pneumatic Storage Example	426
8.4-2 Pneumatic Storage Model Input Data	425
8.4-3 Pneumatic Storage Simulation Data	428
8.4-4 Average Temperature in Heat Exchanger Cell 2	429
8.4-5 Heat Exchanger Outlet Temperature (Charging)	430
8.4-6 Air Mass in Pneumatic Storage	431
8.4-7 Air Mass Temperature in Pneumatic Storage Vessel	432
8.4-8 Heat Exchanger Outlet Temperature (Discharging)	433
9.1-1 PV Test Case Input Data	438
9.1-2 Solar Array Characteristic Current - Voltage Curves	439
9.1-3 Solar Array Output Power Versus Voltage	440
9.2-1 Flat Plate Collector Model Input Data	441
9.2-2 Flat Plate Model Schematic	443
9.2-3 Global Horizontal Radiation Versus Time	444
9.2-4 Tilt Angle Versus Time for Horizontal E-W Axis Tracking	445
9.2-5 Solar Cell Temperature Versus Time	446
9.3-1 Fresnel Lens Model Input Data	447
9.3-2 Fresnel Lens Model Schematic	449
9.3-3 Solar Cell Temperature for One Week Simulation	450
9.3-4 Photovoltaic Array Output for One Week Simulation	451
9.3-5 Thermal Load Demand for One Week Simulation	452
9.3-6 Thermal Storage Temperature for One Week Simulation	453

LIST OF TABLES

	<u>Page</u>
1.1-1 SIMWEST User Oriented Features	4
1.2-1 SIMWEST Library Components	5
1.2-2 Partial List of Component Inputs and Outputs	11
2.1-1 Model Generation Program Language Delimiters	22
3.4-1 Print Control Values	49
6.1-1 Component Subroutine Call Sequence Order	87
7.8 TMY Tape Stations and Location	155
9.0-1 Solar-Photovoltaic Components	436
9.3-1 Incremental Cost Calculations	456

LIST OF REFERENCES

- [1] R. W. Edsinger, Y. K. Chan, A. W. Warren, "A Simulation Model for Wind Energy Storage Systems," Volume I: Technical Report, NASA CR-135283, prepared by Boeing Computer Services Company, August 1977.
- [2] A. W. Warren, R. W. Edsinger, J. D. Burroughs, "A Simulation Model for Wind Energy Storage Systems," Volume II: Operation Manual, NASA CR-135284, prepared by Boeing Computer Services Company, August 1977.
- [3] SOLMET User's Manual, TD-9724, National Climatic Center, Ashville, North Carolina, December 1977.
- [4] J. K. Linn, "Photovoltaic System Analysis Program--SOLCEL," Sandia Laboratories Report SAND77-1268, August 1977.
- [5] AFFDL-TR-75-(D180-18575), "ECS Transient Analysis"; Vol. I - Component Mathematical Models; Vol. II - Component Transient Computer Programs; Vol. III - Integrated Transient Computer Program; and Vol. IV - Optimal Control and Design Synthesis; The Boeing Company, prepared under Air Force Contract F33615-74-C-3041, October 1975.
- [6] A. W. Warren, "An Expanded System Simulation Model for Solar Energy Storage," Volume I: Technical Report, NASA CR-159601, prepared by Boeing Computer Services Company, August 1979.

1.0 INTRODUCTION

Energy storage systems for the utilization of intermittent power sources have received increased study over the past few years. The analysis of storage requirements for optimal utilization of solar-derived energy systems and the total cost of the resulting generator/storage system are often evaluated in such studies. The purpose of the SIMWEST (Simulation Model for Wind Energy Storage) program described in this document is to provide a tool for performing this needed analysis. It is a tool to aid in the design of a wind or solar-photovoltaic energy system for a given application and to allow the resulting system to be evaluated and verified through simulation.

SIMWEST consists of a library of system components and a precompiler program which allows these components to be put together in building block form. The present library contains components for five types of energy storage systems. They are pumped hydro, battery, thermal, flywheel, and pneumatic. The SIMWEST program version described in this document is for use on the CDC 6000 and CYBER series of computers.

The simulation program has proven to be efficient and versatile for performing parametric studies. It has a unique capability for simulating total wind/solar systems containing any one or combination of the above types of storage and at the same time has the flexibility and depth required to perform thorough and meaningful parameter studies.

1.1 SIMWEST OVERVIEW

SIMWEST consists of two basic programs, and a library of generation, storage, environmental, and load components. The first program, the Model Generation Program, is a precompiler which generates computer models (in FORTRAN) of complex energy generation/storage systems, from user specifications using SIMWEST library components. The second program utilizes the resulting computer

model to perform cost and power utilization analysis. It handles input, output, integration of system dynamics, and iterates to obtain convergence of implicit variables. The combination of these two programs provides a powerful tool for analyzing alternate generation and storage system designs.

Figure 1.1-1 shows the general organization of the SIMWEST program. In addition to the two programs described above, there is a third which performs file maintenance. It is used to incorporate user supplied data for new subsystem models. Although the program is shown as a number of subprograms, it can be executed as a single batch program by supplying the model description cards and the control cards describing the desired analysis to be performed and the desired tabular and/or plotted output.

The SIMWEST model generation and simulation programs have a number of user oriented features which greatly enhance the value of the codes. Some of the more prominent features are shown in Table 1.1-1. These features and the supplemental components described in 1.2 enable the user to quickly build, debug, simulate and interpret alternative system designs.

1.2 SIMWEST LIBRARY

The SIMWEST library is listed in Table 1.2-1. It is made up of six types of components: environmental, generation, load, logical, storage and supplemental. The two character mnemonic names are used to identify components in the users model.

The degree of detail in the component models is based upon two design criteria. First, all models should contain sufficient detail to simulate all physical characteristics and constraints having significant impact on system cost effectiveness. Second, the models should be designed to minimize computer time and required user specification. It is assumed that a SIMWEST simulation might cover a time span of one year. Thus, from a computer run time and economic impact point of view a simulation step size of between 15 minutes and one hour was established as a design goal.




Figure 1.1-1 SIMWEST Program Organization

Table 1.1-1 SIMWEST User Oriented Features

MODEL GENERATION PROGRAM

- Simplified Component Connections
- Availability of all Input Parameters for Connection
- Fortran Insertion Capability Between Components
- Line Printer Schematic of User's Model Provided
- Automated Naming of Parameters and Variables
- Built-in Diagnostic Capabilities

SIMULATION PROGRAM

- Free Field Data Inputs, Including Tables
- Diagnostics on Data Inputs
- Default Values Assigned to Unspecified Parameters
- Optional Levels of Line Printer and Diagnostic Output
- Multiple, Back-to-back Simulation Capability
- Printer Plotter Output of Time Histories and Crossplots

Table 1.2-1 SIMWEST Library Components

<u>ENVIRONMENTAL</u>		<u>BATTERY STORAGE</u>	
WIND	WD	INVERTER	IV
AMBIENT TEMP	TP	RECTIFIER	RE
TMY WEATHER TAPE	ED	BATTERY	BA
		ADMITTANCE	AD
<u>WIND POWER GENERATION</u>		<u>FLYWHEEL STORAGE</u>	
TURBINE/GENERATOR	WP		
WIND TURBINE	WT	AC MOTOR	MO
FIXED RATIO TRANSMISSION	GR	VARIABLE RATIO TRANSMISSION	TR
AC GENERATOR	GE	FLYWHEEL/CLUTCH	FL
<u>SOLAR POWER GENERATION</u>		<u>HYDRO STORAGE</u>	
SOLAR ORIENTATION (TRACKING)	SO	HYDRO PUMP	PU
FLAT PLATE COLLECTOR	FP	HYDRO TURBINE	HT
FOCUSING LENS COLLECTOR	FO	HYDRO STORAGE	HS
PHOTOVOLTAIC ARRAY	PV		
<u>UTILITY GENERATION</u>		<u>PNEUMATIC STORAGE</u>	
UTILITY	UT	COMPRESSOR	CO
		TURBINE	TU
		ADIABATIC HEAT EXCHANGER	HX, HY
		BURNER	BN
		PNEUMATIC STORAGE	CS
<u>LOGIC</u>		<u>THERMAL STORAGE</u>	
POWER DIVIDER	PD		
POWER ACCUMULATOR	PA		
PRIORITY INTERRUPT	PI		
SWITCHES	SW, SX	STORAGE VESSEL	TS
	SY, SZ		
<u>LOAD</u>		<u>SUPPLEMENTAL</u>	
ELECTRICAL LOAD	LO	SATURATION	SA
THERMAL LOAD	TL	RANDOM NUMBER GENERATOR	RN
		TEST FUNCTIONS	AF
		TABLE LOOKUPS	FU, FV
		TRANSFER FUNCTIONS	IT, LA, LL, TF
		ARITHMETIC ELEMENTS	MA, MB, MC
		COST MONITOR	CM
		HISTOGRAM	HG
		TIME CONVERSION	TI

As a result of the above design criteria, many physical components, such as the electrical components, were modeled mainly in terms of power flow and steady state response. This level of detail is consistent with a 15 minute time step and with the concept that important transients are on the time scale of demand curves or weather patterns, i.e., an hour or more, rather than on the time scale of electric motor transients of a few seconds. If short time transients were to be modeled, additional detail would be required in the component models which would greatly increase the user's task of specifying the model. Further, the simulation time step would have to be reduced and computer runs would be much costlier.

The environmental components listed in Table 1.2-1 simulate environmental conditions. In the present SIMWEST library a user can generate wind speed and ambient temperatures, or can use selected inputs from the recorded weather and insolation data on the Typical Meteorological Year (TMY) tapes for one of 26 U.S. locations. These variables are generally used as inputs to physical components.

The generation components consist of wind generation, solar-photovoltaic and utility routines. The wind turbine-generation components are fairly simple models for computing the power output of a conventional, horizontal axis wind machine given basic machine parameters. The solar-photovoltaic components are somewhat more sophisticated, especially in the collector thermal analysis, and have a number of modeling options which a user may employ, e.g., active or passive cooling.

The storage components encompass such things as motors, generators, transmissions, flywheels, etc. These components model actual physical hardware which might be used in a wind or solar energy system. The selection of the particular SIMWEST library set of storage components was based on the requirement that it be capable of modeling the five types of energy storage systems mentioned previously: thermal, flywheel, battery, pumped hydro and pneumatic.

The load components in the SIMWEST library are used to simulate various types of power demand. They also monitor how well the system meets the simulated demand and compute the value of the energy delivered to the load. Like the environmental components, these components may be computed from actual measurement data or from randomly generated data based on user furnished load profiles.

The library's logical components are the power dividers, power accumulators, switches and priority interrupts. Although physical hardware or logic devices could be built to serve the function of the logical components, they are not meant to represent any particular existing hardware. Instead, they are idealized components that allow the user flexibility in modeling a wide variety of system and control logic for operational evaluation of energy storage systems. In practice, the control function might be performed by a control room operator using a predefined control strategy or by use of a process computer.

Finally, the supplemental components include such things as the tape read, the histogram and the cost monitor. These components serve to help the user run the simulation and analyze its results.

1.2.1 Storage Subsystems

Figures 1.2-1 through 1.2-5 give possible configurations of the five types of storage subsystems which can be modeled with the present SIMWEST library. For illustrative purposes the number of variables shown passed between components is limited. A description of the variables being passed is given in Table 1.2-2.

A total energy system will generally be made up of elements from a number of different subsystems (see Figure 1.2-6). In addition, the SIMWEST program can be used for models which include networks of storage subsystems of the same type or a network of wind or solar generators.




Figure 1.2-1 Pneumatic Storage Subsystem




Figure 1.2-2 Pumped Hydro Storage Subsystem




Figure 1.2-3 Flywheel Storage





Figure 1.2-4 Battery Storage



LD = LOAD DELIVERED

Figure 1.2-5 Thermal Storage

Table 1.2-2 Partial List of Component Inputs and Outputs
SYMBOLS

P	POWER
RE	POWER REQUEST
MP	MAXIMUM POWER
RS	ROTOR SPEED
T	TEMPERATURE
TA	AMBIENT TEMPERATURE
M	MASS FLOW RATE
H	RESERVOIR HEIGHT
LD	THERMAL LOAD DELIVERED
WV	WIND VELOCITY
GR	GEAR RATIO
EF	EFFICIENCY
INT	INTERRUPT FLAG
PR	PRESSURE
PS	PRIORITY SEQUENCE
WY	WEEK OF YEAR
DW	DAY OF WEEK
TD	TIME OF DAY
SP	SURPLUS POWER

1.2.2 Logic Components

The capability for modeling complex system control logic is provided by the power divider, power accumulator and priority interrupt components. Both the divider and accumulator operate on a priority basis. The priority interrupt is used by other system components to change the priority setting of the divider and accumulator.

The power divider has one input power port and four output power ports (not all output ports need be used for a given simulation). The divider also has an input request associated with each of its output ports. A power request originates with a component which is directly or indirectly connected to an output port. The user specifies priorities of either 0, 1, 2, 3, or 4 to be associated with each of the output ports. If the input power exceeds that requested of the port with highest priority (priority 1) then the excess power goes to the port with the next priority. This process continues until either all power is distributed or all requests of non-zero priority ports are met. A port with zero (0) priority does not receive power. Such ports are included to model backup or switch operated components. In these situations, the connected component would change the zero priority setting of the power divider by use of a priority interrupt. Two or more ports may be assigned the same priority in which case the user may specify weights to be associated with each port. Then if there is not enough power available to satisfy all requests of equal priority, the power is divided between them in proportion to the user specified weights.

The power accumulator is similar to the divider except that instead of distributing power from a single input port among four output ports, it accumulates power from four input ports and sends it out through a single output port. The power accumulator accepts power requests from the downstream component and allocates requests to each of its input ports in order to service the downstream component.

An example illustration of the use of power dividers and power accumulators is given in Figure 1.2-6. It is seen that power from the turbine/generator is distributed with highest priority (priority 1) going to the power accumulator that services load 1. Since the power accumulator servicing load 1 has its priority 1 input port connected to the power divider, it will try first to satisfy load 1 from the turbine/generator and then from the utility. If the power divider satisfies load 1 and there is power left over, it will be used to satisfy the request from the battery. Finally, if the battery is full or if its charging rate is met, then the excess power goes to the flywheel. The battery also has a priority zero connection to the utility. If the battery remains in a discharge state for more than a specified amount of time, it can change the utility priority (from 0 to 1) to receive needed power.

Also in Figure 1.2-6, we see that load 2 prefers to draw power from the flywheel before turning to the battery. This configuration tends to keep the flywheel as discharged as possible, using it primarily as a means to absorb large influxes of power.

1.3 SIMWEST OUTPUT

There are three basic forms of SIMWEST output to facilitate the analysis of wind and solar energy storage systems; line printer plots, histograms of system variables and time sequenced output of variable values. Each SIMWEST library component is associated with a number of output variables. Prior to simulating a given system the user may select any of these outputs for plotting or tabular output. For example, he may want to plot the energy of pneumatic storage as a function of time and/or as a function of temperature. If the user wants a time sequenced listing of all variable values, he may specify the time step between printouts. The listing of all variables has proven to be a useful tool in understanding the performance of the system under consideration and a valuable aid in validating the system design.

SIMWEST also provides a special output which computes life cycle and levelized energy costs per kwh. This output is produced by the cost monitor component




Figure 1.2-6 Example of Power Divider and Accumulator Use

and is illustrated in Figure 1.3-1. The levelized energy costs are based on energy delivered to the loads during a simulation and forecasted to a full years' system operation. This output permits direct comparison of capital and energy costs for alternative system configurations, enabling a user to perform economic trade studies and system sizing.

1.4 TESTING

Reference [1] describes two simulation studies which were used to test the original SIMWEST program. Reference [6] describes the NASA-Lewis approved simulation studies for the expanded SIMWEST program. These studies provide an excellent test and illustration of the program's capability to model complex wind/solar energy systems.

Prior to performing the simulation studies and throughout its development the SIMWEST program was systematically tested. First components were grouped into simple systems and simulations were performed. During these simulations system parameters were driven so as to force the individual components through every normal program path and to assure that all component outputs assume a wide range of values. The number of components and the number of ways they can be connected makes it impossible to exercise every combination. However, the subsystem groupings that were used were representative of the expected program usage. Sections 8 and 9 describe some of the test cases for the wind and solar-photovoltaic generation components.

The test cases and simulation studies revealed that the code is reasonably efficient for system parameter studies. Even on very complex systems, such as represented by the NASA-Lewis test case, convergence of logic variables was quite rapid. Convergence generally took place in less than six iterations per simulation time step. As an example, the year simulations used in the NASA defined parameter study of Reference [1] took less than 420 CPU seconds on the CDC 6600. For comparison, the CPU time on the UNIVAC 1100/40 is approximately two to three times as great as that on the 6600, and CPU time on the Cyber 175 is a factor of two to three times smaller than that of the 6600.

SOLAR/WIND ENERGY STORAGE COST SUMMARY
20 YEAR LIFE CYCLE

• YEARLY SYSTEM COSTS

CAPITAL COST (INCLUDING FIXED CHARGES)	526. \$
FIXED O + M COST	107. \$
OPERATING + FUEL COST	14. \$
TOTAL	646. \$

• ENERGY DELIVERED

ENERGY DELIVERED	7445. KWH

ENERGY COST PER KWH	86.8 MILLS

VALUE OF ENERGY DELIVERED (VALUE OF FUEL SAVED)	372 \$
ENERGY VALUE PER KWH	50.0 MILLS
COST PER VALUE DELIVERED	1.74

• LOAD FACTOR

PERCENT OF LOAD SUPPLIED BY TOTAL SOLAR SYSTEM	100.0
PERCENT OF LOAD SUPPLIED BY UTILITY	0.0
PERCENT OF SOLAR ENERGY SURPLUSSED	0.0
COST TO MEET LOAD (SOLAR + UTILITY)	86.8 MILLS

Figure 1.3-1 Cost Monitor Output for Fresnel Lens Model

1.5 PROGRAM USAGE

During the testing it became clear that while the user need not be a SIMWEST expert or software specialist to make efficient use of the program, he should thoroughly think through and be familiar with the characteristics of the system he wants to simulate. Component models, if not carefully specified, may perform in unexpected ways. If the systems logic is not well thought out, the resulting system may be significantly out of balance and subsystems may not be fully utilized. The test case described in Reference [6] illustrates the process of sizing and logic adjustment to satisfy system performance objectives.

A number of useful procedures were developed during the simulation studies. First it was found that when simulating a complex system, it is best to separately develop and test subsystem portions of the model. This allows problems or unexpected results to be isolated and understood prior to the introduction of the more complex characteristics associated with the total system.

It was found during the simulations that the use of Fortran statements in the model definition is very useful for creating special input to system components and for defining special outputs to be plotted or statistics to be printed. For example, Fortran statements enable the user to generate and interpret trade study data by computing component input parameters from user specified system parameters. The use of Fortran statements is simple and should be encouraged early in SIMWEST applications.

Computer simulation costs may be minimized by appropriate tradeoffs between run time and simulation accuracy. Run time is most directly affected by the integration step size, the total simulation length, and the average number of iterations through the model at each time step. For long duration runs, an hour step size is usually acceptable. Models having smaller time constants than the step size may be approximated by implicit steady state conditions and

solved by iteration through the model. If a model requires many iterations for convergence, then it may be useful to isolate the source of instability in order to modify or simplify that portion of the system model. It has been generally found in the simulation studies that use of a few seasonal weekly simulations is adequate to predict long term performance for system trade studies and design optimization. Four to six week-long simulations are recommended for this purpose.

When making a year simulation run, it is best to break it into twelve monthly simulations. Thus, measures of performance such as plots, histograms and performance statistics are available on a monthly basis. In addition to giving better visibility of the system performance, this helps limit the job core size. The twelve monthly simulations can be submitted as a single run with the results of a given month acting as initial conditions for the next month. The user only needs to submit new data cards for data which changes from one month to the next.

2.0 MODEL GENERATION

The Model Generation program design is based on the assumption that the system analyst will begin by constructing a schematic diagram of the system he wishes to analyze. This schematic will be comprised primarily of standard SIMWEST library components. Standard library components include wind models, AC induction motors, inverters, rectifiers, etc. If a particular system cannot be modeled with existing standard components, the analyst may construct his model by including appropriate FORTRAN statements in his system description.

All interconnections between standard components are accomplished by the Model Generation program. The analyst merely specifies each standard component in the schematic diagram and all of the components that provide inputs to that component. The Model Generation program then generates names and the proper interconnections between the specified components. This is accomplished by matching the input quantities required by each standard component to the output quantities of the specified input components.

After processing the complete system model description, the Model Generation program generates a schematic diagram of the model showing the interconnections between standard components and the quantities such as power, pressure, temperature, mass flow rates, etc., that pass through each interconnection. This schematic is produced on the lineprinter to provide a rapid graphic check on the program's interpretation of the model description.

In addition, the program produces a list of input data that will be required by each component to complete the model description. Both the scalar parameters and tabular data required for the analysis are included in this list. The program assumes that any quantity not supplied by another component will be supplied as a fixed parameter by the analyst. Thus requests for non-parameter items in the input data list will reveal any connection that was omitted from the system model description.

2.1 MODEL DESCRIPTION

The Model Generation program is a precompiler program which accepts model description instructions and from these instructions generates a FORTRAN model of a system. These instructions, referred to as "program commands," are made up of one or more words. In addition, the system model description contains numeric values, standard component names, and standard input and output quantity names.


The Model Generation commands may be best introduced with a simple example of their use to describe a wind turbine system. Figure 2.1-1 shows an analyst's schematic of a wind turbine model that has been constructed using standard components on a SIMWEST schematic form. The standard component names used in this sample are:

- WD - Wind Model
- WT - Wind Turbine
- TI - Time Conversion
- HG - Histogram Generator
- GR - Fixed Ratio Transmission
- LO - Electrical Load
- GE - AC Induction Generator

The SIMWEST description of this model would be as follows:

Example 2.1

MODEL DESCRIPTION		WIND TURBINE TEST CASE
LOCATION=15	TI	
LOCATION=11	WD	INPUTS=TI
LOCATION=31	WT	INPUTS=WD
LOCATION=35	GR	INPUTS=WT



Example 2.1 (Continued)

LOCATION=51	HG	INPUTS=WT(P=FIN)
LOCATION=39	GE	INPUTS=GR
LOCATION=19	LO	INPUTS=GE, TI
END OF MODEL		
PRINT		

The model description consists of a statement as to the location of each component in the schematic and a list of all components that provide inputs to that component. The location of the component in the schematic is used for a line printer drawn schematic of the model, such as shown in Figure 2.1-2. In the line printer schematic the connection variables such as powers (P2 WT, P2 GE, P2 GR) are shown on the various connecting lines.

2.1.1 Phrases and Delimiters

The system model description is interpreted by the Model Generation program as a series of "phrases", which can appear in a free field format in any position on a data card. Phrases must be separated by any one of the delimiter symbols shown in Table 2.1-1.

Table 2.1-1

Model Generation Program Language Delimiters	
=	equal sign
,	comma
(left parenthesis
)	right parenthesis
	three or more blanks

WIND TURBINE TEST CASE




FIGURE 2.1-2 LINEPRINTER-DRAWN WIND TURBINE MODEL SCHEMATIC

2.1.2 Command Phrases

The Model Generation command phrases are described in this section in a logical sequence similar to that in which they appear in system model descriptions.

MODEL DESCRIPTION

The MODEL DESCRIPTION command phrase indicates the start of a new system model. This phrase may be followed, (on the same card), by a title of up to 60 characters. This title will be used to identify various program output schematics, lists and program listings. In Example 2.1, the title was "Wind Turbine Test Case."

LOCATION

The LOCATION command phrase indicates the start of the description of a new component in the system model. This command must be followed by a numeric value phrase that specifies the location of the new component on the model schematic. Thus in the example of Figure 2.1-1, the location number of the wind model WD was 11 and the wind turbine WT was 31, etc. To be a valid component location, the last two digits of this number must comprise a number between 1 and 80. The hundreds column is used to specify additional pages as needed for the schematic. Thus the numbers

1, 13, 51, 80

would be valid location numbers for components on the first page, (PAGE 0), of a system schematic. These same locations on the second page of the schematic, (PAGE 1), would be:

101, 113, 151, 180

The location number phrase is followed by the name of the component at that location. Component names are discussed in Section 2.2.

A LOCATION statement should be given only once for each component. That is, once a LOCATION statement is started for a component the complete description of all inputs to that component should be given.

INPUTS

The INPUTS command phrase indicates that the following phrases contain the names of the components that provide inputs to the component at the specified location. Thus in the example of Figure 2.1-1, the electric load at location 19 which receives inputs from generator GE and the time source TI was described as:

```
LOCATION=19      LO      INPUTS=GE,TI
```

In this example the command phrase INPUTS is followed by two component names. As many component names as are necessary to specify the inputs to a particular system component may be included in each component description.

For some system components there are multiple input and/or output ports. For example, a power divider has four input power ports. When specifying the connections between such components, it is advisable to specify which ports are to be connected. This is done by adding the port numbers to be connected after the name of the input component. Thus, the wind turbine to transmission connection could have been more explicitly described as:

```
LOCATION=35      GR      INPUTS=WT(2,1)
```

This says that port 2 of the wind turbine (WT) drives port 1 of the transmission (GR). Any quantities which have no port numbers are considered "universal ports" for input connections. Thus, the GR input of GR is connected up to GR WT, and the RS input of WT is connected up to RS1GR by the above command. If the port designations are omitted, as they were in Example 2.1, the connections will be made to the first available input port starting with the minimum port

number. Once a connection has been made to an input port, those input quantities that are connected are no longer available for further connections. An exception is made when the physical quantities of both input and output are specified. This method of specifying connections is described in the following paragraphs.

For certain components, such as the arithmetic elements, the inputs to the component can be any physical quantity in the model. For these components, the input component names must be supplemented by the name of the particular output quantity that is to provide the input.

As an example, consider a component that represents a linear first order lag transfer function. If the transfer function component's input, FIN, was to be the rotor speed of the wind turbine WT in Example 2.1, then the statement

```
LOCATION=53      LA      INPUTS=WT(RS=FIN)
```

would indicate to the program that of the outputs of the wind turbine, the output rotor speed, RS, was to be used as the input, FIN, to the transfer function, LA.

To summarize, there are three levels of connection specification:

1. Default (only component names are specified)

Connections are made between all unconnected inputs and outputs for the first ports for which a match of physical quantity names occurs.

2. Ports Specified

Connections are made between matching physical quantities for all unconnected inputs and outputs of the specified ports.

3. Physical Quantities Specified

Connections are made between only those quantities specified. Previous connections can be overridden, providing the three character physical quantity name of the previously connected variable is used. For example, the phrase

```
LOCATION=19      LO      INPUTS=GE,GE(P,2=MP2)
```

will first replace the input parameter MP1LO by MP2GE and then override the connection MP2GE and substitute P2 GE as the LO input.

Note: The LIST STANDARD COMPONENTS command produces a listing of all input and output physical quantity names and port numbers. When specifying individual physical connections this listing may be used to differentiate physical quantity names and port numbers. For example, (P,2=...) denotes connection of a physical quantity P at port 2, whereas (P2=...) denotes connection of physical quantity P2 without regard to port number.

END OF MODEL

The END OF MODEL command phrase indicates that the model description has been completed and that the Model Generation program should proceed with the generation of the model subroutines.

PRINT

The PRINT command phrase causes the program to: (1) draw a schematic of the system model, as shown in Figure 2.1-2; (2) print a list of input requirements for the model; and (3) print a source listing of the FORTRAN subroutines that were generated for the model. The Model Generation program then terminates.

PUNCH

The PUNCH command phrase has the same effect as the PRINT command, but in addition a FORTRAN source deck of the system model is produced.

FORTRAN STATEMENTS

The FORTRAN STATEMENTS command phrase allows the system analyst to supplement the library components with FORTRAN statements. Using this feature, the analyst can introduce his own program logic, DO loops, etc., as necessary to model any system feature not obtainable with standard library components.

One of the common uses of the FORTRAN STATEMENTS command is to input large tables into the model. Two function subprograms TBLU1 and TBLU2 are provided for this use. They perform linear interpolation from one and two dimension tables, respectively. TBLU1 is in general called in the form

$$F = \text{TBLU1}(X, \text{TAB}(4), \text{TAB}(4+N), I, \pm N),$$

where F is the interpolated value at the desired point X, TAB is a one dimension table with dimension N, TAB(4) is the independent variable and TAB (4+N) is the dependent variable list, I = 0 for equal spaced data, I = 1 for unequal spaced data, and the dimension N is specified as the last variable if linear extrapolation is desired, and -N is specified if truncation is desired outside the table limits. Similarly, TBLU2 is in general called using the form

$$F = \text{TBLU2}(X, Y, \text{TAB}(4+M), \text{TAB}(4), \text{TAB}(4+M+N), IX, IY, \pm N, \pm M, N, M),$$

where X and Y are the values of the primary and secondary independent variables, N and M are the dimensions of the primary and secondary variable arrays, IX and IY are indicators for equal spaced or unequal spaced data as above, and the sign convention on N and M is positive for extrapolation, negative for truncation.

The FORTRAN STATEMENTS command would normally be used only when some portion of the system cannot be modeled with library components. When using this feature of the program, the analyst must include detail connections and naming of variables, that are normally accomplished by the Model Generation program. In return for these added tasks, the analyst gains a great deal of additional flexibility in forming details of his system model. Non-executable code such as common blocks must precede the first component definition and executable code should come after a component has been defined for the iteration logic to work properly.

ADD STATES
ADD VARIABLES
ADD PARAMETERS
ADD TABLES

The ADD COMMANDS may be used in conjunction with the FORTRAN STATEMENTS to add states, variables, parameters, and tables that occur within the FORTRAN statements, to the system model. Quantities that are not specified by one of these commands cannot be accessed or manipulated by the Analysis Program.

Before discussing these commands, a few definitions of terms are in order.

States:

States are those quantities in the system model that are described by first order differential equations. The state variables are the result of integrating the set of first order differential equations that comprise the dynamic system model. The number of states equals the order of the system model. The states are dynamic, time varying quantities during most simulation studies. The initial values, (initial conditions), of the states must be input as part of the system model description. Derivatives of the state variables are stored in an array XDOT

where $\dot{X}(I)$ is the derivative of the I th state variable stored in the model (EQMO).

Variables:

Variables are all other dynamic time varying quantities in the system model that are not states. In general, variables are related to states by algebraic relationships.

Parameters:

Parameters are constant scalar quantities in the system model. Parameters can be manipulated by the analyst to alter the system model. All parameter values* should be input as part of the system model description.

Tables:

Tables are constant nonscalar quantities in the system model. Tables are used to represent algebraic functional relationships with one or two independent variables. All table values must be input as part of the system model description.

The format for the ADD commands is that the command is followed by one or more phrases that contain the names of the states, variables, parameters, or tables. In addition to each table name, a number, specifying the amount of storage to be allocated for that table must be given. This number is positive if the table is two dimensional and negative if one dimensional, with absolute value determined by the formula:

$$N = 3 + I + J + D$$

where

N = The total storage required by the table, in words.

* For certain components, default values are provided for some parameters.

I = The number of data points in the primary independent variable table.

J = The number of data points in the secondary independent variable table. (J=0 if there is only one independent variable.)

D = The number of data points in the dependent variable table. (D=I if there is only one independent variable. $D=I*J$ if there are two independent variables.)

The following example from reference [1] illustrates the use of FORTRAN STATEMENTS:

Example 2.2

MODEL DESCRIPTION	PARAMETER STUDY
.	.
.	.
.	.
ADD TABLES = WIND,802	
LOCATION = 41 TI	
FORTRAN STATEMENTS	
C	READ WIND VELOCITY DATA
	WV1WD = TBLU2(TD TI,DY TI,WIND(35),WIND(4),
	1 WIND(59),0,0,24,-31,24,31)
LOCATION = 71 WD	INPUTS = TI
.	.
.	.
.	.

In this model, Fortran is used to input wind velocity data. The wind table, denoted WIND, consists of up to 31 days of hourly wind speeds. Hence, as

described previously, the total storage required is $3+24+31+24*31=802$. The Fortran is inserted after time of day and day of the year are computed in TI. In this case, $N=24$, $M=31$, the data is equal spaced, and extrapolation is used to provide velocity data over each 24 hour period. The variable WVIWD is the name of the wind input to WD generated by the precompiler. Fortran insertion in the model ends when the `LOCATION=71 ...` command is read and a call to the subroutine WD is then generated.

Note: When interpolation of one dimension, equi-spaced data is desired, it is possible to reduce the table dimension and table input by using the following alternative procedure:

- (1) Set the table dimension for the ADD TABLES command to $6+N$, where N is the length of the dependent variable data.
- (2) The call sequence for linear interpolation is changed to

$$F = \text{TBLU1}(X, \text{TAB}(4), \text{TAB}(6), 0, +N),$$

where F is the interpolated value at the desired point X and TAB is the one dimension table name specified in the ADD TABLES command.

- (3) The tabular data input to the simulation program as specified in 3.1-2 is modified such that only the first two values of the independent variable table are specified, i.e., the data cards for the table TAB may be input as follows:

Card 1	TABLE, TAB = N1
Card 2	X1, X2
Card 3	Y1, Y2, ... YN

where $N1 = N/2 + 1$ if $N1$ is even and $N1 = (N+3)/2$ if N is odd, $X1, X2$ are the first two values of the independent variable table, and $Y1, \dots, YN$ are the values of the dependent variable table.

LIST STANDARD COMPONENTS

The LIST STANDARD COMPONENTS command phrase causes the program to print a list of all standard components. For each standard component, lists of inputs, outputs, and tables for that component are provided. For each input, the physical quantity name and port number is given. For each output, the physical quantity name, port number, and the letter S, if the quantity is a state is given. For each table, the table name, the number of independent variables and the maximum amount of storage allowed is provided. This command is usually given as the first command of a model description and will result in a list of all standard component information as the first output from the Model Generation program.

2.2 NAMING CONVENTION

All standard components are given names consisting of two characters, the first of which is alphabetical. Thus we have WT for wind turbine, GE for generator, WD for wind model, etc. Where multiple components of the same type are required, the second character is used to distinguish between the different models of the same basic component type. A specific component in a model can be distinguished from other components of the same type by adding one more character to the standard component name. This character is usually numeric but can also be alphabetical or blank. Thus a given model can contain up to 37 different components of the same standard component type. For example, a model with ten different wind turbines might have these components designated as:

WT1,WT2,WT3,.....,WT8,WT9,WT10

2.2.1 Variable, Parameter, and Table Naming Conventions

All of the input, output, and tabular quantities required by each component in a system model must have unique FORTRAN names. These quantities are given names consisting of up to three characters that describe the physical quantity they represent.

Since a single component may have several inputs or outputs of the same physical quantity, a port number may be added to the second or third character of the physical quantity name to prevent duplication.

The physical quantities that are outputs of a given component are identified by concatenating the three character name of that component to the three character name of the physical quantity. In this way, unique six character FORTRAN names are generated for all output quantities of the system model.

Input quantities to a component that are driven by another component carry the names of the component that drives them. Any inputs that are not driven by other model components are assumed to be parameters and are assigned the name of the component for which they are an input.

If a component should require tabular data as an input, unique table names are generated just as scalar input quantity names by adding the component name to the table name. A pictorial representation of the character assignment in component, variable, and table names is given in Figure 2.2-1.

2.3 MODEL SCHEMATIC

The Model Generation program produces an information flow or schematic diagram of the system being modeled. This schematic is crude but is inexpensive and does not have the flow delays associated with more elaborate plotting methods. Its purpose is to provide a means of rapidly locating errors in the model description.

In order to construct a schematic diagram in an efficient manner with a reasonable size program, it was necessary to establish some simple rules for symbol generation, component connection paths, and labeling. If these rules are kept in mind when laying-out a schematic for the system, the SIMWEST produced schematic will match that developed by the analyst. If the rules are violated, the SIMWEST schematic should still be correct, but may contain some unusual component connection paths and some labeling information may be overwritten.

INPUT/OUTPUT OR TABLE NAMES




FIGURE 2.2-1 CHARACTER ASSIGNMENT INPUT/OUTPUT OR TABLE NAME

2.3.1 Standard Schematic Form


The SIMWEST schematic diagrams are produced on a standard 11" by 14" line-printer page with 80 component locations per page. A standard form containing only the location numbers can be obtained by executing the Model Generation program with the single program command, PRINT. This form can then be reproduced and the copies used as forms for drawing system model schematics.

2.3.2 Input Quantity Labeling


The names of the physical quantities that are input to one component from another component are listed adjacent to the downstream component symbol. These labels are placed near the connecting line that joins the two components. Since these names are composed of the physical quantity name and the name of the component that generates the information, the source of the input is evident from the name itself. Parameter and tabular inputs to a component are not shown on the schematic. These constant inputs are described in the Input Requirements List.

2.3.3 Component Connection Paths

In order to keep the requirements of the SIMWEST schematic subroutine small, it was necessary to limit the types of connecting paths between components to a few basic routes. These paths are shown in Figure 2.3-1. Connections between components on the same horizontal or vertical line are straightforward. However, connections between components that do not share a horizontal or vertical line require a two segment path. These paths have been arbitrarily chosen to follow a clockwise route. It is therefore advisable that components that are on diagonal locations be placed in a clockwise sequence. If counter-clockwise flow between components is necessary, it can be accommodated by placing the components on the same horizontal or vertical lines.



POSSIBLE OUTPUT PATHS



POSSIBLE INPUT PATHS

FIGURE 2.3-1 COMPONENT CONNECTION PATHS

The SIMWEST schematic subroutine makes no attempt to go around components that get in the way of a connection path. Such components are "run-over" by the connecting line.

2.3.4 Additional Pages

The SIMWEST schematic diagram may be broken into as many pages as are necessary. No attempt is made to draw connecting paths between components located on different pages. It is therefore advisable to minimize the number of connecting paths between pages. This can usually be done by grouping components with many interconnections on the same page and placing page boundaries between such groups of components.

2.3.5 Guidelines for Schematic Layout

The following guidelines may help in creating schematic layouts that can be duplicated by the SIMWEST program.

1. Try to place connected components on the same horizontal or vertical line.
2. Avoid placing components on adjacent location points.
3. Place diagonal components so that flow is clockwise.
4. Group components to minimize flow paths between pages.

2.4 WARNING MESSAGES

One or more of the following warning messages will occur if the program is unable to interpret a portion of the model description or encounters problems in assembling the system model. These messages will be preceded by: *** WARNING *** or *** NOTICE ***. The symbols xxx and zzz are used to indicate phrases from the model description that are included as part of the warning message. The following messages are listed in alphabetical order:

1. CAN'T IDENTIFY xxx AS A STANDARD COMPONENT

xxx will contain the first two characters of the phrase which cannot be identified as a command or standard component. This message will often follow other warning messages as the program makes successive attempts to interpret the given phrase.

2. CAN'T IDENTIFY xxx AS A VALID INPUT COMPONENT TO zzz

The component xxx cannot be found in the list of components for the current system model.

3. CAN'T LOCATE xxx AS AN INPUT COMPONENT TO LOCATION n

This message indicates that the component xxx, which provides inputs to location n in the schematic, has not been assigned a location number. Check for a missing LOCATION statement or misspelling of the component name.

4. COMPONENT xxx DEFINITION WASN'T COMPLETED BEFORE STARTING THE DEFINITION OF COMPONENT zzz

The command INPUTS was not given between the component names xxx and zzz. Check for proper spelling of INPUTS and a valid delimiter after the phrase xxx.

5. COMPONENT xxx HAS ALREADY BEEN DEFINED

The component xxx was defined in a previous LOCATION statement.

6. LOCATION NO. xxx FOR COMPONENT zzz HAS LAST TWO DIGITS OUTSIDE THE ALLOWABLE RANGE 1 TO 80. NO SYMBOL WILL BE PLACED IN SCHEMATIC FOR THIS COMPONENT

This message will occur at the end of the model description for a component zzz which has an invalid location number. The system model may still be valid but the schematic will not contain this component.

7. NO xxx OUTPUTS MATCH UNSATISFIED zzz INPUTS

Check that it was intended to drive component zzz with component xxx or that the inputs to zzz have been previously satisfied by other component connections.

8. TABLE NAME xxx MUST BE FOLLOWED BY A NUMERIC DIMENSION RATHER THAN zzz

When using the ADD TABLES command, it is necessary to provide the maximum amount of storage to be allocated for the table as well as the table name. This storage value must be a numeric quantity.

9. THE FOLLOWING COMPONENTS FORM AN IMPLICIT LOOP. xxx, zzz,

Implicit loops can often be corrected by inserting a component with a state variable as its output, e.g., a simple linear lag, LA. All models containing FORTRAN STATEMENTS will receive this warning.

10. THE SEQUENCE OF THE FOLLOWING COMPONENTS HAS BEEN ALTERED TO FORM AN EXPLICIT MODEL. xxx, zzz, ...

The model component sequence as given contained implicit equations. By altering the component sequence it was possible to form an explicit model.

11. xxx IS NOT A VALID INPUT QUANTITY OR PORT DESIGNATION FOR COMPONENT zzz

The phrase xxx cannot be located as one of the input quantities or input ports of the component zzz. No connections will occur. Check the list of standard components for the proper spelling or port designations for this component.

12. xxx IS NOT A VALID LOCATION NUMBER

The LOCATION command must be followed by a numeric location number.

13. xxx IS NOT A VALID PORT DESIGNATION FOR INPUT COMPONENT zzz. ERRONEOUS CONNECTIONS MAY OCCUR.

The phrase xxx cannot be located as a valid input port for the component zzz. Connections will be attempted using the upstream output port that was identified.

2.5 MODEL GENERATION LIMITATIONS

Certain limitations exist in the Model Generation program due to array dimensions within the program. For most applications these limits should not be encountered. However, if they should be encountered they can usually be extended at the expense of larger core requirements to execute the program. The following table describes these limitations:

<u>Limitation Description</u>	<u>Maximum Value</u>
Standard components in library	150
Components per model	200
States per model	200
Inputs per any standard component	50
Outputs per any standard component	50
Tables per any standard component	15
Ports per any standard component	10
Tables per model	100
Table dimension (words)	960

3.0 SIMULATION PROGRAM

Once a model has been generated as described in Section 2.0, the user must describe the simulation he wishes to perform. This involves specifying the various parameters detailing the model components and setting the model initial conditions. It involves defining input data tables and the type and quantities of printed output, both tabular and plotted. The user must also specify the number of iterations he wishes to perform at each time step and the maximum number of component diagnostics. This section describes the commands for specifying the simulation and gives some example output.

3.1 MODEL INPUT DATA

A dynamic system model requires that the values of model parameters, tables and initial conditions, be provided to complete the model description. Sections 3.1.1, 3.1.2 and 3.2 describe the methods used to specify parameter values, tables, and initial conditions.

3.1.1 Scalar Data

PARAMETER VALUES (Default values = .99999)

This program command allows the numeric values of parameters to be loaded into the system model. The PARAMETER VALUES command is followed by one or more parameter names followed by a numeric value. Each name and its value are separated by one of the standard delimiter symbols. This command is used to specify the values of all system model parameters at the beginning of an analysis. It may also be used at any point between analyses to modify the value of one or more model parameters. A default value of .99999 is provided by the Model Generation program for all parameters not so specified.

PRECEDING PAGE BLANK NOT FILMED

Example 3.1-1

PARAMETER VALUES = CYCLES = 6.01, TO TI = 0, EW WP = .2,
CR CM = 15, LE CM = 30, MDEHS = 4.E5,

3.1.2 Tabular Data

If tabular data is required by the system model, it should be loaded before any of the simulation commands described in Section 3.4 are issued. Tables may be modified between analyses by loading new values. The tables required by a SIMWEST generated model are specified in the Input Requirements List. These tables may have either one or two independent variables. All data items are in a free field format with each item separated by one of the standard delimiters: comma [,], equal sign [=], left or right parenthesis [()], or three or more consecutive blank spaces. The data items required for each table are placed on cards as follows:

Card 1	TABLE	table name	NX	NZ
Card 2*	Z table values			
Card 3*	X table values			
Card 4*	Y table values			

where: Table Name - The six character table name generated by the Model Generation program.

NX - The number of points in the primary independent variable table.

NZ** - The number of points in the secondary independent variable table.

Z table ** - Table of NZ secondary independent variable values.

X table - Table of NX independent table values.

Y table - 1 or NZ tables of NX dependent variable values.

* As many cards as required may be used. Each table must start with a new card and NZ, NX, and NX*NZ points must be given per table.

** These items are omitted for tables with one independent variable.

A copy of all tabular input data is printed as it is interpreted from data cards. The following example shows the data cards for a one and a two independent variable table.

Example 3.1-2

Card 1	TABLE, TABONE, 10
Card 2	1, 2, 3, 4, 5, 6, 7, 8, 9, 10
Card 3	11, 12, 13, 14, 15, 16, 17, 18, 19, 110
Card 4	TABLE, TABTWO, 5, 4
Card 5	10.3, 20.4, 30.5, 40.6
Card 6	1, 2, 3, 4, 5
Card 7	11, 12, 13, 14, 15
Card 8	21, 22, 23, 24, 25
Card 9	31, 32, 33, 34, 35
Card 10	41, 42, 43, 44, 45

The printout of these tables would be:

TABLE TABONE									
PRIMARY INDEPENDENT VARIABLE TABLE									
1.000	2.000	3.000	4.000	5.000	6.000	7.000	8.000	9.000	10.00
DEPENDENT VARIABLE TABLE									
11.00	12.00	13.00	14.00	15.00	16.00	17.00	18.00	19.00	110.00
TABLE TABTWO									
SECONDARY INDEPENDENT VARIABLE TABLE									
10.30	20.40	30.50	40.60						
PRIMARY INDEPENDENT VARIABLE TABLE									
1.000	2.000	3.000	4.000	5.000					
DEPENDENT VARIABLE TABLE									
11.00	12.00	13.00	14.00	15.00					
21.00	22.00	23.00	24.00	25.00					
31.00	32.00	33.00	34.00	35.00					
41.00	42.00	43.00	44.00	45.00					

3.2 INITIAL CONDITION, ERROR, AND INTEGRATION CONTROLS

INITIAL CONDITIONS (Default value = 0)
ERROR CONTROLS (Default value = 0.1)
INT CONTROLS (Default value = 1.0)

These program commands may be used to specify state variable initial condition values, integrator error controls, and integrator status, (either active (=1) or frozen (=0)). Default values are furnished by the simulation program. However, it is strongly recommended that values appropriate to the particular system model be furnished for the initial conditions and error controls.

Each of these commands is followed by phrases of the form of a state name followed by a numeric value.

Example 3.2-1:

INITIAL CONDITIONS = MA HS = 1.6E6, E TS = 600, VDELO = 0,
ERROR CONTROLS = MA HS = 10,
INT CONTROLS = MA HS = 0, E TS = 1, VDELO = 1,

ALL STATES (Default Condition)
NO STATES

These program commands may be used to activate or freeze all system integrators. These commands are normally used together with the INT CONTROLS command to specify the desired integrator configuration.

3.3 INITIAL CONDITION STORAGE COMMANDS

XIC-X
XIC-XIC1
XIC-XIC2
XIC-XIC3
XIC1-XIC
XIC2-XIC
XIC3-XIC

These program commands are used to transfer data from the current state vector, X, to the initial condition vector, XIC, and between the XIC vector and three auxiliary initial condition vectors XIC1, XIC2, XIC3.

Example 3.3-1

XIC1-XIC, XIC-X, XIC2-XIC

The three program commands shown above would take the current operating point (initial condition vector) and store it in vector XIC1; then transfer the current state, X, into XIC; and then store that value of XIC in XIC2.

3.4 SIMULATION COMMANDS

SIMULATE

This program command initiates simulation operation. Associated with this command are the program values:

<u>Default Values:</u>		
TINC	= time increment, hours	0.1
TMAX	= duration of the simulation run, hours	1.0
INT MODE	= integration mode control	3
OUTRATE	= output rate	1
PRATE	= print rate	1
PRINT CONTROL	= print control variable	0

These program commands specify the integration time increment, duration of simulation run, the integration mode, the simulation output rate, the printing rate, and the quantity of printing, at each point in time. These quantities should be specified before the first issuance of the SIMULATE command.

The Time increment, TINC, provides the integrator time step size, in hours, for the integrator. TINC also provides the report interval for which data will be available for printing or plotting. The default value for TINC is 0.1.

The duration of a simulation calculation in hours, is specified by the TMAX parameter. The default value of TMAX is 1.

The integration mode control, INT MODE, allows one of three different integration methods to be selected according to the values given below. The default value of INT MODE is 3.

Integration Method Selection

INT MODE	Method
1	Variable Step, Variable Order Gear
2	Variable Step, 4th Order Runge-Kutta
3	Fixed Step Euler (2nd order)

The error controls specified in Section 3.2 determines the system step except for INT MODE = 3.

The output rate parameter, OUTRATE, determines the sampling rate at which simulation data is added to plots. Thus, if OUTRATE is set equal to 10, data will be plotted every 10th time increment, TINC. The default value of OUTRATE is 1. OUTRATE should only be set to positive integer values.

The number of data samples plotted for a simulation analysis is thus given by:

$$\text{No. of Plotted Samples} = \frac{\text{TMAX}}{\text{TINC} \cdot \text{OUTRATE}} + 1$$

For most simulation operation, the plotted output specified by the DISPLAY commands is the primary output and little printer output is used. However, for diagnosing problems in a simulation, the line printer options provided by the PRINT CONTROL parameter allow large amounts of detailed information about the simulated system to be obtained.

The value of the PRINT CONTROL parameter controls the quantity of data printed at each report interval as shown in Table 3.4-1. Options 1 through 4 give "snap-shots" of all states, rates, variables, and parameters of the system model at a particular point in time. Option 5 provides tabular lists of up to 10 specified quantities.* The default value for PRINT CONTROL is 0.

TABLE 3.4-1

Print Control Values

PRINT CONTROL	Resultant Lineprinter Output.
0	None (Default Condition)
1	All states, rates, and time
2	All states, rates, variables, and time
3	All states, rates, variables, and parameters at time = 0
4	All states, rates, variables, and parameters
5	Time and the quantities specified via PRINT VARIABLES command.

The PRATE parameter determines the sampling rate at which the simulation data specified by the PRINT CONTROL parameter is presented on the lineprinter. Thus if PRATE is set equal to 5, data will be printed on the lineprinter every 5th

* See the PRINT VARIABLES command description below.

time it is added to the output plots. The rate of output to the lineprinter can never be greater than that to the plots. The default value of PRATE is 1. PRATE should only be set to positive integer values.

The number of data samples printed for a simulation analysis is thus given by:

$$\text{No. of Printed Samples} = \frac{\text{TMAX}}{\text{TINC} * \text{OUTRATE} * \text{PRATE}} + 1$$

Example 3.4-1:

```
PRINT CONTROL = 2, TINC = .01, TMAX = 10.,  
OUTRATE = 10, PRATE = 10, SIMULATE
```

In the example, the simulation would run for 10 hours. Plotted output would occur every .1 hour, (10* .01), and printed output would occur every 1. hour (10* 10* .01).

PRINT VARIABLES

This program command allows up to ten variables to be specified for printing under option 5 of the PRINT CONTROL. This command is followed by from one to ten state, rate, or variable names separated by delimiters. This command wipes out all previously stored PRINT VARIABLES names.

Example 3.4-2:

```
PRINT VARIABLES = MA HS, E TS, VDELO
```

3.5 PLOT DESIGNATION COMMANDS

```
PRINTER PLOTS  
PLOT OFF
```

The above program commands allow the plotted output to be turned on or off. The default condition is PLOT OFF. It is therefore necessary to include the PRINTER PLOTS command before requesting any analysis from which plots are desired. The PLOT OFF and PRINTER PLOTS commands can be issued between simulation requests if it is desired to omit the plotting of certain analysis results.

DISPLAY1
DISPLAY2
DISPLAY3
DISPLAY4
DISPLAY5
DISPLAY6

These program commands may be used to define the quantities to be displayed by lineprinter plots for simulation calculations. These commands must be issued before the simulation analysis is requested. From one to five plots may be specified per display. Each plot is specified by stating the dependent variable and the independent variable separated by the letters VS. If desired, the independent and dependent axis scale ranges can also be specified. The independent scale range is specified by the word X RANGE followed by the minimum and maximum values for this scale. The dependent scale similarly is specified by the word Y RANGE. If scale ranges are not specified, values will be used that span the given data.

SI MANUAL SCALES

SI AUTO SCALES (Default Condition)

The SI MANUAL SCALES command allows the plotted output requested by the DISPLAY commands to be plotted on manual scales specified by the Y RANGE and X RANGE commands. The SI AUTO SCALES command can be used to return plotting to the automatic scaling mode. Auto scales are selected so that they span each plotted quantity. The auto scale option is the default used until manual

scales are requested. The PRINTER PLOTS command is also required to obtain plots.

Example 3.5-1:

```
SI MANUAL SCALES, PRINTER PLOTS
DISPLAY1
WV2WD, VS, TIME, YRANGE = 10,40
P1 PD, VS, TIME, YRANGE = 0,1000
P2 PD, VS, TIME, YRANGE = 0,1000
DISPLAY2
P2 IV, VS, TIME
RE2BA, VS, TIME
RE1LO, VS, TIME
DISPLAY3
P1 PD, VS, P2 PD, YRANGE =0,1000, X RANGE = 0,1000
```

TITLE

The TITLE command allows a title to be placed on all plotted output. Up to 74 characters may follow the delimiter after the TITLE command. The TITLE command may be changed before each analysis. Once defined, the title remains in effect until a new title is entered.

Example 3.5-2:

```
TITLE = BATTERY TEST MODEL
```

3.6 ITERATION AND DIAGNOSTIC CONTROL

There are three built-in parameters in any SIMWEST model: CYCLES, D LINES and RESET. These parameters are specified similar to component parameters using the PARAMETER VALUES command.

CYCLES controls the number of iterations through the model to obtain steady state. If $CYCLES < 1$, then only one pass is made through the model. If CYCLES is a positive integer then the maximum number of iterations through the model is equal to $CYCLES + 1$. If cycles is positive, but not an integer, then the maximum number of iterations is equal to the smallest integer value exceeding cycles. A maximum of 20 iterations are permitted per time step. Most of the models tested require no more than six iterations per time step to attain steady state. A complex model with cascaded logic components may require more.

Each of the model output variables are monitored each pass for convergence. If all of the outputs are converged within 3% of their previous values, then one final pass is made through the model. Otherwise, all variables exceeding 5% of their previous value are printed out after the last iteration.

Since output statistics are only updated the last iteration, some of the variables printed indicating nonconvergence are statistics, and as such should be ignored.

DLINES controls the amount of convergence related printout as well as the amount of diagnostic printout from the library components. If $DLINES > 0$ then the total number of diagnostics is limited to DLINES. Figure 3.6 shows a typical section of diagnostic printout using $DLINES > 0$. If $DLINES < 0$ then only library component diagnostics are printed with no more than $-DLINES$ of output. Typically, $DLINES = 50$ is sufficient to catch most simulation errors per run.

TS STORAGE TEMPERATURE	59,899	OUTSIDE MINIMUM	60,000	AND MAXIMUM	212,000
TS STORAGE TEMPERATURE	59,731	OUTSIDE MINIMUM	60,000	AND MAXIMUM	212,000
TIME=	88.50				
P2 HT	NONCONVERGENCE, OLD VALUE=	31,913	NEW VALUE=	30,309	
P2 GE	NONCONVERGENCE, OLD VALUE=	30,638	NEW VALUE=	29,098	
PL GE	NONCONVERGENCE, OLD VALUE=	1,275	NEW VALUE=	1,211	
M8 RESERVOIR VOLUME	77210,404	DROPPED BELOW MINIMUM	80000,000		
TS STORAGE TEMPERATURE	59,664	OUTSIDE MINIMUM	60,000	AND MAXIMUM	212,000
TS STORAGE TEMPERATURE	59,964	OUTSIDE MINIMUM	60,000	AND MAXIMUM	212,000
TS STORAGE TEMPERATURE	59,936	OUTSIDE MINIMUM	60,000	AND MAXIMUM	212,000

FIGURE 3.6 TYPICAL DIAGNOSTIC OUTPUT

RESET controls the initialization value for the random number generators if several simulations are run back to back. If $\text{RESET} > 0$ (Default) then the same random numbers are used for each simulation. If $\text{RESET} \leq 0$ then the random numbers at the start of each simulation are obtained from the last value at the end of the previous simulation.

3.7 DEFINE COMMANDS

DEFINE STATES
DEFINE RATES
DEFINE PARAMETERS
DEFINE VARIABLES

These program commands may be used to replace model generated names by user defined alphanumeric names for system states, rates, parameters, and variables. (State variable derivatives, (Rates), are generated as R1, R2, ... for all models. R1, R2, ... refer to the rates of the first, second, ... states respectively.) If it is desired to replace these machine generated names with other names, the DEFINE command may be used to substitute any eight character name of the analyst's choosing. These names are associated with the corresponding numeric quantities located in the labeled commons /CX/, /CXDOT/, /CP/, and /CV/. The appropriate location for each quantity is printed out along with the quantity name prior to each simulation. Each of these commands is followed by phrases containing the location numeric followed by an alphanumeric name with one to eight characters the first of which must be alphabetic.

Example 3.7:

DEFINE STATES

1 = PRESSURE, 2 = STROKE, 5 = VELOCITY, 7 = ANGLE

DEFINE PARAMETERS

5 = MASS, 35 = DCT AREA

DEFINE VARIABLES, 1 = T OUTLET, 2 = LIQ H2O

Note that the program commands, numeric values and alphanumeric names must be separated by delimiters which are: comma [,], equals [=], left parentheses [()], right parenthesis [)], or three or more consecutive spaces.

3.8 FUNCTION SCAN COMMANDS

SCAN1

SCAN2

These program commands initiate the calculation of general algebraic functions of one or two independent variables. Associated with these commands are the program names and values

1. DEPEN = dependent variable
2. INDEP1 = 1st independent variable
3. INDEP2 = 2nd independent variable
4. START1 = starting point of 1st independent variable
5. STOP1 = stopping point of 1st independent variable
6. START2 = starting point of 2nd independent variable
7. DELTA2 = increment of 2nd independent variable
8. CURVES2 = number of 2nd independent variable values

which specify the dependent and independent variables and scan ranges of these quantities. These quantities must be set to their desired values, before

requesting the general algebraic function evaluation. If a single function is requested, i.e., SCAN1, only items 1, 2, 4 and 5 need be specified.

Example 3.8:

```
DEPEN = I PV, INDEP1 = ST1S0, INDEP2 = TC FP, START1 = 0
STOP1 = 3000, START2 = 20, DELTA2 = 30, CURVES2 = 4
SCAN2
```

In this example, the output current of a photovoltaic array, I PV, is calculated as a function of solar insolation, ST1S0, and cell temperature, TC FP (See Example 9.2).

3.9 EXAMPLE OUTPUT

Figure 3.9 shows a sample of the output print format generated using PRINT CONTROL = 3. This sample is taken from the Fresnel Lens Collector Model described in Section 9.3, which is a simple model. At each print time the output quantities are indexed by number and component name as they occur in the model. For example, first all the variables for component TI are printed, then all variables for component ED, etc. The parameter values at time = 0 show both the input values and the default parameters. After T = 0 only the states, rates, and output variables are printed. Since all the model connection variables and output variables are printed, this mode is especially valuable for program debugging and analysis at a fixed time. The printer plots, samples of which are shown in Sections 8 and 9 are useful for monitoring the time behavior of critical parameters such as energy in storage and percent of load delivered by storage.

PRINT RATE= 12 DISPLAY RATE= 1 MODE= 3 TINC= .51000 TMAX= 168.00

FRESNEL LENS COLLECTOR (INCREMENTAL COST COMPUTATION)

CASE NO. 1

79/03/12. 15.59.05.

ED: STATION ID=13985

YEAR 1960

TIME = 0.
1 0P FO = 0. 2 E TS = 80.000 3 VDET = 0. 4 VDELO = 0.

RATES
1 R1 = 0. 2 R2 = -.95760 3 R3 = .78800E-12 4 R4 = 0.

VARIABLES
1 T TI = 0. 2 TD TI = .10000E-05 3 TW TI = .10000E-15 4 DW TI = 1.0000 5 DY TI = 1.0000
6 MY TI = 1.0000 7 MY TI = 1.0000 8 X1 ED = 0. 9 X2 ED = 0. 10 X3 ED = .60000
11 X4 ED = 11.050 12 X5 ED = 0. 13 X6 ED = 0. 14 X7 ED = 0. 15 X8 ED = 0.
16 FO MA = 37.778 17 TC FO = .60000 18 TS FO = .60000 19 FMOFO = 0. 20 T1 FO = 0.
21 T2 FO = 0. 22 PH FO = 0. 23 P1 FO = 0. 24 REAFO = 0. 25 REFFO = 0.
26 LTIFO = 0. 27 V PV = 0. 28 P PV = 0. 29 I PV = 0. 30 EF1PV = 1.0000
31 EF2PV = .33800 32 SP PV = 0. 33 I TS = 0. 34 MP2TS = 158.22 35 INTTS = 0.
36 T TS = 100.00 37 M TS = 6825.9 38 CCOTS = 50.400 39 RE2TS = 24.000 40 MF TS = 8.9647
41 LD TS = .15760 42 TSUTS = 100.00 43 TSLTS = 100.00 44 ME TS = 80.000 45 MFUTS = 8.9647
46 RE TL = .15760 47 PC TL = 100.00 48 SLOTL = .39400E-11 49 SRETL = .39400E-01 50 REILO = 0.
51 L02LO = 0. 52 SRELO = 0. 53 SDELO = 0. 54 PC LO = 0. 55 TIMLO = -1.0000
56 CN LO = -.32624 57 DUMCM = 0.

PARAMETERS
1 TO TI = 0. 2 NX ED = 4.0000 3 INDED = .99999 4 TS ED = -.50000 5 M1 ED = .99999
6 M2 ED = .99999 7 M3 ED = .99999 8 M4 ED = .99999 9 M5 ED = .99999 10 M6 ED = .99999
11 M7 ED = .99999 12 M8 ED = .99999 13 A1 ED = .99999 14 A2 ED = .99999 15 A3 ED = .99999
16 A4 ED = .99999 17 A5 ED = .99999 18 A6 ED = .99999 19 A7 ED = .99999 20 A8 ED = .99999
21 C1 MA = .55556 22 C2 MA = -17.778 23 TFOFO = 42.778 24 CMFOFO = 2.0000 25 AL FO = .90000E-01
26 TAUF0 = 1.0000 27 ABCFO = .95000 28 EFFF0 = .12000 29 SPAFO = .25000E-01 30 EL FO = .90000
31 ES FO = .50000 32 EI FO = .50000 33 CW FO = 3.7500 34 CL FO = 3.9000 35 NL FO = 120.00
36 RC FO = .60000E-01 37 ABLFO = .50000E-01 38 SPFO = 4184.0 39 HI FO = .10000E-01 40 FIRFO = 1.0000
41 NT FO = 24.000 42 MFMFO = .50000 43 DT FO = .15000E-11 44 COSFC = 202.00 45 THSFO = .30000E-02
46 DENFO = 980.00 47 COCFO = .65700 48 HC FO = .10000E+10 49 CC FO = 24.000 50 CM FO = 50.000
51 COPFO = 2.0000 52 VT PV = .99999 53 TL PV = 28.000 54 TH PV = 120.00 55 TR PV = 120.00
56 SL PV = 1000.0 57 SH PV = 25000. 58 SR PV = 25000. 59 RC PV = 25.000 60 AA PV = .60000
61 MS PV = 600.00 62 NP PV = 5.0000 63 I1 PV = .60000E-11 64 I2 PV = 1.5000 65 I3 PV = .50000E-01
66 I4 PV = 1.5600 67 V1 PV = .60000 68 R3 PV = .55000E-11 69 A0 PV = .15400E+34 70 EG0PV = 14000.
71 IL1PV = .60000E-04 72 DS PV = .29215E-14 73 DT PV = .11799E-17 74 DSTPV = .18118E-07 75 KD PV = .20131E-31
76 CF PV = .99999 77 GRKPV = 11610. 78 RAPPV = 1.3000 79 CC PV = 100.00 80 CM PV = 50.000
81 NU TS = .10000E-01 82 TS TS = 5.0000 83 VO TS = .99999 84 TMITS = 212.00 85 TO1TS = 60.000
86 DH TS = .87700E-02 87 PD TS = 12.000 88 PM TS = 24.000 89 MFMTS = 9000.0 90 TDETS = 4.0000
91 EF1TS = .99999 92 MP1TS = .10000E+09 93 CP2TS = .29300E-13 94 TO2TS = 40.000 95 TM2TS = 212.00
96 R TS = .30800E-03 97 CM TS = 7.2000 98 CSATS = 50.000 99 CSBTS = 15.200 100 LE TS = 30.000
101 VE TL = .50000E-01 102 NC TL = .20000 103 TD LO = .99999 104 DW LO = .99999 105 WY LO = .99999
106 NC LO = .99999 107 CT LO = .99999 108 MN LO = 0. 109 STOLO = .99999 110 VE LO = .50000E-01
111 MP1LO = .10000E+11 112 EF1LO = .99999 113 CR CM = 15.000 114 LE CM = 20.000 115 CYCLES = 4.0100
116 DLINEs = 50.000 117 RESET = .99999

FIGURE 3.9 SAMPLE PRINTER OUTPUT

BCS 40262-1

ORIGINAL PAGE IS
OF POOR QUALITY

4.0 JOB CONTROL PROCEDURES

This chapter describes the job control procedures used on the BCS computer network MAINSTREAM-EKS to execute SIMWEST and to develop library components. The user at other CDC computer installations should consult his maintenance organization for extensions and variations to these procedures.

4.1 JOB ENVIRONMENT

The CDC version of SIMWEST was developed for a user with primary computer access via a communications terminal. The job control procedures described below are contained within the user's procedure file PROFIL stored as one of the user account permanent files. These procedures are for a CDC installation using the Network Operating System (NOS) and can be modified for a KRONOS operating system. They enable a user to easily edit files, compile Fortran source on-line, and to submit jobs in interactive or remote job entry modes. Job output may be directed to the terminal, stored in a user controlled file, or disposed to a remote line printer, depending on the procedure and user requirements. These procedures enable the user to minimize development time in constructing system models, and to minimize computer resources when performing system simulations.

4.2 SIMWEST PROGRAM EXECUTION

Four procedures have been developed for constructing SIMWEST system models and running simulations:

- EASYM - Interactive execution of the model generation program with output to user file EASYOUT
- EASY - Batch execution of the model generation and analysis programs with output to an RJE terminal printer

- EASYA - Batch execution of the model generation and analysis programs with output to user files EASYOUT, ANALOUT, and PLOTOUT
- EASYB - Similar to EASY, but includes the capability to input TMY tape environmental inputs (See Section 7.8)

The following is a summary of the usage of these procedures.

EASYM

This procedure is used in timeshare mode to generate the user's Fortran model and system schematic to verify the system model connections. The job command card is

```
CALL (,EASYM(DATAM=MODEL)
```

where MODEL is the user's model generation input file. The output file EASYOUT contains a readback of the input file with error diagnostics, the system model schematic, and the model data requirements list. A compilation listing of the Fortran model is also output to a local or temporary file COMPOUT. Figure 4.2-1 is a listing of the job control cards for EASYM.

EASY

This procedure is used to launch a SIMWEST batch job from a terminal. The job command card is

```
CALL (,EASY(DATAM=MODEL,DATAA=SIMUL)
```

where MODEL is the user's model generation input file and SIMUL is the user's input file for the simulation program. (It is not necessary to run the model generation program each time, but this is normally done since it is inexpensive

```

EASYM
*EXECUTES EASY MODEL GENERATION PROGRAM VIA KIT
RETURN(PROG,DATA)
ATTACH(PROG=EASY4/PW=PSWD,UN=SIMWES)
GET(DATA=DATAM)
ATTACH(TAPE78=WMPF/PW=PSWD)
RFL(70000)
MAP(PART)
LOADXEQ(F=PROG,S=DATA,EASYOUT,TAPE78)
TYPE.NORMAL #EASY# TERMINATION SEE FILE #EASYOUT# FOR OUTPUT
PACK(EASYOUT)
REPLACE(EASYOUT)
GOTO,10.
EXIT.
TYPE.ABNORMAL #EASY# TERMINATION SEE LOCAL FILE #EASYOUT# FOR OUTPUT
PACK(EASYOUT)
RETURN(TAPE78,TAPE7,TAPE13)
GOTO,100.
10,RETURN(TAPE78,TAPE7,TAPE8,TAPE10,TAPE11,TAPE12,TAPE13,DATA,PROG)
REWIND(TAPES,EASYOUT,MODEL8,COMPOUT)
FTN(A,B=MODEL8,I=TAPE9,OPT=0,R=1,L=COMPOUT)
TYPE.SUCCESSFUL MODEL COMPILE SEE LOCAL FILE #COMPOUT# FOR LISTING
RETURN(TAPE9)
PACK(COMPOUT)
GOTO,100.
EXIT.
TYPE.UNSUCCESSFUL MODEL COMPILE SEE LOCAL FILE #COMPOUT# FOR LISTING
PACK(COMPOUT)
RETURN(TAPE9)
100,EXIT.
*END OF PROCEDURE EASYM

```

FIGURE 4.2-1 JOB CONTROL PROCEDURE 'EASYM'

and provides a complete listing of the model associated with a simulation run.) Figure 4.2-2 gives a listing of the control cards for EASY. The job dayfile is also output to user file DAYFLE so that a user can verify whether a job ran successfully prior to receiving the lineprinter output.

The control cards shown in Figure 4.2-2 are for the general case in which the user maintains and updates his own component library files WMPF and WMCOMP. If the user is not developing new library routines, then this procedure can be simplified by replacing the control cards

```
ATTACH(WMCOMP/PW=PSWD)
REWIND(ULIB,MAPF)
LIBGEN(F=WMCOMP,P=ULIB)
RETURN(WMCOMP)
```

by the card

```
ATTACH(ULIB=SIMLIB/PW=PSWD).
```

The permanent library file SIMLIB is easily generated by using the above four control cards plus

```
DEFINE(SIMLIB/PW=PSWD)
COPYEI(ULIB,SIMLIB)
RETURN(ULIB,SIMLIB).
```

EASYA

This procedure is used to launch a SIMWEST batch job from a terminal with output to user files for rapid inspection of output and subsequent printout as desired. The job command card is

```
CALL(,EASYA(DATAM=MODEL,DATAA=SIMUL)
```

```

SIMWES,T30,CM110000,P04.
USER,EEXX15,EEXX15. A.W. WARREN/ 575-5095 / 9C-01 /
*BATCH SIMWEST JOB
NODECK.
RFL(77000)
EXIT(U)
* MODEL GENERATION PROGRAM
*
RETURN(TAPE78,TAPE7)
ATTACH(TAPE78=WMPF/PW=PSWD)
COPYRR(,DATA)
REWIND(DATA)
COPYSBF(DATA)
REWIND(DATA)
ATTACH(PROG=EASY4/UN=SIMWES,PW=PSWD)
MAP(PART)
LOADXEQ(F=PROG,S=DATA,M=/MAPF)
RETURN(TAPE78,TAPE7,PROG)
REWIND(TAPE9)
FTN(A,B=MODELX,I=TAPE9,OPT=0,R=1)
* SIMULATION PROGRAM
*
REWIND(DATA)
COPYRR(,DATA)
REWIND(DATA)
COPYSBF(DATA)
REWIND(DATA,PROG,MODELX,F)
ATTACH(F=NONSIM4/UN=SIMWES,PW=PSWD)
COPYL(F,MODELX,PROG)
RETURN(F,MODELX)
REWIND(PROG)
ATTACH(WMCOMP/PW=PSWD)
REWIND(ULIB,MAPF)
LIBGEN(F=WMCOMP,P=ULIB)
RETURN(WMCOMP)
RFL(110000)
LOADXEQ(F=PROG,U=ULIB,S=DATA,M=/MAPF)
GOTO(20)
EXIT.
REWIND(MAPF)
COPYEI(MAPF)
20,RETURN(PROG)
* PRINTER PLOT PROGRAM
*
REWIND(TAPE30)
ATTACH(NSMPPT/UN=SIMWES,PW=PSWD)
RFL(76000)
MAP(OFF)
LOADXEQ(F=NSMPPT)
100,EXIT(U)
DAYFILE(DAYFLE)
REPLACE(DAYFLE)
EXIT.
* --END OF PROCEDURE EASY.

```

FIGURE 4.2-2 JOB CONTROL PROCEDURE 'EASY'

where MODEL and SIMUL are the model generation and simulation input file names. The output of the model generation program and the model Fortran listings are contained in file EASYOUT. Similarly, ANALOUT contains the output of the simulation program, PLOTOUT contains the output of the printer plot program, and DAYFLE contains the job dayfile. The user is cautioned to print out results of interest before reexecuting this procedure since only the most recent program output is saved on the output files. Procedure LIST may be used for this purpose (see Section 4.3).

Figure 4.2-3 shows the control cards for EASYA. If the model generation or simulation program load and execute step aborts, a load map is also copied onto the respective output file for error traceback and debugging.

EASYB

This procedure launches a SIMWEST batch job using the TMY tape for environmental inputs, i.e., whenever the user's system model includes an ED component. The TMY tape is blocked into logical records, each record containing environmental data for a 24 hour period. There are 26 stations on the tape with each station containing a standard meteorological year of 365 days. Thus the user must edit EASYB whenever a different station or data record length is required. A procedure TMYRD is used to select and copy that portion of the TMY tape to be input for subsequent analyses. See Figure 4.2-4. The command card to launch a SIMWEST job using EASYB is

```
CALL(,EASYB(DATAM=MODEL,DATAA=SIMUL)
```

where MODEL and SIMUL are the model generation and simulation input file names. Each EASYB job mounts the TMY tape and creates a local file TAPE1 for input to the simulation program. If many simulations are required using the same TMY input data, then TAPE1 can be saved and the TMYRD cards in EASYB replaced with

```
FILE(TAPE1,CM=YES,MBL=3168,FL=132,RB=24,RT=F,BT=K)  
GET(TAPE1)
```

This eliminates creation of the input file TAPE1 for each separate SIMWEST job.

```

PEEK,T20,CM110000,P04.
USER,EEXX15,EEXX15. A.W. WARREN /575-5095/ 9C-01 /
*BATCH SIMWEST JOB WITH OUTPUT TO USER FILES.
MODECK.
RFL(77000)
* MODEL GENERATION PROGRAM
*
RETURN(TAPE78,TAPE7)
ATTACH(TAPE78=WMPF/PW=PSWD)
COPYBR(,DATA)
REWIND(DATA)
ATTACH(PROG=EASY4/PW=PSWD,UN=SIMWES)
MAP(PART)
LOADXEQ(F=PROG,S=DATA,EASYOUT,M=/MAPF)
RETURN(TAPE78,TAPE7,PROG)
REWIND(TAPE9)
FTN(A,B=MODEL8,I=TAPE9,OPT=0,R=1,L=EASYOUT)
GOTO(10)
EXIT.
REWIND(MAPF)
COPYEI(MAPF,EASYOUT)
SET(R1=2)
10,PACK(EASYOUT)
REPLACE(EASYOUT)
IF(R1.EQ.2)GOTO(100)
* SIMULATION PROGRAM
*
REWIND(DATA)
COPYBR(,DATA)
REWIND(DATA,MODEL8,F)
ATTACH(F=NONSIM4/PW=PSWD,UN=SIMWES)
COPYL(F,MODEL8,PROG)
REWIND(PROG)
ATTACH(WMCOMP/PW=PSWD)
REWIND(ULIB,MAPF)
LIBGENIF=WMCOMP,P=ULIB)
RETURN(WMCOMP,=)
RFL(110000)
LOADXEQ(F=PROG,U=ULIB,S=DATA,ANALOUT,M=/MAPF)
GOTO(20)
EXIT.
REWIND(MAPF)
COPYEI(MAPF,ANALOUT)
20,PACK(ANALOUT)
REPLACE(ANALOUT)
* PRINTER PLOT PROGRAM
*
REWIND(TAPE30)
ATTACH(NSMPPT/PW=PSWD,UN=SIMWES)
MAP(OFF)
LOADXEQ(F=NSMPPT,S=PLOTOUT)
PACK(PLOTOUT)
REPLACE(PLOTOUT)
100,EXIT(U)
DAYFILE,DAYFLE.
REPLACE(DAYFLE)
EXIT:
* --END OF PROCEDURE EASYA.

```

FIGURE 4.2-3 JOB CONTROL PROCEDURE 'EASYA'

```

TMYSIM,T20,CM11000C,P04.
USER,EEXX15,EEXX15. A.W. WARREN /575-5095/ 9C-01 /
*BATCH SIMWEST JOB USING TMY TAPE INPUTS
NODECK.
RFL(77000)
*MODEL GENERATION PROGRAM
*
RETURN(TAPE78,TAPE7)
--ATTACH(TAPE78=WMPF/PW=PSWD)
COPYBR(,DATA)
REWIND(DATA)
--COPYSBF(DATA)
REWIND(DATA)
ATTACH(PROG=EASY4/PW=PSWD,UN=SIMWES)
--MAP(PART)
LOADXEQ(F=PROG,S=DATA,M=/MAPF)
RETURN(TAPE78,TAPE7,PROG)
--REWIND(TAPE9)
FTN(A,B=MODEL8,I=TAPE9,OPT=0,R=1)
*   PREPARE TMY TAPE INPUT FILE - TAPE1
*
RFL(30000)
GET(TMYRD/PW=PSWD,UN=SIMWES)
--CALL(TMYRD(NSKIP=2920,NCOPY=9)
*   SIMULATION PROGRAM
*
REWIND(DATA)
COPYBR(,DATA)
REWIND(DATA)
--COPYSBF(DATA)
REWIND(DATA,MODEL8,F)
ATTACH(F=NONSIM4/PW=PSWD,UN=SIMWES)
--COPYL(F,MODEL8,PROG)
RETURN(F)
REWIND(PROG)
--ATTACH(WMCOMP/PW=PSWD)
REWIND(ULIB,MAPF)
LIBGEN(F=WMCOMP,P=ULIB)
--RETURN(WMCOMP)
RFL(110000)
LDSET(FILES=TAPE1)
--LOADXEQ(F=PROG,U=ULIB,S=DATA,M=/MAPF)
GOTO(20)
EXIT.
--REWIND(MAPF)
COPYEI(MAPF)
20,RETURN(PROG)
*PRINTER PLOT PROGRAM
*
REWIND(TAPE30)
--ATTACH(NSMPPT/PW=PSWD,UN=SIMWES)
MAP(OFF)
LOADXEQ(F=NSMPPT)
--100,EXIT(U)
DAYFILE,DAYFLE.
REPLACE(DAYFLE)
--EXIT.
* --END OF PROCEDURE EASYB.

```

FIGURE 4.2-4 JOB CONTROL PROCEDURE 'EASYB'

The job command card to create input file TAPE1 is

```
CALL(TMYRD(NSKIP=N1,NCOPY=N2)
```

where N1 is the number of logical records to skip and N2 is the number of records to be copied from the TMY tape onto TAPE1. These parameters are specified using

```
N1 = 365 * (NSTATION -1) + DSTART -1  
N2 = DEND - DSTART +1
```

where

```
NSTATION = station number of the data file as shown in Table 7.8  
DSTART = first or start day of the desired data file  
DEND = last or end day of the desired file.
```

For example, if a user wanted TMY inputs for April (DSTART = 91 and DEND = 120) at Albuquerque, New Mexico (NSTATION = 13), then N1 = 4470 and N2 = 30. Thus, procedure EASYB would be edited so that the TMYRD call statement reads

```
CALL(TMYRD(NSKIP=4470,NCOPY=30)
```

4.3 FILE MAINTENANCE AND LIBRARY UPDATES

This section describes frequently used procedures for modifying and developing SIMWEST library components. A terminal based user would first create his Fortran component subroutines and any associated subroutines as records within a user file of source routines. The procedures FORMOD and FORMODG are then used to compile these routines and merge the relocatables produced onto the component library WMCOMP. The FILOAD procedure is then called to update the component name list of input and output variables on WMPF. (See Section 6.0

for component coding conventions and preparation of input for the FILOAD program.) Usage of the procedures FORMOD, FORMODG, FILOAD, and LIST are described below.

FORMOD

This procedure is used in timeshare mode to compile a multi-record Fortran source file and merge the object code onto a specified file of relocatable records. The job command card is

```
CALL(,FORMOD(SOURCE=MYFILE,OLD=RELFLE)
```

where MYFILE is the permanent file name of the user's source code and RELFLE is the file name of the relocatable code.

Figure 4.3-1 shows the control cards for FORMOD. If the source code has fatal errors, diagnostics are printed out on the terminal printer. Otherwise the source code listings are disposed to a lineprinter. If no relocatable file is specified, or if RELFLE cannot be found, then the object code is copied onto permanent file 'OLD'.

FORMODG

This procedure is similar to FORMOD except it enables compilation of specified records from a multi-record source file. The job command card is

```
CALL(,FORMODG(SOURCE=MYFILE,OLD=RELFLE)
```

The terminal then prompts the user for the record numbers of the source code to be compiled, i.e., the terminal prints:

```

FORMOD
* COMPILES AND MERGES EXTENDED FORTRAN PROGRAMS
* ACCEPTS MULTIRECORD FILE OF SOURCE CODE --SOURCE--
* PLACES COMPILER LISTING ON --LIST--
* USES CDC EXTENDED COMPILER FTN4.6
*
REWIND(LIST,TEXT)
GET(S1=SOURCE)
GOTO,5.
EXIT.
TYPE,--CAN'T FIND #SOURCE#
GOTO,60.
5,REWIND(S1)
PACK(S1)
RFL(77000)
FTN(A,I=S1,B=TEXT,L=LIST,R=3,OPT=1)
TYPE,SUCCESSFUL FTN COMPILATION
SET(R2=0) ZERO FOR NO FTN ERRORS
CALL(,LIST)
GOTO,10.
EXIT.
SET(R2=1) INDICATE FORTRAN ERRORS
TYPE, FORTRAN ERRORS DETECTED BY EXTENDED COMPILER
RETURN(TEXT,S1)
REWIND(LIST)
ERRLIST,LIST.
TYPE,TO SEND LISTING TO LINEPRINTER% CALL(,LIST)
10,RETURN(S1)
IF(R2.EQ.1)GOTO,60. SKIP MERGE IF ERRORS
*
*MERGES NEW TEXT RECORD --TEXT-- WITH EXISTING MULTIRECORD
* TEXT FILE CONTAINING A RECORD HAVING SAME NAME
* OF SUBROUTINE OR PROGRAM. TEXT FILE IS --OLD--
*
ATTACH(S1=OLD/PW=PSWD,M=W)
GOTO,30.
EXIT.
REWIND(TEXT)
DEFINE(S2=OLD/PW=PSWD)
TYPE,OLD FILE COULD NOT BE FOUND
TYPE, BINARIES ARE PLACED ON PERMANENT FILE #OLD#
COPYEI(TEXT,S2)
GOTO,20.
EXIT.
TYPE, OLD FILE BUSY
TYPE, BINARIES ARE ON LOCAL FILE #TEXT#
GOTO(60)
30,REWIND(S1,OLD,TEXT)
COPYLM(S1,TEXT,OLD,,A)
REWIND(OLD,S1)
COPYEI(OLD,S1)
TYPE,SUCCESSFUL MERGE INTO #OLD# FILE
20,RETURN(S1,TEXT,CLD,S2)
60,RFL(20000)
*--END OF PROCEDURE FORMOD

```

FIGURE 4.3-1 JOB CONTROL PROCEDURE 'FORMOD'

INPUT RECORD NUMBERS

I>

The user enters the record numbers to be compiled followed by two carriage returns (CR), i.e.

I> 3,38 CR

I> CR

This procedure will catalog the records to be compiled, compile the source code and merge the object code onto RELFLE, replacing old object code routines with those just created. Figure 4.3-2 shows the control cards for FORMODG.

FILOAD

This procedure is used in timeshare mode to create or modify input, output and table name and dimension data for SIMWEST library components. The job command card is

CALL(,FILOAD(DATA=NAMES)

where NAMES is the permanent file name of the input data for the FILOAD program. (See Section 6.2 for preparation of the input file.)

If the FILOAD program execution aborts, the user should check the format of the input data since exact spacing of the alphanumeric character inputs is required. Figure 4.3-3 shows the control cards for FILOAD.

LIST

This procedure is used to dispose a local file to be printed. If the local file LOCAL has no printer control characters, then one uses the command cards:

```

FORMODG
* COMPILES AND MERGES EXTENDED FORTRAN PROGRAMS
REWIND(LIST,TEXT)
GET(A=SOURCE)
GOTO,5.
EXIT.
TYPE: CANJT FIND #SOURCE#
GOTO,60.
5,RETURN(OUTPUTX)
*SELECT SOURCE RECORDS TO BE COMPILED
REWIND(PROFIL)
SKIPF(PROFIL,5)
COPY3F(PROFIL,GT)
REWIND(GT,F)
RFL(30000)
GT.
REWIND(F)
CATALOG(F)
RETURN(A,GT,TAPE0,14U)
GOTO,7.
EXIT.
GOTO,60.
* COMPILE SOURCE FILE F
7,PACK(F)
RFL(77000)
FTN(A,I=F,B=TEXT,L=LIST,R=3,OPT=1)
TYPE.SUCCESSFUL FTN COMPILATION
SET(R2=0) ZERO FOR NO FTN ERRORS
RETURN(F)
CALL(,LIST)
GOTO,10.
EXIT.
SET(R2=1) INDICATE FORTRAN ERRORS
TYPE. FORTRAN ERRORS DETECTED BY EXTENDED COMPILER
REWIND(LIST)
ERRLIST,LIST.
TYPE.TO SEND LISTING TO LINEPRINTERX CALL(,LIST)
10,IF(R2.EQ.1)GOTO,20. SKIP MERGE IF ERRORS
ATTACH(S1=OLD/PW=PSWD,M=W)
GOTO,30.
EXIT.
REWIND(TEXT)
DEFINE(S2=OLD/PW=PSWD)
TYPE.OLD FILE COULD NOT BE FOUND
TYPE. BINARIES ARE PLACED ON PERMANENT FILE #OLD#
COPYE1(TEXT,S2)
GOTO,20.
EXIT.
TYPE. OLD FILE BUSY
TYPE. BINARIES ARE ON LOCAL FILE #TEXT#
GOTO(60)
30,REWIND(S1,OLD,TEXT)
COPYLM(S1,TEXT,OLD,,A)
REWIND(OLD,S1)
COPYE1(OLD,S1)
TYPE.SUCCESSFUL MERGE INTO #OLD# FILE
20,RETURN(S1,TEXT,OLD,S2)
60,RFL(20000)
*--END OF PROCEDURE FORMODG

```

FIGURE 4.3-2 JOB CONTROL PROCEDURE 'FORMODG'

```

FILOAD
RETURN(OUTPUTX,DMPFILE,TAPE77,TAPE9)
ATTACH(FILOAD4/UN=SIMWES,PW=PSWD)
ATTACH(TAPE78=WMPF/PW=PSWD,M=W)
GET(TAPE3=DATA)
--RFL(50000)--
TYPE. FILOAD EXECUTION HAS BEGUN
FILOAD4.
--REWIND(TAPE78,TAPE79)--
COPYNF(TAPE79,TAPE78)
TYPE.NORMAL #FILOAD# TERMINATION
--RETURN(TAPE78,TAPE3,TAPE79,FILOAD4)--
EXIT.
TYPE.ABNORMAL #FILOAD# TERMINATION NO DEGAS OCCURED SEE DMPFILE FOR DUMP
--RETURN(TAPE3,TAPE78,FILOAD4)--
*---END PROCEDURE FILOAD---

```

FIGURE 4.3-3 JOB CONTROL PROCEDURE 'FILOAD'

```

LIST
* CONTROLS LIST PRINT, SUBMITS TO PRINTER FROM KIT
* --AS-DESIRED-BY-TERMINAL-USER--
GET(MAILBOX)
EXIT(U)
--REWIND(LIST)--
DISPOSE(LIST=PR/EI=SC1183)
* --END OF PROCEDURE LIST

```

FIGURE 4.3-4 JOB CONTROL PROCEDURE 'LIST'

COPYSBF(LOCAL,LIST)
CALL(,LIST)

To print files such as EASYOUT which contain printer control characters, it suffices to use the command

CALL(,LIST(LIST=EASYOUT))

Figure 4.3-4 shows the control cards for LIST. (See previous page.)

5.0 DIAGNOSTICS

Diagnostic messages are printed by both the model generation and the simulation program. In addition, individual library components generally have diagnostic printout associated with them. The diagnostics associated with the model generation program are discussed in Section 2.0. Section 5.0 describes the diagnostics associated with the simulation program and the library components.

5.1 WARNING MESSAGES

One or more of the following warning messages will occur if the program encounters difficulty in interpreting analysis instructions or performing an analysis. These messages will be preceded by the flag:

*** WARNING ***

Message symbols xxx, zzz, or nnn are used to indicate phrases from the analysis description that are included as part of the warning message. The following messages are listed in alphabetical order:

1. A VALID PARAMETER NAME MUST PRECEDE THE NUMERIC VALUE nnn

This message indicates that a valid parameter name was not identified preceding the numeric value nnn. Check for missing delimiters or misspelled parameter name.

2. xxx CAN'T BE SET EQUAL TO zzz. VALUE MUST BE NUMERIC.

Check for missing numeric value or delimiters.

3. CAN'T IDENTIFY xxx AS A VALID PRINT VARIABLE

Check spelling of xxx or for missing delimiters.

4. CAN'T IDENTIFY xxx VALUE WILL BE IGNORED

This will result in not setting the quantity intended by xxx to its new value. Check for spelling of xxx or for missing delimiters.

5. CAN'T INTERPRET xxx

The phrase xxx cannot be recognized as a valid program command, program name, or program value. Check spelling of xxx or for missing delimiters.

6. nnn EXCEEDS THE ALLOWABLE INDEX RANGE FOR xxx THIS QUANTITY WILL NOT BE DEFINED

The number nnn was outside the allowable range of states, rates, variables, or parameters. Therefore, the name xxx cannot be assigned as a name for the nnnth state, rate, variable or parameter.

7. NON-ALPHA NAME ON THIS CARD --- xxx. WILL IGNORE THIS CARD.

The table inputs routine expected an alphanumeric table name but encountered a numeric value on the data card printed. Check the sequence and number of tabular data cards to assure that they match those required by the model's tables and table input formats. See Section 3.1.2 for correct formats.

8. NON-NUMERIC DATA ON THIS CARD --- xxx. WILL READ NEXT TABLE

The table input routine expected a numeric value but encountered an alphanumeric name on the data card printed. Check that the sequence and number of tabular data cards matches the model's tables and table input formats. See Section 3.1.2 for correct formats.

9. nnn PRIMARY and xxx SECONDARY INDEPENDENT VARIABLE POINTS EXCEEDS THE zzz WORD STORAGE LIMIT FOR THE FOLLOWING TABLE. SOME DATA WILL BE LOST.

The maximum amount of data allowed for each table is given in the Input Requirements List produced by the Model Generation program. Check that given data falls within this limit or for data card errors.

5.2 DIAGNOSTIC MESSAGES FOR LIBRARY COMPONENTS

Diagnostic messages are produced by many components when a critical variable gets out of bounds during analysis. Adjustment of component parameters may be necessary.

In component alphabetical order, these diagnostic messages are:

- AD: INPUT POWER xxxx TOO HIGH RELATIVE TO ADMITTANCE xxxx AND RATED
VOLTAGE xxx
ADMITTANCE POWER LOSS xxxx EXCEEDS INPUT POWER xxxx
- BA: POWER REQUEST xxxx EXCEEDS BATTERY CAPABILITY. CHECK VC, VO, AND RT.
- BN: BN INLET AIR MASS FLOW RATE xxxx GREATER THAN MAXIMUM ALLOWABLE xxxx
- CO: MAX ITERATIONS FOR COMPRESSOR EFFICIENCY. NP, XNP, RS = xxxx, xxxx, xxxx
- CS: CS STORAGE TEMPERATURE xxxx GREATER THAN ALLOWABLE xxxx
CS MASS OF AIR IN STORAGE xxxx BELOW MINIMUM ALLOWABLE xxxx
CS MASS OF AIR IN STORAGE xxxx EXCEEDS MAXIMUM ALLOWABLE xxxx
- ED: INPUT ERROR, DAY OF YEAR DY IS OUT OF RANGE
TAPE INPUT ERROR OR EOF

FL: FLYWHEEL POWER LOSS xxxx EXCEEDS CHARGING POWER xxxx
 FLYWHEEL LOSS xxxx EXCEEDS DISCHARGING POWER xxxx
 FLYWHEEL CLUTCH LOSS xxxx EXCEEDS DELIVERABLE POWER xxxx
 FLYWHEEL KINETIC ENERGY xxxx EXCEEDS CAPACITY xxxx
 FLYWHEEL KINETIC ENERGY xxxx FALLS BELOW MINIMUM REQUIREMENT xxxx

GE: GENERATOR OUTPUT EXCEEDS RATED POWER

HS: HS INLET MASS FLOW RATE xxxx OR OUTLET MASS FLOW RATE xxxx IS GREATER THAN
 MAXIMUM xxxx
 HS RESERVOIR VOLUME xxxx EXCEEDED MAXIMUM ALLOWABLE xxxx
 HS RESERVOIR VOLUME xxxx DROPPED BELOW MINIMUM xxxx

HT: HT TURBINE CHARACTERISTIC PARAMETER OUT OF RANGE
 HT INLET MASS FLOW RATE xxxx GREATER THAN MAXIMUM DESIGN VALUE

HX: HX EXIT TEMPERATURE xxxx GREATER THAN MAXIMUM ALLOWABLE xxxx

IF: IV POWER LOSS xxxx EXCEEDS INPUT POWER xxxx CHECK RATED DC VOLTAGE VDC

MB: WARNING-DIVISOR IN MB EQUALS 0., HAS BEEN SET = 1.

MO: MOTOR INPUT POWER xxxx .GT. RATED INPUT POWER xxxx
 MOTOR SLIP xxxx EXCEEDS RATED POWER SLIP xxxx
 STATOR RESISTANCE xxxx OR DAMPING xxxx TOO HIGH FOR MOTOR

PV: WARNING: INSULATION OR TEMPERATURE AT CELL EXCEED RANGE

RE: RE POWER LOSS xxxx EXCEEDS INPUT POWER xxxx
 RE, AC INPUT POWER xxxx TOO LARGE IN RELATION TO TRANSFORMER REACTANCE
 xxxx AND RATED AC VOLTAGE xxxx

TR: TRANSMISSION POWER LOSS xxxx EXCEEDS INPUT xxxx
TRANSMISSION POWER LOSS xxxx EXCEEDS MAXIMUM INPUT POWER

TS: TS WORKING FLUID FLOW RATE xxxx GREATER THAN MAXIMUM ALLOWED xxxx
TS INPUT POWER xxxx GREATER THAN MAXIMUM ALLOWED CHARGE RATE xxxx
TS STORAGE TEMPERATURE xxxx OUTSIDE MINIMUM xxxx OR MAXIMUM xxxx

TU: TURBINE BACK PRESSURE xxxx GREATER THAN STORAGE VESSEL PRESSURE xxxx

6.0 CREATION OF NEW LIBRARY COMPONENTS

The addition of new standard components to the SIMWEST library involves two steps. The first is the design of the component. This design must conform to certain design conventions if the new component is to be compatible with existing components. Section 6.1 discusses these design conventions and the addition of the component subroutine to the SIMWEST library. The second step involves the addition of the new component's input and output description to the SIMWEST file WMPF. File WMPF is used by the precompiler to generate subroutine calling sequences for the library components. Section 6.2 discusses the use of the FILOAD program to accomplish this task.

6.1 LIBRARY COMPONENT CODING

6.1.1 Component Call Sequence

The items in the component subroutine call sequence must be arranged in the following order:

1. Tables
2. Output Quantities
3. Input Quantities

Tables or inputs may be absent from the subroutine call sequence. However those items that are present must follow the sequence given above.

Dummy argument names for the call sequence quantities that are used within each subroutine should be chosen to match the physical quantity names placed in the input, output, and table name lists. Exceptions to this policy may be made when integer names (names starting with I through N) must be avoided or when additional letters will clarify the name.

PRECEDING PAGE BLANK NOT FILMED

The subroutine name must contain only two characters and must not duplicate the name of an existing standard component.

Tables

The table arrays must be dimensioned within the component subroutine. They must be dimensioned with only one subscript; e.g., DIMENSION TABLE (1). When table data is passed to the component subroutine, the first word in the array contains the name of the table. The second word contains the number of values given for the primary independent variable. The third word contains the number of values given for the secondary independent variable. Both of these numbers are stored as REAL quantities and must be converted to INTEGER before they can be used as a subscript. This can be done by a statement such as:

NX = TABLE (2) - number of primary independent variables

NZ = TABLE (3) - number of secondary independent variables

If there is a secondary independent variable, the secondary independent variable array will begin with the fourth word in the array. Thus if this array is designated as z(1), z(2),, then:

z(1) = TABLE (4)

z(2) = TABLE (5)

z(3) = TABLE (6)

. .
. .
. .

The primary independent variable array begins with word NZ + 4. Thus, if this array is designated as X(1), X(2), ..., then:

X(1) = TABLE (NZ + 4)

X(2) = TABLE (NZ + 5)

. .
. .
. .

The dependent variable array begins with word $NX + 4$ if there is no secondary independent variable. Thus, if this array is designated as $Y(1), Y(2), \dots$, then:

Y(1) = TABLE (NX + 4)

Y(2) = TABLE (NX + 5)

. .
. .
. .

If there is a secondary independent variable array and this array was designated $Y(I,J)$, with $1 \leq I \leq NX$ and $1 \leq J \leq NZ$, then $Y(I,J)$ would be related to the table array as:

$Y(I,J) = \text{TABLE}(NX + NZ + 3 + I + (J-1) * NX)$

Normally the individual elements in the table are not used directly but are passed to a table look-up routine. In this case the starting address of the X, Y, and Z tables would be referred to as:

Z(1) = TABLE (4)

secondary independent variable table

X(1) = TABLE (NZ+4)

primary independent variable table

Y(1,1) = TABLE (NX+NZ+4)

dependent variable table

If more than one table is used by a component subroutine, the table names must appear in the same sequence in the table name list stored in WMPF as in the subroutine call sequence.

Example 6.1: Given a component, HA, that requires the tables TPH and TPC as inputs. The call sequence of this subroutine would appear as:

SUBROUTINE HA(TPH,TPC,...

Output Quantities

The term "output quantity" refers to information that is calculated and then "output" by a particular component subroutine. This is not to be confused with the "outlet quantities" of the component. The outlet quantities are associated with a particular component port as a result of assigning a positive direction of power or information flow through the component. Some outlet quantities may be calculated by the component subroutine and thus become output quantities of that component. While other outlet quantities may be furnished to the component subroutine and thus become input quantities to that subroutine.

Certain output quantities may be internal to the component and not associated with any port. In other cases the same output quantity may be associated with several ports. In such cases, no port designation is assigned to the output quantity. Such quantities are referred to as "universal port" quantities. As such, they are allowed to connect to any other similar physical quantity regardless of the input quantities port number. This is not the case for quantities with specified port numbers. Once a connection has been made between an input and output quantity with given port numbers, only connections of matching physical quantities with those port numbers occur. Manual override of this provision can be made by specifying particular physical quantity connections.

Three quantities are required for each state variable output. The first is the state variable, the second is the state variable derivative, (rate), and the third is an integer quantity, the integrator control variable.

Example: Given a component, HA, with the following outputs:

Physical Quantity	Port No.	
T	3	} Outlet Ports
T	4	
P	1 (State Variable)	} Inlet Ports
P	2 (State Variable)	

The call sequence arguments for these outputs would be:

```
SUBROUTINE HA(TPH,TPC,T3,T4,P1,P1DOT,IP1,P2,P2DOT,IP2,...
```

Input Quantities

The term "input quantity" refers to information that is provided to a particular component subroutine. This is not to be confused with the "inlet quantities" of the component. The inlet quantities are associated with a particular component port as a result of assigning a positive direction of power or information, through the component. Some inlet quantities may be calculated by the component subroutine and thus become output quantities of that component, while other inlet quantities may be furnished to the component subroutine and thus become input quantities to that subroutine.

The input quantities should be grouped together by port. That is, all inlet, (port one quantities), then all outlet, (port two quantities), etc. Port designations for two port components which have the same physical quantity on both inlet and outlet will be: port 1 for upstream or inlet port and port 2 for downstream or outlet port. It is important that the inlet port quantities be listed before any outlet port quantities. If a component has multiple inlet ports, the input quantities associated with each inlet port should be grouped together and listed before any outlet port quantities.

Certain input quantities may be internal to the component and not associated with any port. In other cases, the same input quantity may be associated with several ports. In such cases, no port designation is assigned to the input quantity. Such quantities are referred to as "universal port" quantities. As such, they are allowed to connect to any other similar physical quantity regardless of the output quantities port number. This is not the case for quantities with specified port numbers. Once a connection has been made between an input and output quantity with given port numbers, only connections of matching physical quantities with those port numbers occur. Manual override of this provision can be made by specifying particular physical quantity connections.

Example: Given the component HA described in the above example, with the following inputs:

Physical Quantity	Port No.	
T	1	} Inlet Ports
T	2	
P	3	} Outlet Ports
P	4	
AKH	(universal port quantity)	

The call sequence for these inputs would follow the output arguments, giving the complete call sequence:

```
SUBROUTINE HA(TPH,TPC,T3,T4,P1,P1DOT,IP1,P2,P2DOT,IP2,T1,T2,P3,P4,AKH)
```

The call sequence for standard component subroutines should follow the order shown in Table 6.1-1.

TABLE 6.1-1

COMPONENT SUBROUTINE
CALL SEQUENCE ORDER

1. Tables
2. Output Quantities
 - 2.1 All Outlet Port Quantities*
 - 2.2 All Inlet Port Quantities* (feedback variables)
 - 2.3 All Other Output Quantities
3. Input Quantities
 - 3.1 All Inlet Port Quantities*
 - 3.2 All Outlet Port Quantities* (feedback variables)
 - 3.3 All Other Input Quantities

* Group quantities with the same port number together. If multiple inlet or outlet ports exist, arrange port quantities in order of increasing port numbers.

6.1.2 Additions and Modifications to Component Library

Section 4.3 describes the job control procedures to add a new component to the component library, compile the source code that describes the new component and add the relocatable binaries to the component library WMCOMP.

6.1.3 Coding Conventions

There are several coding rules which apply to any component coded. First of all, the calling sequence must be ordered so that it agrees with that constructed from the FILOAD program. Hence the calling sequence begins with table arrays, is followed by output variables, and then by input parameters. State variables require three sequential parameters in the calling sequence: the state variable, the state derivative, and an integer valued integration control. With the exception of the latter, all parameters in the calling sequence are real valued. In general, one cannot use any local variables or arrays to store information from call to call since there may be several components in the model which call a given subroutine. In other words, local variables can only be used for scratch calculations, unless the computed information is based on COMMON block inputs.

Most of the coding conventions and techniques used are illustrated in Figures 6.1-1 and 6.1-2. Figure 6.1-1 shows the code for the simple power curve component WP. Following the call sequence are a number of comment cards including the component purpose and calling sequence. The table PW is treated as a single dimension Fortran array. Power output is obtained from the table interpolation subroutine TBLU1. (Use of the table interpolation routines TBLU1 and TBLU2 is explained in Section 2.1). The rest of the code shows the conventions used to compute output statistics and add costs for the cost summary. IMPL is an integer variable which indicates the iteration control status:


```

CGE      SUBROUTINE GE(P2,EE,RS,PL,EF2,PM2,PMN,SP,P1,RAP,RSY,RAS,DA,SR,VO,
1 EF1,PM1,CCI,CMI)
C
C      PURPOSE      MODEL AC INDUCTION GENERATOR
C
C      METHOD        MECHANICAL AND ELECTRICAL EFFICIENCIES ARE USED TO COMPUTE
C                   OUTPUT POWER. ROTOR SPEED IS COMPUTED ASSUMING POWER IS
C                   PROPORTIONAL TO SLIP.
C
C      WRITTEN BY A.W. WARREN                                VERSION 1, MARCH 16 1977
C
C      CALL SEQUENCE
C      OUTPUTS
C          P2 - OUTPUT POWER, KW
C          EE - ELECTRICAL EFFICIENCY
C          RS - ROTOR SPEED, RPM
C          PL - POWER LOSS, KW
C          EF2 - OUTPUT PRODUCT EFFICIENCY
C          PM2 - MAXIMUM OUTPUT POWER, KW
C          PMN - MAX. OBSERVED OUTPUT POWER / RATED POWER
C          SP - TOTAL OUTPUT ENERGY, KWH
C
C      INPUTS
C          P1 - INPUT POWER, KW
C          RAP - RATED OUTPUT POWER, KW
C          RSY - SYNCHRONOUS ROTOR SPEED, RPMN
C          RAS - RATED POWER SLIP (DEFAULT = .05)
C          DA - MECHANICAL DAMPING, JOULE-SEC
C          SR - STATOR RESISTANCE, OHMS
C          VO - RATED BUS VOLTAGE, VOLTS
C          EF1 - INPUT PRODUCT EFFICIENCY
C          PM1 - MAXIMUM INPUT POWER, KW
C          CCI - CAPITAL COST/YEAR, $
C          CMI - MAINTENANCE COST/YEAR, $
C
C      COMMON /CIMPL/ IMPL,ICNT /CTIME/ TIME
C      COMMON /COST/ CC,CM,C0,CV /CSIMUL/ DUM(6),TINC,TMAX
C      INITIALIZATION
C
C      IF( IMPL.GT.0) GO TO 10
C      EFF = 1.
C      TMAX1 = TMAX*.99999
C      IF(RSY.EQ..99999) RSY = 1800.
C      IF(RAS.EQ..99999) RAS = .05
C      IF(DA.EQ..99999) DA = 0.
C      IF(SR.EQ..99999) SR = $.4/RAP
C      IF(VO.EQ..99999) VO = 400.
C      IF(PM1.EQ..99999) PM1 = 1.E10
C      PMN = 0.0
C      SP = 0.0
C      RATI = RAP*1000./VO
C      EE = RAP/(RAP + SR*.001*RATI**2)
C
C      COMPUTE ROTOR SPEED AND OUTPUT POWER
C 10 IF( P1.GT. 0.) GO TO 20
C      P2 = 0.0
C      PL = 0.0
C      RS = RSY
C      GO TO 30
C
C 20 A = RAP/(EE*RAS)
C      B = RSY/( A + RSY**2*DA*1.0966E-5)
C      RS = B*(A + P1)
C      P2 = RAP*(RS/RSY - 1.)/RAS
C      IF (P2.GT.RAP.AND.IMPL.EQ.2) WRITE(6,100)
C 100 FORMAT(1H0, 40X,37HGENERATOR OUTPUT EXCEEDS RATED POWER /)
C
C      IF(P2.GT.RAP .AND. IMPL.EQ.2)ICNT=ICNT+1
C      PL = P1 - P2
C      EFF = P2/P1
C 30 EF2 = EF1*EFF
C      PM2 = AMIN1(RAP, PM1*EFF)
C
C      STATISTICS
C      IF(IMPL.LE.1) RETURN
C      PMN = AMAX1(PMN, P2/RAP)
C      SP = SP + P2*.5*TINC
C
C      COST SUMMATION
C      IF( TIME.LT.TMAX1) RETURN
C      CC = CC + CCI
C      CM = CM + CMI
C
C      RETURN
C      END

```

FIGURE 6.1-2 SAMPLE COMPONENT CODE - GE

IMPL = 0 the first time in a simulation that the model (EQMO) is called
= 1 if more iterations and hence subroutine calls are expected at a
given time step
>1 the final iteration through the model

Hence when IMPL = 0, subroutine variables are initialized, default values are assigned, etc. The statistics are only updated at the final iteration when the model has presumably attained steady state values. Finally, the costs are added up when the simulation has reached the maximum time point. Capital costs, maintenance costs, and operating costs are stored in the first three locations of common block COST.

Figure 6.1-2 shows the code for the generator component GE. The program automatically assigns default parameters = .99999. Hence, when IMPL = 0 component dependent default values are assigned whenever the .99999 default is assumed. The code near Format statement 100 shows a typical diagnostic print-out. The diagnostic is only printed if IMPL = 2 since we need only diagnose errors at the final iteration. Note that a counter ICNT is updated each time a diagnostic is printed. It is stored in the second location of common block CIMPL and is monitored to see if diagnostic print lines exceeds DLINEs. If so, IMPL is set to 3 the final iteration, so that no further diagnostics are printed. The last convention observed here concerns the use of the maximum power and product efficiency variables denoted PM1, EF1, PM2, EF2. These variables are used to communicate information to the logic components PD and PA. The efficiency variable EFF is defined as the ratio of output power to input power except when P1 = 0. In this case the old EFF value is used, but in any case EFF = 0 must be avoided since this would communicate a zero efficiency to a logic device which would then generate an infinite request. Observe that EF2 and PM2 represent the joint efficiency and maximum power at the output port as a consequence of the rated generator power and computed input/output efficiency.

C - 2

Storage devices have in addition to the above, certain conventions to communicate with the logic components. An input parameter RE1 for port 1 request is used to initiate power discharge from storage. An output variable RE2 for port 2 request is used to communicate a maximum charge rate request and is usually computed by

$$RE2 = \text{MIN} (MP1, RAP)/EF1$$

where MP1 and EF1 are the input maximum power and input product efficiency, and RAP denotes the maximum storage charging rate. A priority interrupt INT should also be defined so that INT = 1. when storage is empty or at a minimum, INT = 0. if no interrupt is required, and INT = -1. at full storage capacity. The amount of storage is normally a state variable so that the code computes the state derivative at each time point and lets the integrator update the state at each time point.

6.2 FILOAD PROGRAM

In addition to merging the subroutine representing the new standard component into the component library, descriptions of the inputs, outputs, and tables required by the new component must be added to the permanent file WMPF. These lists are used by the Model Generation program to direct the connection of component inputs and outputs. The program FILOAD is provided to perform any of the following tasks:

1. Add new input, output, or table name lists.
2. Replace existing input, output or table name lists.
3. Remove all name lists for specified components.
4. Dump contents of WMPF file onto TAPE9 in input format.

6.2.1 FILOAD Program Commands

The FILOAD program will recognize the following commands.

LIST STANDARD COMPONENTS

The LIST STANDARD COMPONENTS command causes the program to print the input, output, and table lists for all components modified or added to the WMPF file. If this command is not given the program will merely give a message stating the name of the new components being added to the file.

PURGE

The PURGE command can be used to remove a component from the WMPF file. The PURGE command is followed by the names of the components to be purged. The command and the component names must be separated by one of the standard delimiters; i.e., [] three or more blanks, [,] comma, [=] equal sign, [()] left or right parentheses.

Example 6.3: PURGE = CM, TB, OB

This command would remove all lists for the CM, TB, and OB components from the name list file.

SYMBOL

The SYMBOL command may be used to designate the type of symbol that is to appear for each standard component in the lineprinter drawn model schematic diagram. The SYMBOL command is followed by the names of the components each followed by a symbol number. The symbol numbers and their associated symbols are shown in Figure 6.2-1. The SYMBOL command, component names, and symbol numbers are separated by standard delimiters.

Example: SYMBOL, CO = 100, SH = 200, TU = 300, OC = 400

If a symbol number is not specified for a component, the default symbol of a square box will be used.

STANDARD SCHEMATIC SYMBOLS




FIGURE 6.2-1 LIST OF STANDARD COMPONENT SYMBOLS

DUMP FILE

The DUMP FILE command causes the FILOAD program to dump the contents of the WMPF file onto TAPE9, in the input format of the FILOAD program. Thus for each standard component, a list of inputs, outputs, and tables will be produced. This data will be preceded by the command NEW FILE described below. This file may be edited to modify the input, output or tables description of any existing standard component or to derive a new standard component description from an existing one. The results of such an editing would then serve as input data to a subsequent run of the FILOAD program. Unless it is intended to purge the WMPF file and start anew, the NEW FILE command at the beginning of TAPE9 should be removed before the subsequent run of the FILOAD program.

NEW FILE

The NEW FILE command instructs the FILOAD program to construct a new WMPF file. This command must occur as the first card in a set of data describing a completely new WMPF file. Any previous components that may have existed on the WMPF file are purged by this command.

FILE NAME

This command is used to load the file name to be associated with the WMPF file. The current WMPF file name is SIMWEST II. This command is used as:

FILE NAME = SIMWEST II

6.2.2 Input Name Lists

Input name lists are identified by the letters INPT following the component name. Thus, the input name list for a component DC would be introduced with the phrase, DCINPT. This must be followed by a phrase that contains the number of names in the input name list.

The input names are contained on the following data cards, 8 names per card. The names must be left adjusted in fields, 10 characters wide. The names are placed in Columns 1 through 3 of each field. Column 9 of each field can be used to indicate a port number which can be attached to the name to distinguish it from other quantities of the same name that occur with the given component. Thus, to indicate that temperature, T, is an input to port 1, the input name list would be:

Column:	1	2	3	4	5	6	7	8	9	10
Item:	T								1	

This quantity would then be referred to as T1.

Example 6.4:

```
SWINPT = 3
IN.....1.IN.....2.CNT
```

(The dots are used here to indicate blank spaces and would not be included in an actual data card).

These two data cards would indicate that the component SW had 3 input quantity names. A quantity IN appears at port 1, and is to be referred to as IN1. A quantity IN appears at port 2, and is to be referred to as IN2. A third input quantity CNT has no port designation. Note that if a port number is to be attached to a quantity name, that name should contain no more than 2 characters.

The sequence of names in the input name list must match the sequence of input arguments in the component call sequence.

6.2.3 Output Name Lists

Output name lists are identified by the letters OUTP following the component name. Thus, the output name list for a component DC would be introduced with the phrase, DCOUTP. This must be followed by a phrase that contains the number of names in the output name list.

The output names are contained on the following data cards, 8 names per card. The names must be left adjusted in fields 10 characters wide. The names are placed in Columns 1 through 3 of each field. Column 9 of each field can be used to introduce a port number which can be attached to the name to distinguish it from other quantities of the same name that occur with the given component. If the output quantity is a state variable, this must be indicated by placing S in Column 10 of the field. Thus, if power P is a state variable output quantity at port 2, the output name list would be:

Column:	1	2	3	4	5	6	7	8	9	10
Item:	P								2	S

This quantity would then be referred to as P2.

Example 6.5:

TZOUTP = 3
X.....1SX.....2SOUT

(The dots are used here to indicate blank spaces, and would not be included on an actual data card).

These two data cards would indicate that the component TZ had 3 output quantity names. A quantity X appears at port 1. This is a state variable, and will be referred to as X1. A quantity X is also a state variable that appears at port 2. It will be referred to as X2. The quantity OUT is an output variable, not a

state variable, and does not have a port number associated with it. Note, that if a port number is to be attached to a quantity name that name should contain no more than 2 characters. These two characters plus the port number will reach the maximum number of 3 characters in a quantity name.

The sequence of names in the output name list must match the sequence of output arguments in the component call sequence. However, whereas three arguments are provided for each state in the subroutine call sequence, only one name is included in the output name list.

6.2.4 Table Name Lists

Table name lists are identified by the letters TABS, following the component name. Thus, the table name list for a component CM would be introduced with the phrase CMTABS. This must be followed by a phrase containing the number of tables in the table name list. The table names are contained in the following cards, one table name per card. The name is located in the first 3 columns of the card. It must be accompanied by the maximum dimension that is to be provided for this table. This number must be given in columns 4 through 10 and should have a decimal point given. For single independent variable tables this number must be negative. For tables with two independent variables, this number must be positive.

Example:

```
CMTABS = 3
TAM      53.
TAB      43.
TCM     -27.
```

These four data cards would indicate that the component CM had 3 tables. The first two tables TAM and TAB have two independent variables each, as indicated by the positive dimension numbers. The table TCM has only one independent

variable, as indicated by the negative dimension number. 53, 43, and 27 words of storage are to be provided for tables TAM, TAB, and TCM respectively. The maximum storage is related to the maximum number of primary, NX, and secondary, NZ, independent variables by:

$MAX = 3 + NX + NZ + NX * NZ$ for tables with two independent variables

$MAX = 3 + 2 * NX$ for tables with one independent variable

7.0 LIBRARY COMPONENT DESCRIPTIONS

This section describes the mathematical algorithms and input/output structure of the SIMWEST library components. Each component writeup contains a brief textual description of the algorithms, a mathematical expression summarizing its function, a list of input and output variables, a description of the calculation sequence and logic used in the model, and the model code. A figure is provided which shows the nominal input and output connections, and the state variables of each component.

There are a number of features and conventions in the component descriptions which require some elaboration. These are briefly summarized below.

7a. INPUT/OUTPUT NAME LISTS

A potentially confusing factor is the way port numbers on input parameters and output variables are designated. On the model generation input cards the name of the physical quantity and the port number are separated by a comma. For example, the power variable with port designation 1 is denoted P,1. To emphasize the distinction between the physical quantities and port numbers they are listed separately in the name lists of the component writeups. For example, P 1 in the name list denotes the power variable (or parameter) with port designation 1 even though in other parts of the text it may simply be denoted P1.

Another convention in the name lists is that the alphabetic symbol 'O' is shown as Ø to distinguish this symbol from a zero. Elsewhere in the text symbols such as VØ may be referred to as VO.

7b. INPUT PARAMETER SPECIFICATION

All input parameters are associated with default values. Many of the parameters have default values denoted in the parameter description by the letter D.

For example, in the Battery component the default value for terminal resistance, RT, is $D = .001$ ohms. All input parameters for which a default value is not so specified have a default value of .99999. Default values are intended to enable users to put models together quickly by specifying a minimum of input data. Users need only specify detailed parameter values for those components of current interest. One must be careful using this approach since the operating characteristics and efficiency of a 10kw rated device may, for example, be quite different than for a 100kw device.

Any user-specified input parameter can be driven by one or two dimension table lookups using the FU and FV components. This enables the user to build more detailed models using time or other output variables to drive the tables. For example, if one needs to specify cost of peak load generation to the utility component as a function of peak load request, then one adds FU as an input to UT and specifies load request as an input connection to FU. The desired function table for FU is specified in the simulation input.

It may be noted that not all of the components have maintenance or operating cost inputs. Thus, whenever these costs are important, one can aggregate such costs and input lumped costs to the model. For example, the maintenance cost of the hydro storage system may include maintenance costs for the pump and turbine.

7c. COMPONENT LOGIC

In constructing SIMWEST components, we have adopted several conventions to aid communication with the logic components. All physical components distributing power are given two input parameters EF and MP (port 1) and two output variables EF and MP (port 2). The output EF is the product efficiency of all components in the distribution subsystem up to and including the given component, and MP is the maximum power deliverable at the output of the component. Each storage component has in addition a power request input denoted RE (port 1), a power request output denoted RE (port 2), and a priority interrupt flag denoted INT.

Figure 7.0 shows the logic and physical variable connections for power flow in and out of a hydro reservoir. Power flows from the power divider to the pump at a rate not to exceed the request RE from HS. The HS request is computed by dividing the input maximum power by the input (or pump) efficiency EF. Hence, the maximum power flowing to HS cannot exceed $RE \cdot EF = MP$. Similarly, the input request to HS is computed by the PA component so as not to exceed the maximum input power MP divided by EF (turbine efficiency). Hence, the power that flows to PA cannot exceed $RE \cdot EF = \text{input maximum power}$.

When the hydro reservoir is empty, the interrupt flag is turned on and the priority sequence is changed so that the reservoir is given access to power flowing into the divider.

7d. UNITS

Most of the SIMWEST components are coded in English units. However, SI or metric units were used to code the solar-photovoltaic components: ED, SO, FP, FO, and PV. This is generally not a problem since there are at most only a few interconnection variables between the solar-photovoltaic generation components and other SIMWEST components, and units conversions are easily handled using an MA arithmetic component. (See for example the Fresnel Lens Model, Section 9.3.)





FIGURE 7.0 SAMPLE CONNECTIONS FOR LOGIC COMPONENTS

7.1 ADMITTANCE



The admittance model can be used to model transmission lines, transformers, capacitors or impedance power flows. A primary assumption is that the reactive parameters dominate the real parameters so that power transfer angle is solely based on reactive values, and power losses are based on the real admittance parameters and on power angle. The equation for power loss is based upon the following model:




FIGURE 7.1 ADMITTANCE NETWORK MODEL

$$\begin{pmatrix} I1 \\ I2 \end{pmatrix} = \begin{pmatrix} G1 + jB1 & GM + jBM \\ GM + jBM & G2 + jB2 \end{pmatrix} \begin{pmatrix} V1 \\ V2 \end{pmatrix}$$

Where the reactive parameters B_1 and B_2 do not enter into the power loss calculations.

Inputs

<u>Parameter/Port</u>	<u>Description</u>	<u>Units</u>
G1,GM,G2	Real admittance parameters *	mho
BM	Reactive admittance parameter *(≠0)	mho
V0	Rated voltage magnitude	volts
P 1	Input power	kw
EF 1	Input product efficiency	-
MP 1	Maximum input power	kw
CC	Capital cost/year	\$

Outputs

<u>Variable/Port</u>	<u>Description</u>	<u>Units</u>
P 2	Output power	kw
PL	Power loss	kw
PA	Power angle	deg
EF 2	Output product efficiency	-
MP 2	Maximum output power	kw

* - See next page for User Input to Model Transmission lines, Transformers and Impedances.

Transmission Line Input:

$$G1 = G2 = g * l$$

$$GM = -g * l$$

$$BM = 1 / (\omega * L * l)$$

where g = line conductance per unit length

l = length of line

ω = frequency in radians/sec = 120π

L = line inductance per unit length

Transformer Input:

$$G1 = G2 = GM = 0$$

$$BM = 1 / X * h$$

where X = reactance in ohms

h = turns ratio

(No power loss modeled with a transformer)

Impedance Input: (Includes capacitors and inductors)

$$G1 = G2 = -GM = R / (R^2 + X^2)$$

$$BM = X / (R^2 + X^2)$$

where R = resistance in ohms

X = reactance in ohms

$$= \begin{pmatrix} \omega L & \text{for an inductance } L \\ -\frac{1}{\omega C} & \text{for a capacitance } C \end{pmatrix}$$

Calculation Sequence

If $P_1 \leq 0$ $P_2 = PL = PA = 0$ and Return

1) Compute power angle

If $P_1 * 1000 > BM * V_0^2$, $\cos \theta = 0$ and write DIAGNOSTIC

$$\theta = -\sin^{-1}(P_1 * 1000 / BM * V_0^2)$$

$$PA = \theta * 180 / \pi$$

$$\cos \theta = \sqrt{1 - (P_1 * 1000 / BM * V_0^2)^2}$$

2) Compute power loss and output power

$$PL = V_0^2 * (G_1 + G_2 + 2 * GM * \cos \theta) / 1000$$

$$P_2 = P_1 - PL$$

$$EFF = P_2 / P_1$$

If $P_2 > 0$ go to 3)

write DIAGNOSTIC

$$EFF = 1.$$

3) Efficiency and maximum output power

$$EF_2 = EF_1 * EFF$$

$$MP_2 = \min(MP_1, |BM| * V_0^2 / 1000) * EFF$$

4) Compute costs

C4D

SUBROUTINE AD(P2,PL,PA,EF2,MP2, G1,GM,G2,BM,VO,P1,EF1,MP1,CC)

PURPOSE MODEL OF TRANSMISSION LINES, TRANSFORMERS,
CAPACITORS, OR IMPEDANCE POWER LOSS

METHOD OUTPUT POWER AND POWER LOSS COMPUTED FROM
INPUT POWER

WRITTEN BY Y.K.CHAN

VERSION 1, JULY, 1977

CALL SEQUENCE

OUTPUTS

P2 -OUTPUT POWER, KW
PL -POWER LOSS, KW
PA -POWER ANGLE, DEG
EF2 -OUTPUT PRODUCT EFFICIENCY
MP2 -MAXIMUM OUTPUT POWER, KW

INPUTS

G1,GM,G2 -REAL ADMITTANCE PARAMETERS, MHO
BM -REACTIVE ADMITTANCE PARAMETERS (.NE.0.), MHC
VO -RATED VOLTAGE MAGNITUDE, VOLTS
P1 -INPUT POWER, KW
EF1 -INPUT PRODUCT EFFICIENCY
MP1 -MAXIMUM INPUT POWER, KW
CC -CAPITAL COST/YEAR, \$

COMMON /CIMPL/IMPL, ICNT/CTIME/TIME/CSIMUL/DUM(7), TMAX
X /COST/CCI

REAL MP2, MP1

P2=0.

TMAX1=TMAX*.99999

IF(P1.GT.0.)GO TO 10

P2=0.

PL=0.

PA=0.

MP2=MP1

EF2=EF1

GO TO 400

COMPUTE POWER ANGLE

10 RR=P1*1000./(BM*VO*VO)

RR2=RR*RR

IF(RR2.LE.1.)GO TO 100

PA=-90.

RRC=0.

IF(IMPL.EQ.2)WRITE(6,108)P1,BM,VO

108 FORMAT(1H0,13H INPUT POWER ,F12.3,33H TOO HIGH RELATIVE TO ADMITTA
XNCE ,F12.3,19H AND RATED VOLTAGE ,F12.3)

IF(IMPL.EQ.2)ICNT=ICNT+1

GO TO 200

100 THETA=-ASIN(RR)


PA=THETA*180./3.14159

RRC=SQRT(1.-RR2)

COMPUTE POWER LOSS AND OUTPUT POWER

```
C
C
200 PL=VO*VO*(G1+G2+2.*GM*RRC)/1000.
   P2=P1-PL
   EFF=P2/P1
   IF(P2.GE.0.)GO TO 300
   P2=0.
   EFF=1.
   IF(IMPL.NE.2)GO TO 300
   WRITE(6,308)PL,P1
308 FORMAT(1H0,24H ADMITTANCE POWER LOSS ,F12.3,21H EXCEEDS INPUT POWE
   XR ,F12.3)
   ICNT=ICNT+1
C
300 EF2=EF1
   IF(P2.GT.0.)EF2=EF1*EFF
   IF(P2.GT.0.)MP2=AMIN1(MP1,ABS(BM)*VO*VO/1000.)*EFF
C
400 IF(IMPL.LE.1)RETURN
   IF(TIME.LT.TMAX1)RETURN
   CCI=CCI+CC
C
RETURN
END
```

7.2 TEST FUNCTION GENERATOR



Inputs

Parameter/Port

C0D

Description

Specifies which analytic function is calculated. (See equations below for use of these inputs)

C1

C2

C3

C4

C5

Outputs

Variable/Port

F0

Output variable

Calculation Sequence

- C0D = 1 $F0 = C1 + C2 * \sin(C3 * T + C4)$
 - 2 $F0 = C1 + C2 * \cos(C3 * T + C4)$
 - 3 $F0 = C1 + \exp(-C5 * T) * \sin(C3 * T + C4)$
 - 4 $F0 = C1 + \exp(-C5 * T) * \cos(C3 * T + C4)$
 - 5 $F0 = C1 + C2 * T$
 - 6 $F0 = C1 + C2 * \exp(-C3 * T)$
- where: T = TIME


```

CAF
SUBROUTINE AF(F0,COD,C1,C2,C3,C4,C5)

C
C PURPOSE - TO SIMULATE ANALYTICAL FUNCTIONS
C
C
C METHOD - SEE CODING
C
C
C WRITTEN BY - ADAM LLOYD
C
C LATEST REVISION
C
C FEB 76
C
C LIMITATIONS - NONE
C
C INPUT/OUTPUT LIST
C
C
C F0          OUTPUT VARIABLE          ANY      OUTPUT VAR
C COD        CODE IDENTIFYING ANALYTICAL FUNCTION  ---      INPUT  PARAM
C
C          CODE=      F0=
C          1          C1+C2*SIN(C3*TIME+C4)
C          2          C1+C2*COS(C3*TIME+C4)
C          3          C1+C2*EXP(-C5*TIME)*SIN(C3*TIME+C4)
C          4          C1+C2*EXP(-C5*TIME)*COS(C3*TIME+C4)
C          5          C1+C2*TIME
C          6          C1+C2*EXP(-C5*TIME)
C
C C1          CONSTANT INPUTS FOR ABOVE EQNS          ---      INPUT  PARAM
C C2          CONSTANT INPUTS FOR ABOVE EQNS          ---      INPUT  PARAM
C C3          CONSTANT INPUTS FOR ABOVE EQNS          ---      INPUT  PARAM
C C4          CONSTANT INPUTS FOR ABOVE EQNS          ---      INPUT  PARAM
C C5          CONSTANT INPUTS FOR ABOVE EQNS          ---      INPUT  PARAM
C
COMMON/CTIME/TIME
NCODE=COD
GO TO (10,20,30,40,50,60),NCODE
10  F0=C1+C2*SIN(C3*TIME+C4)
GO TO 100
20  F0=C1+C2*COS(C3*TIME+C4)
GO TO 100
30  F0=C1+C2*EXP(-C5*TIME)*SIN(C3*TIME+C4)
GO TO 100
40  F0=C1+C2*EXP(-C5*TIME)*COS(C3*TIME+C4)
GO TO 100
50  F0=C1+C2*TIME
GO TO 100
60  F0=C1+C2*EXP(-C5*TIME)
100 RETURN
END

```

7.3 BATTERY



The battery model is based on the circuit diagram shown below. Current flow is determined by the output power request minus input power. Battery leakage is proportional to stored energy. Priority interrupt logic is activated when a minimum or maximum capacity level is attained.




FIGURE 7.3 BATTERY CIRCUIT DIAGRAM

Basic Equations

The output power $P2$, stored energy PE , terminal current I , and capacitor voltage VC is computed using the following equations:

$$P2 = RE1$$

$$PE = (VC^2 + 2*V0*VC)*CB/7.2 \times 10^6$$

$$(P2 - P1) * 1000 = (V0 + VC)I - I^2 * RT$$

$$PE = -(I + VC/RL)(VC + V0)/1000$$

Inputs

<u>Parameter/Port</u>		<u>Description</u>	<u>Units</u>
P	1	Input power	kw
VØ		Internal voltage	volts
RT*		Terminal resistance ($D = 0.001$)	ohms
CB ¹		Battery capacitance ($D = 2.88 \times 10^8$)	farads
RL ¹		Leakage resistance ($D = 0.05$)	ohms
RAP		Rated input power	kw
EF	1	Input product efficiency	-
MP	1	Maximum input power	kw
E1		Maximum energy storage	kwh
RE	1	Power request	kw
EDE		Energy deadband for priority resequencing	kwh
DT		Down time for priority resequencing	h
CC		Capital cost/year	\$
CM		Maintenance cost/year	\$

Outputs

<u>Variable/Port</u>			
P	2	Output power (=RE1)	kw
PE		Stored energy (state of charge)	kwh
I		Terminal current (+out, -in)	amps
VC		Capacitor voltage	volts
VT		Terminal voltage	volts
PL		Power loss	kw
TØ		Time when battery was discharged	h
MP	2	Maximum output power	kw
INT		Priority interrupt flag	-
RE	2	Maximum charging rate request	kw

D - Default values supplied

1 - Battery leakage time constant in hours = $CB \cdot RL / 3600$

* - RT may be used as an adjustment parameter for specifying battery efficiency at rated power.

Statistics

Variable/Port

Description

Units

MPE	Maximum stored energy	kwh
SPC	Sum of charging energy	kwh
SPD	Sum of discharging energy	kwh

Calculation Sequence

- 1) Compute VC

$$VC = \sqrt{7.2 \times 10^6 * PE / CB + V_0^2} - V_0$$

- 2) Solve for terminal current I

If $(P_2 - P_1) * 1000 \geq (VC + V_0)^2 / 4 * RT$, GO TO 2'

$$I = \frac{(VC + V_0) - \sqrt{(VC + V_0)^2 - 4 * RT * (P_2 - P_1) * 1000}}{2 * RT}$$

Go to 3)

- 2') $I = (VC + V_0) / 2 * RT$ and write DIAGNOSTIC

- 3) Compute VT

$$VT = VC + V_0 - I * RT$$

- 4) Potential energy balance and power loss

$$PE = -(I + VC / RL) (VC + V_0) / 1000.$$

$$PL = (I^2 * RT + VC^2 / RL) / 1000.$$

- 5) Maximum charging and discharging rates

$$RE_2 = \min(MP_1, RAP, (E_1 - PE) / TINC) / EF_1$$

$$MP_2 = \min(RAP, (VC + V_0)^2 / (4000 * RT), (PE - EDE) / TINC)$$

where TINC = integration step size

Calculation Sequence Cont.

6) Priority interrupt logic

If $PE \leq EDE$ and $T0 = 10^6$, $T0 = TIME$

If $PE \leq EDE$ and $TIME - T0 \geq DT$, $INT = 1$ and go to 7)

$T0 = 10^6$

If $PE > 2 * EDE$ and $INT = 1$, $INT = 0$

If $PE \geq E1$, $INT = -1$

If $PE < E1 - EDE$ and $INT = -1$, $INT = 0$

7) Compute Statistics and Costs

CBA

SUBROUTINE BA(P2,PE,PED,IPE,I,VC,VT,PL,TU,MP2,INT,RE2,MPE,SPC,SPD,
1 P1,VO,RT,CB,RL,RAP,Ef1,MP1,E1,RE1,EDE,DT,CC,CM)

PURPOSE BATTERY MODEL

METHOD COMPUTE STORED ENERGY AND POWER OUTPUT AS
FUNCTIONS OF POWER INPUT AND POWER REQUEST.
A RESISTOR/CAPACITOR NETWORK IS USED TO
MODEL BATTERY STORAGE.

WRITTEN BY Y.K.CHAN

VERSION 1, JUNE 3,1977

CALL SEQUENCE

OUTPUTS

P2 -OUTPUT POWER, KW
PE -STORED ENERGY (STATE),KWH
PED -STORED ENERGY DERIVATIVE
IPE -INTEGRATOR CONTROL
I -TERMINAL CURRENT (+=OUT, -=IN),AMPS
VC -CAPACITOR VOLTAGE, VOLTS
VT -TERMINAL VOLTAGE, VOLTS
PL -POWER LOSS, KW
TU TIME WHEN BATTERY WAS DISCHARGED, HR
MP2 -MAXIMUM OUTPUT POWER, KW
INT -PRIORITY INTERRUPT FLAG
RE2 -MAXIMUM CHARGING RATE REQUEST, KW

STATISTICS

SPC -SUM OF CHARGING ENERGY, KWH
MPE -MAXIMUM STORED ENERGY,KWH
SPD -SUM OF DISCHARGING ENERGY, KWH

INPUTS

P1 -INPUT POWER, KW
VO -INTERNAL VOLTAGE, VOLTS
RT -TERMINAL RESISTANCE, OHMS
CB -BATTERY CAPACITANCE, FARADS
RL -LEAKAGE RESISTANCE, OHMS
RAP -RATED INPUT POWER, KW
Ef1 -INPUT PRODUCT EFFICIENCY
MP1 -MAXIMUM INPUT POWER, KW
E1 -MAXIMUM ENERGY STORAGE, KWH
RE1 -POWER REQUEST, KW
EDE -ENERGY DEADBAND FOR PRIORITY RESEQUENCING, KWH
DT -DOWNTIME FOR PRIORITY RESEQUENCING, HR
CC -CAPITAL COST/YEAR, \$
CM -MAINTENANCE COST/YEAR, \$

COMMON /CIMPL/IMPL,ICNT/CTIME/TIME/CSIMUL/DUM(7),TMAX/COST/CCI,CM1
REAL I,MP2,MPE,MP1,INT
TINC1=DUM(7)*.5

IF(IMPL.GT.0) GO TO 100
IF(RT.EQ..99999)RT=.001
IF(CB.EQ..99999)Cb=2.88E6
IF(RL.EQ..99999)RL=.05
TU=1000000.
INT=0
TMAX1=TMAX*.99999

TINC=DUM(7)

MPE=0.

SPC=0.

SPD=0.

CAPACITOR VOLTAGE

100 VC=SQRT((PE*7.2E6/CB)+VO*VO) - VO

TERMINAL CURRENT

P2=RE1

AA=(P2-P1)*4000.*RT

B=VC+VO

B2=B*B

IF(AA.GT.B2) GO TO 200

I=B-SQRT(B2-AA)

I=I/(2.*RT)

GO TO 300

200 I=B/(2.*RT)

IF(IMPL.EQ.2)WRITE(6,208)P2

208 FORMAT(1H0,15H POWER REQUEST ,F12.3,50H EXCEEDS BATTERY CAPABILITY

1. CHECK VC,VO, AND RT.)

IF (IMPL.EQ.2)ICNT=ICNT+1

TERMINAL VOLTAGE

300 VT=VC+VO-I*RT

POTENTIAL ENERGY BALANCE AND ENERGY LOSS

IF(IPE.NE.0)PED=-((1+ VC/RL)*(VC+VO)/1000.

PL=(I*I*RT+VC*VC/RL)/1000.

MAXIMUM CHARGING AND DISCHARGING RATES

AP1=AMAX1(0.,(E1-PE)/TINC)

RE2=AMIN1(MP1,RAP,AP1)

RE2=RE2/EF1

AP2=AMAX1(0.,(PE-EDE)/TINC)

MP2=AMIN1(RAP,B2/(4000.*RT),AP2)

PRIORITY INTERRUPT

C=E1-EDE

ED2=EDE+EDE

IF(PE.GT.EDE)GO TO 401

IF(TO.GT.999999.)TO=TIME

WAIT=TIME-TO

IF (WAIT.GT.DT)INT=1

GO TO 400

401 TO=1000000

IF(PE.LE.ED2)GO TO 400

IF(PE.GT.E1)GO TO 403

IF(PE.GT.C)GO TO 400

INT=0

GO TO 400
403 INT=-1
400 CONTINUE

C
C
C
C
IF(IMPL.LE.1)RETURN


STATISTICS

MPE=AMAX1(MPE,PE)
SPC=SPC+TINC1*P1
SPD=SPD+TINC1*P2

C
C
C
IF(TIME.LT.TMAX1)RETURN
CCI=CCI+CC
CMI=CMI+CM

C
RETURN
END

7.4 BURNER



The burner model computes the amount of fuel required to be burned in the inlet airstream to raise the air temperature from the given inlet temperature to the specified outlet temperature. The fuel mass flow rate when integrated over time allows calculation of the cost of burner fuel.

Basic Equation

The mass of fuel consumed, F , is computed from the equation:

$$\dot{F} = \frac{M1 * CP * (T2 - T1)}{NU * HF}$$

Inputs

<u>Parameter/Port</u>		<u>Description</u>	<u>Units</u>
M	1	Inlet air mass flow rate	lb/h
CP		Air heat capacity ($D = 72 \times 10^{-6}$)	kwh/lb-°F
T	1	Inlet air temperature	°F
T	3	Outlet air temperature (specified)	°F
NU		Combustor efficiency ($D = 0.98$)	-
HF		Fuel heating value ($D = 5.56$)	kwh/lb
CF		Specific fuel cost ($D = 0.094$)	\$/lb
FDM		Maximum allowable fuel mass flow rate ($D=17800$)	lb/h
CB		Burner cost coefficient ($D = 1.683$)	\$/lb/h
LE		Burner life expectancy	years
MDM		Maximum allowable air mass flow rate ($D=27000$)	lb/h
EF	1	Input product efficiency	-
MP	1	Maximum input power	kw
P	1	Input power	kw

Outputs

<u>Variable/Port</u>			
F		Fuel mass consumed (state)	lb
EF	2	Output product efficiency	-
MP	2	Maximum output power	kw
T	2	Outlet air temperature	°F
FD		Fuel mass flow rate	lb/h
CC0		Burner capital cost/year	\$
C0		Fuel cost	\$
M	2	Outlet mass flow rate (= M1)	lb/h
P	2	Output power	kw

Statistics

FDU	Maximum fuel mass flow rate	lb/h
-----	-----------------------------	------

D - Default values supplied

The calculation sequence and default values are based on a burner sized using first principles to maintain the outlet temperature at 600°F assuming an inlet temperature of 120°F and a mass flowrate of 2.7×10^4 lb/h. These conditions represent the extreme conditions expected and should satisfy all burner requirements. No. 6 fuel oil is assumed to be the fuel type. Cost and heating values were obtained from References 1 and 2. Cost estimates for the burner were estimated from the results of Reference 1.

Calculation Sequence

1) Capital Cost

$$CC0 = CB * MDM / LE$$

2) Maximum air mass flow rate allowed

If $M1 = 0$ set $EFF = 1$, $MP2 = MP1$ and go to 3)

$$M1M = \min \left\{ \frac{NU * HF * FDM}{CP * (T3 - T1)}, MDM \right\}$$

If $T1 > T3$, $M1M = MDM$

3) Efficiency and maximum discharge power

$$EFF = 1 + M1 * CP * (T2 - T1) / P1 \quad (\text{if } P1 > 0)$$

$$EF2 = EF1 * EFF$$

$$MP2 = \min \{ MP1 * EFF, P1 * M1M / M1 \} \quad (\text{if } M1 > 0)$$

$$P2 = P1 * EFF$$

1. "Preliminary Feasibility Evaluation of Compressed Air Storage Power Systems," United Technologies AER 74-00242, December 1976.

2. Steam, Its Generation and Use, Babcock and Wilcox, New York, NY, 1972.

Calculation Sequence Cont.

4) Fuel mass flow rate

$$\dot{F} = \frac{M1 * CP * (T2 - T1)}{NU * HF}$$

$$T2 = \text{MAX}(T1, T3)$$

If $M1 > M1M$ write DIAGNOSTIC

5) Compute Statistics and Costs

$$C0 = CF * F$$

CBN

SUBROUTINE BN(F,DF,IF,EF2,MP2,T3,FD,CC,CO,M2,P2,FDU,M1,CP,T1,T2
1 ,NU,HF,CF,FDM,CB,LE,MDM,EF1,MP1,P1)

PURPOSE COMPUTE FUEL REQUIRED TO RAISE THE AIRSTREAM
TEMPERATURE A GIVEN INCREMENT.

METHOD INTEGRATE THE FUEL MASS FLOW RATE OVER TIME

WRITTEN BY F.G. MAHONY

VERSION 1, MARCH 22 1977

CALL SEQUENCE

OUTPUTS

F - FUEL MASS CONSUMED SINCE TIME=0 (STATE), LB
DF - FUEL MASS DERIVATIVE
IF - STATUS INDICATOR
EF2 - OUTPUT PRODUCT EFFICIENCY
MP2 - MAXIMUM OUTPUT POWER, KW
T3 - OUTLET AIR TEMPERATURE, DEG F
FD - FUEL MASS FLOW RATE, LB/HR
CC - BURNER CAPITAL COST/YEAR, \$
CO - FUEL COST, \$
M2 - OUTLET MASS FLOW RATE, LB/HR
P2 - OUTPUT POWER, KW
FDU - OBSERVED MAXIMUM FUEL MASS FLOW RATE, LB/HR

INPUTS

M1 - INLET AIR MASS FLOW RATE, LB/HR
CP - AIR HEAT CAPACITY, KWH/LB-DEG F
T1 - INLET AIR TEMPERATURE, DEG F
T2 - OUTLET AIR TEMPERATURE, DEG F
NU - COMBUSTER EFFICIENCY
HF - FUEL HEATING VALUE, KWH/LB-DEG F
CF - SPECIFIC FUEL COST
FDM - MAXIMUM ALLOWABLE FUEL MASS FLOW RATE, LB/HR
CB - BURNER COST COEFFICIENT
LE - BURNER LIFE EXPECTANCY, YEARS
MDM - MAXIMUM ALLOWABLE AIR MASS FLOW RATE, LB/HR
EF1 - INPUT PRODUCT EFFICIENCY
MP1 - MAXIMUM INPUT POWER, KW
P1 - INPUT POWER, KW

COMMON/CIMPL/IMPL,ICNT /CTIME/TIME /CSIMUL/DUM(7),TMAX
COMMON/COST/CCI,CMI,COP
REAL MP2,M2,M1,NU,LE,MDM,MP1,NIM

IF(IMPL.GT.0) GO TO 100

TMAX1 =TMAX*.99999

IF(CP .EQ. .99999) CP = 72.0E-6

IF(NU .EQ. .99999) NU = 0.98

IF(HF .EQ. .99999) HF = 5.56

IF(CF .EQ. .99999) CF = 0.094

IF(FDM.EQ. .99999) FDM=1.78E+4

IF(CB .EQ. .99999) CB =1.683

IF(MDM.EQ. .99999) MDM=2.7E+4

```

      FDU = 0.0
      CC = CB*MDM/LE
100  EFF=1.0
      IF(M1.EQ.0.0)GO TO 200
      M1M=MDM
      IF(T1.GT.T2) GO TO 200

      C
      C
      C          MAXIMUM ALLOWABLE AIR FLOW RATE
      C
      M1M=AMIN1(NU*HF*FDM/CP/(T2-T1),MDM)
      C
      IF(M1.GT.M1M) GO TO 1000
300  CONTINUE

      C
      C          EFFICIENCY AND MAXIMUM DISCHARGE POWER
      C
      IF(P1.EQ.0.0)GO TO 200
      C
      C
      EFF = 1.0+M1*CP*(T2-T1)/P1
      C
200  EF2 = EF1*EFF
      MP2=MP1
      IF(M1.GT.0.) MP2=AMIN1(MP1*EFF,P1*M1M/M1)
      P2=P1*EFF


      C
      C
      C          FUEL FLOW RATE
      C
      IF(IF.NE.0) DF= M1*CP*(T2-T1)/NU/HF
      IF(T1.GT.T2) DF=0.0
      FD=DF

      C
      C
      C          COSTS
      C
      CO = CF*F
      T3=AMAX1(T1,T2)
      M2=M1

      C
      C
      C          STATISTICS
      C
      IF(IMPL.LE.1) RETURN
      C
      FDU = AMAX1(FD,FDU)
      C
      IF(TIME.LT.TMAX1) RETURN
      CCI= CCI + CC
      COP= COP + CO
      RETURN
      C
1000 IF(IMPL.EQ.2)WRITE(6,1010) M1,M1M
1010 FORMAT(1H0,28HBN INLET AIR MASS FLOW RATE ,F12.3,
1      36H GREATER THAN MAXIMUM ALLOWABLE ,F12.3)
      IF(IMPL.EQ.2)ICNT=ICNT+1
      GO TO 300
      END

```


7.5 COST MONITOR¹



This component sums the capital, operating and maintenance costs of all system components. The total yearly cost TC is then computed using a fixed charge rate factor which represents depreciation, cost of money, insurance and taxes.

The total energy delivered to the loads plus surplus energy is then summed and yearly energy delivered TED computed. Cost of operation in mills is

¹ This component must be placed last in the model generation input file, i.e., just prior to the END OF MODEL command.

then given by

$$\text{System cost/kwh} = \text{TC} * 1000./\text{TED}$$

Similarly, the value of energy delivered to the loads is summed minus the utility energy value and including the value of surplus energy, and factored to give yearly energy value delivered VED. Energy value in mills is given by

$$\text{Load value/kwh} = \text{VED} * 1000./\text{TED}.$$

Cost per value delivered is the ratio of the above two equations.

In addition to the above cost calculations, percent of total load supplied by storage PCW, percent of load supplied by utilities PCU, and percent of energy surplus to the utilities PCS is computed. The total cost in mills to meet the load is then given by

$$\text{Load cost/kwh} = (\text{system cost/kwh} * \text{PCW} + \text{utility cost/kwh} * \text{PCU})/100.,$$

where

$$\text{Utility cost/kwh} = \text{value of utility energy} * 1000./\text{utility energy delivered}.$$

<u>Inputs</u> <u>Parameter/Port</u>	<u>Description</u>	<u>Units</u>
CR	Capital charge rate	%/year
LE	System life expectancy	years

Common Block Inputs

	<u>Description</u>	<u>Units</u>
CC	Total yearly capital costs	\$
CM	Total yearly maintenance costs	\$
CO	Operating and fuel costs over TMAX	\$
TMAX	Simulation time interval	hr
VDE	Value of energy delivered (including surplus)	\$
TDE	Solar energy delivered (including surplus)	kwh
TLD	Total load demand	kwh
UTV	Value of utility energy	\$
UTD	Utility energy supplied	kwh
SPD	Surplus energy supplied	kwh

Outputs¹

Total yearly costs (TC)	\$
Yearly energy delivered (TED)	kwh
Cost of energy per kwh	mills
Yearly value delivered (VED)	\$
Cost per value delivered	-
Percent of load supplied by	
Storage (PCW)	-
Utility (PCU)	-
Surplus energy load factor (PCS)	-
Total load cost per kwh	mills

¹ Printout only occurs when simulation is completed. Thus no output variable symbol is required.

SUBROUTINE CM(DUMM,FCR,LE)

PURPOSE SUMMARIZE WIND ENERGY STORAGE COSTS AND LEVELIZED
ENERGY COSTS PER KWH.

WRITTEN BY A.W. WARREN

VERSION 1, MAY 1977

INPUT PARAMETERS

FCR - FIXED CHARGE RATE FACTOR INCLUDING DEPRECIATION,
MONEY COST, INSURANCE, AND TAXES, PER YEAR
LE - SYSTEM LIFE EXPECTANCY, YEARS
TMAX - SIMULATION TIME, HR
CC - TOTAL YEARLY CAPITAL COSTS, \$
CM - TOTAL YEARLY MAINTENANCE COSTS, \$
CO - TOTAL OPERATING AND FUEL COSTS OVER TMAX, \$
VDE - VALUE OF ENERGY DELIVERED OVER TMAX, \$
TDE - TOTAL ENERGY DELIVERED OVER TMAX, KWH
TLD - TOTAL LOAD DEMAND OVER TMAX, KWH
UTV - VALUE OF UTILITY ENERGY SUPPLIED LESS SURPLUS VALUE, \$
UTD - TOTAL UTILITY ENERGY DELIVERED, KWH
SPD - TOTAL SURPLUS ENERGY SUPPLIED TO UTILITY, \$

COMMON /COST/ CC, CMA,CO,VDE,TDE,TLD,UTV,UTD ,SPD
COMMON /CIMPL/IMPL /CTIME/ TIME /CSIMUL/ DUM(7),TMAX
REAL LE

INITIALIZATION

IF(IMPL.GT.0)GO TO 100
DUMM=0.0
CC = 0.
CMA = 0.
CO = 0.
VDE= 0.
TDE= 0.
TLD= 0.
UTV=0.
UTD=0.
SPD=0.
TMAX1= TMAX*.99999

100 IF(TIME.LT.TMAX1)RETURN
IF(IMPL.LE.1)RETURN

COST SUMMARY OUTPUT

LLE = LE
WRITE(6,200)LLE
200 FORMAT(1H1,35X,39H SOLAR/WIND ENERGY STORAGE COST SUMMARY //
1 1H ,40X,12,17H YEAR LIFE CYCLE)
COY = CO*8760./TMAX
CCY = CC*LE*FCR*.01
TOY = COY + CMA + CCY
WRITE(6,300)CCY,CMA,COY,TOY
300 FORMAT(//// 30X,22H0 YEARLY SYSTEM COSTS/ 1H+,29X,1H+/ 1H-,42X,
1 12HCAPITAL COST,12X,F8.0,2H \$ / 1H ,42X, 17H(INCLUDING FIXED ,

2 8HCHARGES) / 1H0,42X,16HFIXED O + M COST, 8X,F8.0,2H \$ /1H0 ,
 3 42X,21HOPERATING + FUEL COST, 3X,F8.0,2H \$ / 1H0,42X,5HTOTAL,
 4 19X,F8.0,2H \$)


EDE = TDE * 8760./TMAX
 IVDE = VDE * 8760./TMAX
 TOYN = TOY*1000./ EDE
 VDEN = VDE*1000./ TDE
 CPV = TOYN / VDEN

WRITE(6,400)EDE,TOYN,IVDE,VDEN,CPV
 400 FORMAT(//// 30X,26H0 ENERGY DELIVERED / 1H+,29X,1H+ / 1H-,
 1 42X,16HENERGY DELIVERED, 7X,F9.0,4H KWH / 1H0,33X,50(1H*) /
 1 1H ,33X,1H*,48X,1H* /
 2 1H ,33X,1H*, 8X,19HENERGY COST PER KWH, 7X,F6.1,9H MILLS * /
 2 1H ,33X,1H*,48X,1H* / 1H ,
 3 33X,10(5H*****) / 1H0,42X,25HVALUE OF ENERGY DELIVERED,17,
 4 2H \$ / 1H ,42X,22H(VALUE OF FUEL SAVED) / 1H0,42X,20HENERGY VALUE
 5 PER KWH, 6X,F6.1,6H MILLS / 1H0,42X,24HCOST PER VALUE DELIVERED,
 6 2X,F6.2)

PCD= (TDE-SPD)*100./TLD
 PCU= UTD*100./TLD
 PCS= SPD*100./TLD
 CPKWH= (TOYN*(TDE-SPD) + UTV*1000.)/TLD
 WRITE(6,500)PCD ,PCU,PCS,CPKWH
 500 FORMAT(//// 30X,31H0 LOAD FACTOR / 1H+,29X,
 1 1H+ / 1H-,42X,
 1 26HPERCENT OF LOAD SUPPLIED , F6.1, 2H / 1H ,42X, 28HBY TOTAL S
 2OLAR SYSTEM / 1H0,42X,24HPERCENT OF LOAD SUPPLIED,2X,F6.1 /
 2 1H ,41X,11H BY UTILITY /
 3 1H0,42X,26HPERCENT OF SOLAR ENERGY ,F6.1 /
 3 1H ,42X,9HSURPLUSED /
 4 1H0,42X,23HCOST TO MEET LOAD , 3X,F6.1,6H MILLS/
 5 1H ,42X,29H(SOLAR + UTILITY) / 1H1)

RETURN
 END

7.6 COMPRESSOR (PNEUMATIC)



The compressor model represents the off-design performance of a typical axial flow compressor. The compressor is assumed designed for a specified set of design operating conditions and performance requirements. The mass flow rate is assumed directly proportional to angular velocity and independent of the pressure ratio across the compressor. This is expected to hold for $\pm 15\%$ of the design mass flow rate. The polytropic efficiency of the compressor is assumed to be a weak function of the angular velocity. Initial calculations are made with the design polytropic efficiency, and refinements made after the off-design parameters are calculated.

Basic Equations

The expression for the angular velocity is

$$RS = P1 * \frac{RSD}{MD} \frac{EFF}{CP * (TA + 460) * [(PR2/PA)^{**A} - 1]}$$

where:

$$EFF = ((PR2/PA)^{**A * NP} - 1.) / ((PR2/PA)^{**A} - 1.)$$

$$A = (GAM - 1) / GAM * NP$$

Inputs

<u>Parameter/Port</u>		<u>Description</u>	<u>Units</u>
P	1	Input power	kw
RSD		Design angular velocity (D = 3600)	rpm
MD		Design mass flow rate (D = 3000)	lb/h
CP		Heat capacity of air (D = 7.2×10^{-5})	kwh/lb ^o F
TA		Inlet air temperature (ambient) (D = 70)	^o F
PR	2	Exit pressure (D = 147)	psi
PA		Inlet pressure (ambient) (D = 14.7)	psi
GAM		Heat capacity ratio (D = 1.4)	-
EF	1	Input product efficiency	-
MP	1	Maximum input power	kw
NPD		Design polytropic efficiency (D = 0.88)	-
PID		Design inlet pressure (ambient) (D = 14.7)	psi
PØD		Design outlet pressure (D = 147)	psi
TID		Design inlet air temp (ambient) (D = 70)	^o F
CK		Compressor capacity cost coefficient ¹ (D = 1.0)	-
FØ		Compressor exponent for cost calculations (D = 0.75)	-

Outputs

<u>Variable/Port</u>			
NP		Polytropic efficiency	-
EF	2	Output product efficiency	-
MP	2	Maximum output power	kw
TØ		Torque	ft-lb
M		Mass flow rate	lb/h
T	2	Exit temperature	^o F
RS		Angular velocity	rpm
CCØ		Cost of compressor/year	\$

¹ CK = capital cost (known unit)/(design point mass flow rate)^{FØ} *
LN (outlet/inlet pressure ratio)*(life expectancy of unit)
D - Default values supplied

<u>Statistics</u>	<u>Description</u>	<u>Units</u>
MT	Maximum temperature	°F
MF	Maximum mass flow rate	lb/h

The calculation sequence and the default values are based on the assumption of an axial flow compressor, nominally rated at 125kw, and a pressure ratio of 10. The equations used relate first order effects among the various physical quantities and were derived from first principles originally to support the research work of Reference 1. Cost scaling was also developed in that reference based on cost estimates obtained from turbomachinery manufacturers.

Calculation Sequence

1) Costs (First pass only)

$$CC0 = CK * (MD)**F0 * LN \left(\frac{P0D}{PID} \right)$$

If $P1 > 0$ go to 2)

$$A = (GAM-1)/(GAM*NPD)$$

$$RAT = (P0D/PID)**A$$

$$EFF = 1, RS = 0, \text{ go to 3)}$$

-
1. "Closed Cycle High Temperature Central Receiver Concept for Solar Electric Power," BEC/EPRI RP 377-1, June 1976.

Calculation Sequence Cont.

2) Angular velocity iteration

$$A = (GAM-1)/(GAM*NP) \quad (\text{Initially } NP = NPD)$$

$$RAT = (PR2/PA)*A$$

$$EFF = (RAT*NP-1)/(RAT-1)$$

$$\frac{RS}{RSD} = \frac{P1}{MD \cdot CP \cdot (TA+460)} \cdot \frac{EFF}{(RAT-1)}$$

Polytropic efficiency

$$NP = 1 - (1 - NPD) * [2.0 - (\frac{PID * (TA+460) * RSD}{PA * (TID+460) * RS})^{0.2}]$$

Iterate until NP and RS are consistent

(If iteration doesn't converge, then write DIAGNOSTIC and exit)

3) Mass flow rate

$$M = MD * RS / RSD$$

4) Exit temperature

$$T2 = (TA+460)*RAT - 460$$

5) Torque

If $P1 \leq 0$, set $T0 = 0$ and go to 6)

$$T0 = P1 * 737.6 / (RS * 2\pi / 60)$$

6) Efficiency and maximum power

$$EF2 = EF1 * EFF$$

$$MP2 = \min(MP1 * EFF, 1.5 * MD * CP * (T2 - TA))$$

7) Compute Statistics and Costs

CCO

SUBROUTINE CO(NP,EF2,MP2,TO,M,T2,RS,CC,MT,MF,P1,RSD,MD,CP,TA,PR2,
1 PR1,GAM,EF1,MP1,NPD,PID,POD,TID,CK,FO)

PURPOSE PERFORMANCE MODEL OF AXIAL FLOW COMPRESSOR

METHOD COMPRESSOR IS SIZED FROM INPUT OPERATING REQUIREMENTS.
MASS FLOW IS ASSUMED PROPORTIONAL TO ANGULAR VELOCITY
AND INDEPENDENT OF PRESSURE RATIO.

WRITTEN BY F.O. MAHONY

VERSION 1, MARCH 22 1977

CALL SEQUENCE

OUTPUTS

NP - POLYTROPIC EFFICIENCY
EF2 - OUTPUT PRODUCT EFFICIENCY
MP2 - MAXIMUM OUTPUT POWER, KW
TO - TORQUE, FT-LB
M - MASS FLOW RATE, LB/HR
T2 - EXIT TEMPERATURE, DEG F
RS - ANGULAR VELOCITY, RPM
CC - COST OF COMPRESSOR PER YEAR, \$/YEAR
MT - MAXIMUM TEMPERATURE OBSERVED, DEG F
MF - MAXIMUM MASS FLOW RATE, LB/HR

INPUTS

P1 - INPUT POWER, KW
RSD - DESIGN ANGULAR VELOCITY, RPM
MD - DESIGN MASS FLOW RATE, LB/HR
CP - HEAT CAPACITY OF AIR, KWH/LB-DEG F
TA - INLET AIR TEMPERATURE (AMBIENT), DEG F
PR2 - EXIT PRESSURE, PSI
PR1 - INLET PRESSURE (AMBIENT), PSI
GAM - HEAT CAPACITY RATIO
EF1 - INPUT PRODUCT EFFICIENCY
MP1 - INPUT MAXIMUM DISCHARGE POWER, KW
NPD - DESIGN POLYTROPIC EFFICIENCY
PID - DESIGN INLET PRESSURE (AMBIENT), PSI
POD - DESIGN OUTLET PRESSURE (AMBIENT), PSI
TID - DESIGN INLET TEMPERATURE (AMBIENT), DEG F
CK - COMPRESSOR CAPACITY COST COEFFICIENT
FO - COMPRESSOR EXPONENT FOR COST CALCULATION

COMMON /CIMPL/ IMPL /CTIME/ TIME /CSIMUL/DUM(7),TMAX /COST/CCI
REAL MD,MP1,NPD,NP,MP2,M,MT,MF
DATA P1 /3.14159/

INITIALIZATION

IF(IMPL.GT.0) GO TO 100
MT = 0.0
MF = 0.0

IF (RSD.EQ. .99999) RSD = 3600.0
IF (MD .EQ. .99999) MD = 3.0E3
IF(MP1.EQ. .99999) MP1= 1.E8
IF (CP .EQ. .99999) CP = 72.0E-6

```

IF (TA .EQ. .99999)TA = 70.0
IF (PR2.EQ. .99999)PR2 = 147.0
IF (PR1.EQ. .99999)PR1 = 14.7
IF (GAM.EQ. .99999)GAM = 1.4
IF (NPD.EQ. .99999)NPD = 0.88
IF (PID.EQ. .99999)PID = 14.7
IF (POD.EQ. .99999)POD = 147.0
IF (TID.EQ. .99999)TID = 70.0
IF (CK .EQ. .99999)CK = 1.0
IF (FO .EQ. .99999)FO = 0.75
NP = NPD

```

COST

```

CC = CK*MD**FO*ALOG(POD/PID)
TMAX1 = TMAX*.99999

```

```

100 CONTINUE

```

SOLVE FOR POLYTROPIC EFFICIENCY
AND ANGULAR VELOCITY

```

ISP = 0

```

```

EFF=1.0

```

```

IF(P1.GT.0.0)GO TO 200

```

```

RAT= (POD/PID)**((GAM-1.0)/(GAM*NPD))

```

```

TO =0.0

```

```

RS=0.0

```

```

NP=NPD

```

```

GO TO 300

```

```

200 A = (GAM-1.0)/(GAM*NP)

```

```

RAT= (PR2/PR1)**A

```

```

EFF= (RAT**NP - 1.)/(RAT - 1.)

```

```

RSNO = EFF*P1/MD*1.0/CP/(TA+460.0)/(RAT-1.0)

```

```

XNP = NP

```

```

NP = 1.0-((1.0-NPD)*((2.0-(PID/PR1*(TA+460.0)/(TID+460.0)/RSNO)
1      **0.2)

```

```

IF(ISP.GT.10) GO TO 1000

```

```

ISP = ISP+1

```

```

IF(ABS((NP-XNP)/NP).GT.0.001) GO TO 200

```

```

RS= RSD*RSNO

```

MASS FLOW RATE

```

300 M = MD*RS/RSD

```

EXIT TEMPERATURE

```

T2 = (TA+460.0)*RAT-460.0

```

```

IF(P1.LE.0.0)GO TO 400

```

TORQUE

TO = $P1 * 737.6 / (RS * 2.0 * PI / 60.0)$

EFFICIENCY AND MAXIMUM POWER

400 EF2 = EF1*EFF

MP2 = AMIN1(MP1*EFF, 1.5*MD*CP*(T2-TA))

STATISTICS AND COST SUMMATION

IF (IMPL.LE.1) RETURN

MT = AMAX1(MT, T2)

MF = AMAX1(MF, M)

IF (TIME.LT.TMAX1) RETURN

CCI = CCI + CC

RETURN

1000 WRITE (6,1010) NP,XNP,RS


1010 FORMAT (1H0,40HMAX ITERATIONS FOR COMPRESSOR EFFICIENCY,

1 15H - NP,XNP,RS = ,3F12.6)

STOP

END

7.7 PNEUMATIC STORAGE VESSEL (CONSTANT PRESSURE)



The pneumatic storage vessel is based on a constant pressure underground cavern design as represented in Figure 7.7. A surface pressure-compensation pond via a water shaft is assumed to maintain the vessel pressure at a constant value. This model is assumed to be used in conjunction with a heat exchanger. The energy is calculated as a function of the stored gas mass, the inlet/storage air temperature, and a leakage function proportional to the stored energy.

Basic Equation

The rate of energy storage is computed from the equation

$$\dot{E} = M1 * CP * (T1 - T0) - NU * E, \text{ charging}$$

$$\dot{E} = -M2 * CP * (T2 - T0) - NU * E, \text{ discharging}$$

where $M1$ = mass flow rate during charge

$M2$ = mass flow rate during discharge




FIGURE 7.7 CONSTANT PRESSURE AIR STORAGE

<u>Inputs</u>				
<u>Parameter/Port</u>		<u>Description</u>		<u>Units</u>
M	1	Inlet air mass flow rate		lb/h
CP		Air heat capacity ($D = 7.2 \times 10^{-5}$)		kwh/lb ^o F
T	1	Inlet air temperature		^o F
T0		Minimum air temperature ($D = 60$)		^o F
NU		Leakage coefficient ($D = 0.0008$)		h ⁻¹
R		Gas constant ($D = 2.009 \times 10^{-5}$)		kwh/lb
VM		Maximum storage capacity ($D = 1.2 \times 10^6$)		ft ³
PR	1	Vessel pressure ($D = 147$)		psi
LE		Life expectancy of vessel		years
CV		Vessel capacity cost ($D = 0.22$)		\$/ft ³
RE	1	Load request		kw
EF	1	Input product efficiency		-
MP	1	Input maximum power		kw
MDE		Mass threshold for priority resequencing		lb
MD		Maximum charge or discharge mass flow rate		lb
TM		Maximum allowable air temperature ($D = 120$)		^o F
TEM		Maximum allowable inlet temperature		^o F
CM		Maintenance cost/year		\$
<u>Outputs</u>				
<u>Variable/Port</u>				
E		Stored energy (state)		kwh
M	2	Outlet mass flowrate		lb/hr
T	2	Storage temperature		^o F
V		Storage volume		ft ³
CC0		Cost of vessel/year		\$
MS		Mass of air in storage (state)		lb
MP	2	Maximum output power		kw
RE	2	Maximum charging rate		kw
INT		Interrupt priority flag		-
TS0		Minimum air temperature (=T0)		^o F

D - Default values supplied

Outputs Cont.Variable/Port

PR	2	Vessel pressure (=PR1)	psi
P	2	Output power (discharge)	kw
MDM		Maximum allowable mass flow rate (=MD)	

Statistics

EU		Maximum stored energy	kwh
VU		Maximum storage volume	ft ³

The pneumatic storage vessel calculation sequence and default values assume a 10atm cavern approximately 340 ft. below ground and sized for storage of 120kw for 24 hours. A maximum cavern wall temperature of 120°F is assumed. Cost estimates for the vessel were estimated from the results of Reference 1, with cost scaling by .05 to account for plant size differences.

-
1. "Preliminary Feasibility Evaluation of Compressed Air Storage Power Systems," United Technologies AER 74-00242, December 1976.

Calculation Sequence

TINC = integration step size, hr

C1 = conversion constant = 5.43×10^{-5}

$\frac{\text{kwh/ft}^3}{\text{psi}}$

- 1) Vessel Cost

$$CC0 = CV * VM / LE$$

- 2) Storage temperature

$$T2 = \frac{E}{CP * MS} + T0$$

- 3) Storage volume

$$V = MS * \frac{R * (T2 + 460)}{PR1 * C1}$$

- 4) Maximum Mass and charging rate

$$MSM = VM * \frac{(PR1 * C1)}{R * (T2 + 460)}$$

$$MD1 = \text{MIN}(MDM, (MSM - MS) / TINC)$$

$$RE2 = \min \left\{ MP1, MD1 * CP * (TEM - T0) \right\} / EF1$$

- 5) Mass flow out (discharge mode)

$$M2 = \frac{RE1}{CP * (T2 - T0)}$$

$$P2 = RE1$$

- 6) Maximum discharge rate

$$MD = \text{MIN}(MDM, (MS - MDE) / TINC)$$

$$MP2 = CP * (T2 - T0) * MD$$

Calculation Sequence Cont.

7) Stored energy rate

$$\dot{E} = CP*(T1-T0)*M1 - NU*E - RE1$$

8) Stored mass rate

$$\dot{M}S = M1 - M2$$

9) Priority interrupt

If $MS \leq MDE$, $INT = 1$

If $MS > 2*MDE$ and $INT = 1$, $INT = 0$

If $MS \geq MSM$, $INT = -1$

If $MS < MSM - MDE$ and $INT = -1$, $INT = 0$

If $T2 > TM$ write diagnostic and set $INT = -1$

If $MS < MDE$ or $MS > MSM$ write diagnostic

10) Compute Statistics and Costs

SUBROUTINE CS(E,DE,IE,MS,DMS,IMS,M2,T2,V,CC,MP2,RE2,INT,TSO,PR2,
1 ,P,MDM,EU,VU,M1,CP,T,TO,R,VM,PR1,LE,NU,CV,RE1,EF1,MP1,MDE,MD,TM
2 ,TEM,CM)

PURPOSE PERFORMANCE MODEL OF CONSTANT PRESSURE STORAGE VESSEL

METHOD ENERGY IN STORAGE COMPUTED AS A FUNCTION MASS AND
INLET TEMPERATURE.

WRITTEN BY F.O. MAHONY

VERSION 1, MARCH 23 1977

CALL SEQUENCE

OUTPUTS

E - STORED ENERGY (STATE VARIABLE), KWH
DE - STORED ENERGY DERIVATIVE, KW
IE - STATUS INDICATOR FOR E
MS - MASS OF AIR IN STORAGE (STATE VARIABLE), LB
DMS - AIR FLOW RATE, LB/HR
IMS - STATUS INDICATOR FOR MS
M2 - OUTLET MASS FLOWRATE, LB/HR
T2 - STORAGE TEMPERATURE, DEG F
V - STORAGE VOLUME, FT**3
CC - COST OF VESSEL/YEAR, \$
MP2 - MAXIMUM OUTPUT POWER, KW
RE2 - MAXIMUM CHARGING RATE, KW
INT - INTERRUPT PRIORITY FLAG
TSO - MINIMUM AIR TEMPERATURE, DEG F
PR2 - VESSEL PRESSURE, PSI
P - OUTPUT POWER (DISCHARGE), KW
MDM - MAXIMUM ALLOWABLE MASS FLOW RATE, LB/HR
EU - MAXIMUM STORED ENERGY, KWH
VU - MAXIMUM STORAGE VOLUME, FT**3

INPUTS

M1 - INLET AIR MASS FLOW RATE, LB/HR
CP - AIR HEAT CAPACITY, KWH/LB-DEG F
T - INLET AIR TEMPERATURE, DEG F
TO - MINIMUM AIR TEMPERATURE, DEG F
R - GAS CONSTANT, KWH/LB-DEG R
VM - MAXIMUM STORAGE CAPACITY, FT**3
PR1 - VESSEL PRESSURE, PSI
LE - LIFE EXPECTANCY OF VESSEL, YEARS
NU - LEAKAGE COEFFICIENT, 1/HR
CV - VESSEL CAPACITY COST, \$/FT**3
RE1 - LOAD REQUEST, KW
EF1 - INPUT PRODUCT EFFICIENCY
MP1 - INPUT MAXIMUM POWER, KW
MDE - RESERVOIR THRESHOLD MASS FOR PRIORITY
RESEQUENCING, LB
MD - MAXIMUM CHARGE / DISCHARGE MASS FLOW RATE, LB/HR
TM - MAXIMUM ALLOWABLE STORAGE TEMPERATURE, DEG F
TEM - MAXIMUM ALLOWABLE INLET TEMPERATURE, DEG F
CM - MAINTENANCE COST / YEAR, \$

COMMON /CIMPL/IMPL,ICNT/CTIME/ TIME /CSIMUL/DUM(7),TMAX
 COMMON /COST/ CCI,CMI
 REAL NU,MS,MP2,INT,MDM,M1,LE,MP1,MDE,MD,M2,MSM,MD1

IF(IMPL.GT.0) GO TO 100

IF(CP .EQ. .99999) CP = 72.0E-6
 IF(TM .EQ. .99999) TM= 120.0
 IF(TO .EQ. .99999) TO = 60.0
 IF(NU .EQ. .99999) NU = 0.0008
 IF(R .EQ. .99999) R = 2.009E-5
 IF(VM .EQ. .99999) VM = 1.2E+6
 IF(PR1.EQ. .99999) PR1 = 147.0
 IF(CV .EQ. .99999) CV = 0.22
 RE1=0.0

TMAX1 = TMAX*0.99999
 TINC=DUM(7)
 TSO=TO

CC = CV*VM/LE
 C1 = 5.43E-5

INT = 0.
 PR2=PR1
 EU= 0.
 VU= 0.

100 CONTINUE

STORAGE TEMPERATURE

$T2 = E/CP/MS+TO$

STORAGE VOLUME

$V = MS*R*(T2+460.0)/PR1/C1$

MAXIMUM MASS AND CHARGING RATE

MDM=MD
 $MSM = VM*PR1*C1/R/(T2+460.0)$
 $MD1=AMIN1(MDM,AMAX1(0.,(MSM-MS)/TINC))$
 $RE2 = AMIN1(MP1,MD1*CP*(TEM-TO))/EF1$

MASS FLOW OUT (DISCHARGE)

$M2 = RE1/CP/(T2-TO)$
 P = RE1

MAXIMUM DISCHARGE RATE

$AMD=AMAX1(0.,(MS-MDE)/TINC)$
 $MDM=AMIN1(MDM,AMD)$
 $MP2 = CP*(T2-TO)*MDM$

STORED ENERGY RATE

IF(IE.NE.0) DE=CP*(T-TO)*M1 - NU*E -RE1

STORED MASS RATE

IF (IMS.NE.0) DMS=M1-M2

PRIORITY INTERRUPT LOGIC

```

IF(MS .LE. MDE) INT=1.
IF(MS.GT. 2.*MDE .AND. INT.EQ.1.) INT=0.
IF(MS .GE. MSM) INT = -1.
IF(MS.LT. MSM-MDE .AND. INT.EQ.-1.) INT=0.
IF(T2 .GT. TM) INT= -1.

```

```

IF(IMPL.LE.1)RETURN
IF(IMPL.GT.2)GO TO 200
IF(T2.LT.TM)GO TO 10
WRITE(6,1000)T2,TM
ICNT=ICNT+1
10 IF(MS.GT.MDE)GO TO 20
WRITE(6,1010)MS,MDE
ICNT=ICNT+1
20 IF(MS.LT.MSM)GO TO 200
WRITE(6,1020)MS,MSM
ICNT=ICNT+1

```


STATISTICS

```
200 EU = AMAX1(EU,E)
    VU = AMAX1(VU,V)
```

```
IF (TIME.LT.TMAX1) RETURN
CCI = CCI+CC
CMI=CMI+CM
```

RETURN
1000 FORMAT(1H0,23HCS STORAGE TEMPERATURE,F12.3,22HGREATER THAN ALLOWAB
1LE, F12.3)
1010 FORMAT(1H0,25HCS MASS OF AIR IN STORAGE,F12.3,
1 26H BELOW MINIMUM ALLOWABLE,F12.3)
1020 FORMAT(1H0,25HCS MASS OF AIR IN STORAGE,F12.3,
1 28H EXCEEDS MAXIMUM ALLOWABLE,F12.3)
END

7.8 ENVIRONMENTAL DATA (TMY TAPE)



This component reads data values from the Typical Meteorological Year (TMY) tapes or data with a similar format structure such as the University of Wisconsin insolation and environmental data tape or the SOLMET tapes. Only one ED component is allowed per model. (Unit 1 is reserved for the input tape.) The file structure assumes hourly recorded data with one record or card image per hour of data. Twenty-four hourly records are read into core at a time and linear interpolation is used to obtain the output values at the current simulation time. The component TI is used to supply the time inputs DY and TD. Standard outputs with the TMY tape are direct and global solar insolation, dry bulb temperature, and wind speed. For non-standard outputs or non-TMY format tapes the user may specify the input format to read one to eight data variables. The following limitations apply in this case:

- 1) Time information is decoded in integer month (1-12), day (1-31), and hour (0-24) format.
- 2) Output variables are decoded in F or E format, even if recorded in integer format.
- 3) Where data is missing, fill in with 9's is assumed. The code checks for certain 9 fill values, namely 99., 999., 9999., and 99999. If any one of these values is read, then the corresponding data input is replaced with 0. or the previous value, depending on the sign of IND. (However, one must use FN.0 format N=2,3,4,5 for this option and a scale multiplier if necessary to obtain the desired exponent.)

<u>Inputs/Port</u> ¹	<u>Description</u>	<u>Units</u>
NX	Number of output variables (default = 4, max = 8)	-
IND	Indicator function: 0 = no read ±1 = standard format and units (default) ±2 = user-specified format and units IND>0 sets missing data = 0 IND<0 sets missing data = previous value	

¹ Also see page 65 in Section 4.2 for inputs to procedure TMYRD. This procedure creates the data input file TAPE1 from the multi-station TMY tape.

<u>Inputs/Port (cont'd)</u>	<u>Description</u>	<u>Units</u>
TS*	Time shift of data (default = -0.5)	hours
TD	Time of day (0-24)	hours
DY	Day of year (1-365)	-
M1	Units multiplier for X1 (default = 1)	-
.	.	
.	.	
.	.	
M8	Units multiplier for X8 (default = 1)	-
A1	Units addition factor for X1 (default = 0)	-
.	.	
.	.	
.	.	
A8	Units addition factor for X8 (default = 0)	-

* Compensation term since solar radiation data is an integrated total over the observation interval.

<u>Outputs/Port</u>	<u>Description</u>	<u>Units</u>
X1	1st output variable (IND = ± 1 : beam radiation in w/m^2)	-
X2	2nd output variable (IND = ± 1 : global horizontal radiation in w/m^2)	-
X3	3rd output variable (IND = ± 1 : dry bulb temperature in $^{\circ}\text{C}$)	-
X4	4th output variable (IND = ± 1 : wind speed in m/s)	-
.		
.		
.		
X8	8th output variable	-

Format Specification

A user-specified format may be input in order to select non-standard environmental outputs or to read a tape other than the TMY insolation tape. The following sequence of data cards is recommended for insertion in the model generation input following the MODEL DESCRIPTION command:

```

FORTRAN STATEMENTS
DIMENSION FMT(7)
COMMON/READER/N,FMT
DATA FMT/XXH(...)/,N/NN/

```

where the format specification contains XX-2 characters inserted after 'XXH(' and followed by ')', and NN = the number of characters per data record.

The format specification must conform to the following rules:

- 1) The first two words read are station and year identifying information. These words must be either A format or nH format with up to six characters for station and two characters NN for year 19NN.
- 2) The next three words are two-digit integers containing month (1-12), day (1-31), and hour (0-24) information.
- 3) The next one to eight words specify the location of the output variables X1...X8 and must be given in F or E format.

NOTE: The tab or column spacing control T may be used to read data from files which are not ordered as in 1) to 3), e.g., (T71, A5, T1, A2,...).

For example, the standard TMY tape format specification (neglecting blanks) is

Station	Yr-Mo-Dy-Hr	Beam Rad.	Global Rad.	Temp	Wind
(A5,	A2,312,11X,	F4.0 ,26X,	F4.0,45X,	F4.1,7X,	F4.1)

and N = 132, XX = 46.

The general format for variables on the TMY tape is summarized in Figure 7.8.

ED

FIELD NUMBER	SOLAR RADIATION OBSERVATION														S U N S H I N E M I N		
	WBAN STN #	SOLAR TIME				LST TIME	ETR KJ/m ²	RADIATION VALUES KJ/m ²									
		YR	MO	DY	HR:MN			D I R E C T	D I F F U S E	N E T	T I L T E D	GLOBAL				A	B
												OBS	ENG COR	STD YR COR			
002	XX	XX	XX	XXXX	XXXX	XXXX	XXXXXX	XXXXXX	XXXXXX	XXXXXX	XXXXXX	XXXXXX	XXXXXX	XXXXXX	XXXXXX	XX	

SURFACE METEOROLOGICAL OBSERVATION															
O B S E R V I N G L S T	C E I L I N G dam	SKY COND	VSBY hm	WEATHER	PRESSURE kPa		TEMP °C		WIND		T O T A L	S N O W C O V E R	P A Q U E		
					SEA LEVEL	STA- TION	DRY BULB	DEW- PT.	D I R	S P D					
														deg	m/s
XX	XXXX	XXXXX	XXXX	XXXXXXXXXX	XXXXXX	XXXXXX	XXXX	XXXX	XXXX	XXXX	XX	XX	X		
201	202	203	204	205	206	207	208	209	210						

TAPE FIELD NUMBER	RECORD POSITIONS	DESCRIPTION
002	01-05	WBAN STATION NUMBER
003	06-15	SOLAR TIME (YR,MO',DAY,HOUR,MINUTE)
004	16-19	LOCAL STANDARD TIME (HR AND MINUTE)
101	20-23	EXTRATERRESTRIAL RADIATION
102	24-28	DIRECT RADIATION
103	29-33	DIFFUSE RADIATION
104	34-38	NET RADIATION
105	39-43	GLOBAL RADIATION ON A TILTED SURFACE
106	44-48	GLOBAL RADIATION ON A HORIZONTAL SURFACE- OBSERVED DATA
107	49-53	GLOBAL RADIATION ON A HORIZONTAL SURFACE- ENGINEERING CORRECTED DATA
108	54-58	GLOBAL RADIATION ON A HORIZONTAL SURFACE- STANDARD YEAR CORRECTED DATA
109,110	59-68	ADDITIONAL RADIATION MEASUREMENTS
111	69-70	MINUTES OF SUNSHINE
201	71-72	TIME OF COLLATERAL SURFACE OBSERVATION (LST)
202	73-76	CEILING HEIGHT (DEKAMETERS)
203	77-81	SKY CONDITION
204	82-85	VISIBILITY (HECTOMETERS)
205	86-93	WEATHER
206	94-103	PRESSURE (KILOPASCALS)
207	104-111	TEMPERATURE (DEGREES CELSIUS TO TENTHS)
208	112-118	WIND (SPEED IN METERS PER SECOND TO TENTHS)
209	119-122	CLOUDS
210	123	SNOW COVER INDICATOR

FIGURE 7.8 TMY TAPE FORMAT

ORIGINAL PAGE IS
OF POOR QUALITY

A complete description of the available data, and the meaning of the recorded outputs, is contained in the SOLMET user's manual [3]. The TMY tape was derived from SOLMET tapes of the 26 stations with rehabilitated solar radiation data, and has the same format as the SOLMET tapes except that tape deck number and detailed cloud data have been omitted. Table 7.8 shows the identity and location of the 26 stations on the TMY tape.

Calculation Sequence

If IND = 0 Return

1) INITIALIZATION (first pass only)

- Set defaults and initialize LTD = -1
- Read first data block and write out identification information. (Error exit to 6))
- Go to 4)

2) Table Interpolation for Output (DY = DYF)

- If $DY > DYF$ go to 3)
- If $DYF > DY$ go to 5)
- If LTD = TD return (LTD = last time C(I,J) was accessed)
- $X(I) = TBLU1(TD, TO, C(1,I), 0, 24) * M(I) + A(I)$ I = 1,...NX
- LTD = TD
- Return

- 3) Read One or More Data Blocks ($DY > DYF$)
 - Read $DY-DYF$ data blocks. (Error exit or EOF exit to 6))
- 4) Decode Using Specified Format
 - Decode day-of-year (DYF) and time information ($T0$) and put output variables in array $C(I,J)$ $I=1,24$ and $J=1,NX$. Check for missing data values in $C(I,J)$.
 - Go to 2)
- 5) Backspace the File ($DYF > DY$)
 - Backspace and read first data block
 - Decode day-of-year (DYF)
 - Go to 4) if $DYF \leq DY$. Otherwise print diagnostic and stop.
- 6) Read Error or EOF Encountered
 - Print diagnostic and stop.

TABLE 7.8 TMY TAPE STATIONS AND LOCATION

<u>STATION NUMBER</u>	<u>WBAN IDENTIFIER</u>	<u>STATION</u>	<u>LATITUDE</u>	<u>LONGITUDE</u>
1	3927	Fort Worth, Texas	32°50'	97°03'
2	3937	Lake Charles, Louisiana	30°07'	93°13'
3	3945	Columbia, Missouri	38°49'	92°13'
4	12832	Apalachicola, Florida	29°44'	84°59'
5	12839	Miami, Florida	25°48'	80°16'
6	12919	Brownsville, Texas	25°54'	97°26'
7	13880	Charleston, South Carolina	32°54'	80°02'
8	13897	Nashville, Tennessee	36°07'	86°41'
9	13985	Dodge City, Kansas	37°46'	99°58'
10	14607	Caribou, Maine	46°52'	68°01'
11	14837	Madison, Wisconsin	43°08'	89°20'
12	23044	El Paso, Texas	31°48'	106°24'
13	23050	Albuquerque, New Mexico	35°03'	106°37'
14	23154	Ely, Nevada	39°17'	114°51'
15	23183	Phoenix, Arizona	33°26'	112°01'
16	23273	Santa Maria	34°54'	120°27'
17	24011	Bismarck, North Dakota	46°46'	100°45'
18	24143	Great Falls, Montana	47°29'	111°22'
19	24225	Medford, Oregon	42°22'	122°52'
20	24233	Seattle-Tacoma, Washington	47°27'	122°18'
21	93193	Fresno, California	36°46'	119°43'
22	93729	Cape Hatteras, North Carolina	35°16'	75°33'
23	93734	Washington, D.C.	38°59'	77°28'
24	94701	Boston, Massachusetts	42°22'	71°03'
25	94728	New York, New York	40°47'	73°58'
26	94918	North Omaha, Nebraska	41°22'	96°01'

CED

SUBROUTINE ED(X,X2,X3,X4,X5,X6,X7,X8,NX,IND,TS,TD,DY,
1M1,M2,M3,M4,M5,M6,M7,M8,A1,A2,A3,A4,A5,A6,A7,A8)

PURPOSE THIS COMPONENT READS THE TYPICAL METEOROLOGICAL
YEAR TAPE WITH A STRUCTURE SIMILAR TO THE
SOLMET DATA TAPE. USER MAY SPECIFY FORMAT FOR NON-
STANDARD TAPES

WRITTEN BY Y.K.CHAN, 10-5-78, VERSION 1

METHOD TWENTY FOUR HOURLY RECORDS ARE READ INTO CORE
AT A TIME AND LINEAR INTERPOLATION IS USED TO
OBTAIN THE OUTPUT AT CURRENT SIMULATION TIME.

CALL SEQUENCE

OUTPUTS

X1,...,X8 -OUTPUT VARIABLES AT CURRENT TIME
X1 -BEAM RADIATION IF IND=+-1, W/M2
X2 -GLOBAL RADIATION IF IND=+-1, W/M2
X3 -DRY BULB TEMPERATURE IF IND=+-1, C
X4 -WIND SPEED IF IND=+-1,M/S

INPUTS

NX -NUMBER OF OUTPUT VARIABLES(DEFAULT=4,MAX=8)
IND -INDICATOR FUNCTION
0=NO READ
+-1=STANDARD FORMAT AND UNITS(DEFAULT)
+-2=USER SPECIFIED FORMAT AND UNITS
>0,SETS MISSING DATA TO 0
<0,SETS MISSING DATA TO PREVIOUS VALUE
TS -TIME SHIFT OF DATA(DEFAULT=-0.5)
(COMPENSATION TERM SINCE SOLAR RADIATION
DATA IS AN INTEGRATED TOTAL, USUALLY OVER 1 HOUR)
TD -CURRENT TIME OF DAY(0-24)
DY -CURRENT DAY OF YEAR(1-365)
M1,...,M8 -UNITS MULTIPLIERS FOR X1,...,X8
DEFAULT M1=...=M8=1
A1,...,A8 -ADDITION FACTOR FOR X1,...,X8
DEFAULT A1=...=A8=0

DIMENSION X(8),A(8),FRMT(7),FMT(7),C(24,8),AA(336),IB(5),B(8),
1 CL(8),TO(24),DM(12)
COMMON /READER/N,FMT
COMMON /CIMPL/IMPL,ICNT,ITEST
REAL NX,IND,M1,M2,M3,M4,M5,M6,M7,M8,M(8),LTD
DATA FRMT/70H(A5,A2,3I2,11X,F4.0,26X,F4.0,45X,F4.1,7X,F4.1)
1
DATA DM/0.,31.,59.,90.,120.,151.,181.,212.,243.,
1 273.,304.,334./

IF(ABS(IND).LE..1)RETURN

INITIALIZATION

IF(IMPL.GT.0)GO TO 100
IF(NX.EQ..99999)NX=4
IF(TS.EQ..99999)TS=-.5
INX=NX+.1

ORIGINAL PAGE IS
OF POOR QUALITY

```

M(1)=M1
M(2)=M2
M(3)=M3
M(4)=M4
M(5)=M5
M(6)=M6
M(7)=M7
M(8)=M8
A(1)=A1
A(2)=A2
A(3)=A3
A(4)=A4
A(5)=A5
A(6)=A6
A(7)=A7
A(8)=A8

```

```
DO 11 I=1,INX
```

```
IF(M(I).EQ..99999)M(I)=1.
```

```
11 IF(A(I).EQ..99999)A(I)=0.
```

C
C

```
SET DEFAULT TAPE RECORD FORMAT TO STANDARD
```

```
IF(ABS(1ND).GT.1.01)GO TO 2
```

```
M(1)=1./3.6
```

```
M(2)=1./3.6
```

```
DO 3 I=1,7
```

```
3 FMT(I)=FRMT(I)
```

```
N=132
```

```
2 CONTINUE
```

```
LTD=-1.
```

```
DO 10 J=1,INX
```

```
10 CL(J)=0.
```

C
C
C

```
READ FIRST DATA BLOCK
```

```
IREWIN=0
```

```
J13=N/10
```

```
IF(N.GT.10*J13)J13=J13+1
```

```
DO 20 J=1,24
```

```
J1=J13*(J-1)+1
```

```
J2=J1+J13-1
```

```
BUFFER IN (1,0)(AA(J1),AA(J2))
```

```
IF(UNIT(1))20,600,600
```

```
20 CONTINUE
```

```
DECODE(N,FMT,AA(1))IB,B
```

```
WRITE(6,308)IB(1),IB(2)
```

```
308 FORMAT(1H0,3X,*ED STATION ID=*,A5,10X,*YEAR 19*,A2)
```

```
GO TO 400
```

C
C

```
100 CONTINUE
```

C

```
200 CONTINUE
```

C

C

C

C

```
INTERPOLATION FOR OUTPUT IF CURRENT DAY OF YEAR HAS  
BEEN LOCATED
```

```
TD1=TD
```

```
IF(DY.GT.(DYF+.1))GO TO 300
```



```

      IF(DY.LT.(DYF-.1))GO TO 500
24  IF(LTD.EQ.TD)RETURN
      DO 201 I=1,INX
201  X(I)=TBLU1(TD1,TD,C(1,I),0,24)*M(I)+A(I)
      LTD=TD
      RETURN

```

```

C
300 CONTINUE

```

```

C
C      IF CURRENT DAY OF YEAR HAS NOT BEEN LOCATED, READ MORE TAPE
C

```

```

      ID=DY-DYF+.1
      IF(ID.EQ.1 .AND. TD.LT. .00001) TD1=24.
      IF(TD1.EQ. 24.) GO TO 24
      DO 30 I=1,ID
      DO 301 J=1,24
      J1=J13*(J-1)+1
      J2=J1+J13-1
      BUFFER IN(1,0)(AA(J1),AA(J2))
      IF(UNIT(1))301,600,600

```

```

301 CONTINUE

```

```

30 CONTINUE

```

```

C
C      DECODE DATA AND TIME OF DAY
C

```

```

400 CONTINUE

```

```

      DO 402 I=1,24
      I1=J13*(I-1)+1
      DECODE (N,FMT,AA(I1))IB,B
      DO 401 J=1,INX
      C(I,J)=B(J)
      CIJ=C(I,J)
      IF((CIJ.EQ.99.) .OR. (CIJ.EQ.999.) .OR. (CIJ.EQ.9999.) .OR.
1(CIJ.EQ.99999.))C(I,J)=CL(J)
      IF(IND.LT.0.)CL(J)=C(I,J)

```

```

401 CONTINUE

```

```

      TO(I)=IB(5)+TS

```

```

402 CONTINUE

```

```

      DYF=IB(4)+DM(IB(3))
      GO TO 200

```

```

C
500 CONTINUE

```

```

C
C      IF DAY OF YEAR ON TAPE IS PAST CURRENT DAY OF YEAR,
C      REWIND TAPE.

```

```

      IF(IREWIN.GT.0)GO TO 507
      REWIND 1
      IREWIN=IREWIN+1
      DO 501 J=1,24
      J1=J13*(J-1)+1
      J2=J1+J13-1
      BUFFER IN(1,0)(AA(J1),AA(J2))
      IF(UNIT(1))501,600,600

```

```

501 CONTINUE

```

```

      DECODE(N,FMT,AA(1))IB,B

```

```

      DYF=IB(4)+DM(IB(3))

```

```

      IF(DYF.LT.(DY+.1))GO TO 400

```

```

507 WRITE(6,508)

```

ED

508 FORMAT(1H0,* INPUT ERROR, DAY OF YEAR DY IS OUT OF RANGE*)
STOP

C
C


IF ERROR IN READ, PRINT DIAGNOSTICS

600 WRITE(6,608)

608 FORMAT(1H0,*ED TAPE INPUT ERROR OR EOF*)
STOP

END

7.9 FLYWHEEL/CLUTCH



The flywheel model is a first order differential equation for kinetic energy which is driven by input power when charging and by a load request when discharging. Power losses include clutch losses versus shaft speed and torque, windage losses, and friction losses due to bearing and seals. Shaft speed is determined analytically from kinetic energy. Priority interrupt logic is activated if minimum or maximum capacity levels are reached.

Basic Equations

$$KE = k * \omega^2$$

$$\dot{KE} = P_{IN} - P_{OUT} - C_1 * \omega - C_2 * \omega^{2.8},$$

where k, C_1, C_2 are flywheel constants

ω = rotor speed in rad/sec

P_{IN} = input power - clutch losses

P_{OUT} = output load request

<u>Tables</u>		<u>Description</u>	<u>Units</u>
CL0		Clutch losses versus rotor speed (rpm) and torque (ft-lb), when engaged (Table dimension = 90)	kw
CL1		Clutch losses versus rotor speed (rpm) when disengaged (Table dimension = 17)	kw
<u>Inputs</u>			
<u>Parameter/Port</u>			
PR		Pressure in vacuum housing	psi
HM		Moment of inertia ¹	slug-ft ²
RF		Radius of flywheel	ft
SR		Shaft radius	ft
WT		Flywheel weight	lb
KF		Coefficient of friction	-
ZE		Width of flywheel at tip	ft
C2		Windage loss coefficient (analytic default)	-
P	1	Input power	kw
EF	1	Input product efficiency	-
MP	1	Input maximum charging rate	kw
RAP		Rated power, charge or discharge	kw
RE	1	Discharge load request	kw
E0		Minimum allowable storage capacity	kwh
E1		Maximum allowable storage capacity	kwh
EDE		Energy deadband for priority resequencing	kwh
CM		Maintenance cost/year	\$
CC		Capital cost/year	\$
<u>Outputs</u>			
<u>Variable/Port</u>			
RS		Rotor speed	rpm
KE		Kinetic energy (state)	kwh

¹ Includes physical drive system.

Outputs Cont.

<u>Variable/Port</u>		<u>Description</u>	<u>Units</u>
T0		Input torque (charging)	ft-lb
T1		Output torque (discharging)	ft-lb
P	2	Output power	kw
PL0		Clutch losses (charging)	kw
PL1		Clutch losses (discharging)	kw
EF	2	Output efficiency	-
MP	2	Maximum output power	kw
INT		Priority interrupt flag	-
RE	2	Maximum charging power request	kw

Statistics

ME		Maximum stored energy	kwh
MPC		Maximum charge rate	kw
MPD		Maximum discharge rate	kw
SPC		Sum of charging energy	kwh
SPD		Sum of discharging energy	kwh

Calculation Sequence

1) Compute flywheel constants

$$k = \frac{1}{2} * HM * 3.7661 * 10^{-7}$$

$$C_1 = KF * WT * SR * 1.3558 * 10^{-3}$$

$$C_2 = C_o * PR^{0.8} * RF^{4.6} * (1 + 2.3 * ZE / RF) \quad (\text{DEFAULT})$$

$$C_o = 1.0946 * 10^{-7}$$

If $KE < E0$ or $KE > E1$ write diagnostic

2) Compute rotor speed

$$\omega = \sqrt{KE/k}$$

$$RS = \omega * (60 / 2\pi)$$

$$P_{IN} = 0$$

3) Compute power losses and net power when charging

If $P1 = 0$, set $T0 = PL0 = P_{IN} = 0$ and go to 4)

$$T0 = P1 * 737.6 / \omega$$

$$PL0 = CL0(RS, T0)$$

$$P_{IN} = P1 - PL0$$

If $P_{IN} < 0$, write diagnostic

4) Compute power losses and output power when discharging

If $RE1 = 0$, set $T1 = PL1 = P2 = P_{OUT} = 0$ and go to 5)

$$T1 = RE1 * 737.6 / \omega$$

$$PL1 = CL0(RS, -T1)$$

Calculation Sequence

4) Cont.

$$P_2 = RE_1 - PL_1$$

$$P_{OUT} = RE_1$$

If $P_2 < 0$, set $P_2 = 0$. and write diagnostic

5) Compute power losses when disengaged

If $P_1 > 0$ or $RE_1 > 0$, go to 6)

$$P_{OUT} = CL_1(RS)$$

6) Flywheel kinetic energy rate

$$\dot{KE} = P_{IN} - P_{OUT} - C_1 * \omega - C_2 * \omega^{2.8}$$

7) Maximum Input (charging power)

$$TM = MP_1 * 737.6 / \omega$$

$$MP_0 = MP_1 - CL_0(RS, TM)$$

If $MP_0 \leq 0$, write diagnostic and go to 8)

$$EF_0 = EF_1 * MP_0 / MP_1$$

$$RE_2 = \min(MP_0, RAP), (EI - KE) / TINC / EF_0$$

8) Output efficiency and maximum power

$$RAP_1 = \min(RAP, (KE - EI) / TINC), \quad TINC = \text{integration step}$$

$$TM = RAP_1 * 737.6 / \omega$$

$$MP_2 = RAP_1 - CL_0(RS, -TM)$$

Calculation Sequence

8) Cont.

If $MP2 < 0$ write diagnostic

$$EF2 = MP2/RAP1$$

If $RE1 > 0$, $EF2 = P2/RE1$

9) Priority interrupt logic

If $KE \leq E0$, $INT = 1$

If $KE > E0 + EDE$ and $INT=1$, $INT=0$

If $KE \geq E1$, $INT = -1$

If $KE < E1 - EDE$ and $INT= -1$, $INT=0$

10) Compute Statistics and Costs

CFL

SUBROUTINE FL(CLO,CL1,RS,KE,KED,IKE,TO,T1,P2,PLO,PL1,EF2,MP2,INT,
 1 RE2,ME,MPC,MPD,SPC,SPD, PR,HM,RF,SR,WT,KF,ZE,C2,P1,EF1,MP1,RAP
 2 ,RE1,EO,E1,EDE,CM,CC)

PURPOSE MODEL OF FLYWHEEL CAPABLE OF ABSORBING POWER
 AND OF DELIVERING POWER ON REQUEST

METHOD OUTPUT POWER AND KINETIC ENERGY COMPUTED FROM
 POWER REQUEST AND INPUT POWER

WRITTEN BY Y.K.CHAN

VERSION 1, JUNE 17, 1977

CALL SEQUENCE TABLES

CLO -CLUTCH LOSSES VS ROTOR SPEED(RPM) AND TORQUE(FT-LB),KW
 CL1 -CLUTCH LOSSES VS ROTOR SPEED(RPM) WHEN DISENGAGED,KW

OUTPUTS

RS -ROTOR SPEED, RPM
 KE -KINETIC ENERGY(STATE),KWH
 KED -KINETIC ENERGY INCREASE RATE,KW
 IKE -INTEGRATOR CONTROL
 TO -INPUT TORQUE (CHARGING), FT-LB
 T1 -OUTPUT TORQUE (DISCHARGING),FT-LB
 P2 -OUTPUT POWER,KW
 PLO -CLUTCH LOSSES (CHARGING),KW
 PL1 -CLUTCH LOSSES (DISCHARGING),KW
 EF2 -OUTPUT EFFICIENCY
 MP2 -MAXIMUM OUTPUT POWER,KW
 INT -PRIORITY INTERRUPT FLAG
 RE2 -MAXIMUM CHARGING POWER REQUEST

STATISTICS

ME MAXIMUM STORED ENERGY,KWH
 MPC -MAXIMUM CHARGE RATE,KW
 MPD -MAXIMUM DISCHARGE RATE,KW
 SPC -SUM OF CHARGING POWER,KWH
 SPD -SUM OF DISCHARGING POWER,KWH

INPUTS

PR -PRESSURE IN VACUUM HOUSING,PSI
 HM -MOMENT OF INERTIA,SLUG-FT²
 RF -RADIUS OF FLYWHEEL,FT
 SR -SHAFT RADIUS,FT
 WT -FLYWHEEL WEIGHT,LB
 KF -COEFFICIENT OF FRICTION
 ZE -WIDTH OF FLYWHEEL AT TIP,FT
 C2 -WINDAGE COEFFICIENT (ANALYTIC DEFAULT)
 P1 -INPUT POWER,KW
 EF1 -INPUT PRODUCT EFFICIENCY
 MP1 -INPUT MAXIMUM CHARGING RATE,KW
 RAP -RATED POWER, CHARGE OR DISCHARGE,KW
 RE1 -DISCHARGE LOAD REQUEST,KW
 EO -MINIMUM ALLOWABLE STORAGE CAPACITY,KWH
 E1 -MAXIMUM ALLOWABLE STORAGE CAPACITY,KWH
 EDE -ENERGY DEADBAND FOR PRIORITY RESQUENCING,KWH
 CM -MAINTENANCE COST/YEAR,\$

ORIGINAL PAGE IS
 OF POOR QUALITY

```

C      CC  -CAPITAL COST/YEAR,$
C
COMMON /CIMPL/IMPL,ICNT/CTIME/TIME/CSIMUL/DUM(7),TMAX
X      /COST/CC1,CMI
REAL KE,KED,MP2,INT,ME,MPC,MPD,KF,MP1,MPD,MPA,MPB
C      DIMENSION CLO(1),CL1(1)

      IF(IMPL.GT.0)GO TO 10
      TINC=DUM(7)*.5
      IF(C2.EQ..99999)C2=(1.0946E-7)*(PR**.8)*(RF**4.6+2.3*ZE*(RF**3.6))
      INT=0.
      TMAX1=TMAX*.99999
C
      ME=0.
      RE1=0.
      MPC=0.
      MPD=0.
      SPC=0.
      SPD=0.
10  CONTINUE
      AK=.5*HM*3.76616E-7
      C1=KF*WT*SR*1.3558E-3
      IF(((KE.GT.E0).AND.(KE.LT.E1)).OR.(IMPL.NE.2))GO TO 20
      IF(KE.LE.E0)WRITE(6,108)KE,E0
      IF(KE.GE.E1)WRITE(6,109)KE,E1
109  FORMAT(1H0,26H FLYWHEEL KINETIC ENERGY ,F12.3,
X 18H EXCEEDS CAPACITY ,F12.3)
108  FORMAT(1H0,24H FLYWHEEL KINETIC ENERGY,F12.3,
X 33H FALLS BELOW MINIMUM REQUIREMENT ,F12.3)
      ICNT=ICNT+1
20  CONTINUE
      NNRS=CLO(2)
      NNT=CLO(3)
      M4=NNT+4
      MN4=M4+NNRS
      NNNRS=CL1(2)
      NNNRS4=NNNRS+4
      TO=0.
      T1=0.
      P2=0.
      PLO=0.
      PL1=0.
      RE2=0.
C
C      COMPUTE ROTOR SPEED
C
100  OMEGA=1.E-6
      IF(KE.GT.0.)OMEGA=SQRT(KE/AK)
      RS=OMEGA*30./3.14159
      PIN=0.
C
C      COMPUTE POWER LOSSES AND NET POWER WHEN CHARGING
C
      IF(P1.EQ.0.)GO TO 200
      TO=P1*737.6/OMEGA
      PLO=TBLU2(RS,TO,CLO(M4),CLO(4),CLO(MN4),1,1,-NNRS,-NNT,NNRS,NNT)
      PIN=P1-PLO
      POUT=0.

```

```

C
  IF(PIN.GE.0.)GO TO 200
  IF(IMPL.NE.2)GO TO 200
  WRITE(6,208)PLO,P1
208  FORMAT(1H0,21H FLYWHEEL POWER LOSS ,F12.3,
X24H EXCEEDS CHARGING POWER ,F12.3)
  ICNT=ICNT+1
C
C
C      COMPUTE POWER LOSSES AND OUTPUT POWER WHEN DISCHARGING
200  IF(RE1.EQ.0.)GO TO 300
      T1=RE1*737.6/OMEGA
      PL1=TBLU2(RS,-T1,CLO(M4),CLO(4),CLO(MN4),1,1,-NNRS,-NNT,NNRS,NNT)
      P2=RE1-PL1
      POUT=RE1
      IF(P2.GT.0..OR.IMPL.NE.2)GO TO 300
      WRITE(6,308)PL1,RE1
308  FORMAT(1H0,16H FLYWHEEL LOSS ,F12.3,
X27H EXCEEDS DISCHARGING POWER ,F12.3)
      ICNT=ICNT+1
      P2=0.
C
C
C      COMPUTE POWER LOSSES WHEN DISENGAGED
300  IF(P1.GT.0.)GO TO 400
      IF(RE1.GT.0.)GO TO 400
      POUT=TBLU1(RS,CL1(4),CL1(NNNRS4),1,-NNRS)
C
C
C      FLYWHEEL KINETIC ENERGY BALANCE
400  IF(IKE.NE.0)KED=PIN-POUT-C1*OMEGA-C2*(OMEGA**2.8)
C
C
C      MAXIMUM CHARGING POWER REQUEST
      TM=MP1*737.6/OMEGA
      MPA=TBLU2(RS,TM,CLO(M4),CLO(4),CLO(MN4),1,1,-NNRS,-NNT,
X      NNRS,NNT)
      MPO=MP1-MPA
      IF(MPO.GT.0.)GO TO 500
      IF(IMPL.EQ.2)WRITE(6,508)MPA,MP1
C 508  FORMAT(1H0,22H FLYWHEEL CLUTCH LOSS ,F12.3,
C      X 31H EXCEEDS MAXIMUM INPUT POWER ,F12.3)
C      IF(IMPL.EQ.2)ICNT=ICNT+1
      GO TO 600
500  EFO=EF1*MPO/MP1
      APC=AMAX1(0.,.5*(E1-KE)/TINC)
      RE2=AMIN1(MPO,RAP,APC)
      RE2=RE2/EFO
C
C
C      OUTPUT EFFICIENCY AND MAXIMUM POWER
600  RAPT=(KE-E0)/(TINC*2.)
      RAPT=AMIN1(RAPT,RAP)
      RAPT=AMAX1(RAPT,RAP/1000.)
      TM=RAPT*737.6/OMEGA
      MPB=TBLU2(RS,-TM,CLO(M4),CLO(4),CLO(MN4),1,1,-NNRS,-NNT,

```

```

X  NNRS,NNT)
MP2=RAPT-MPB
IF(MP2.GT.0..OR.IMPL.NE.2)GO TO 700
708 FORMAT(1H0,22H FLYWHEEL CLUTCH LOSS ,F12.3,
X27H EXCEEDS DELIVERABLE POWER ,F12.3)
WRITE(6,708)MPB,RAPT
ICNT=ICNT+1
700 MP2=AMAX1(MP2,RAP/1000.)
EF2=MP2/RAPT
IF(RE1.GT.0..AND.P2.GT.0.)EF2=P2/RE1

```

PRIORITY INTERRUPT

```

EC1=E1-EDE
ECO=E0+EDE
IF((KE.GT.ECO).AND.(INT.EQ.1))INT=0
IF((KE.LT.EC1).AND.(INT.EQ.-1))INT=0

IF(KE.LE.E0)INT=1.
IF(KE.GT.E1)INT=-1.
IF((KE.GT.ECO).AND.(KE.LT.EC1))INT=0.
IF(IMPL.LE.1)RETURN

```

STATISTICS

```

ME=AMAX1(ME,KE)
MPC=AMAX1(MPC,KED)
MPD=AMAX1(MPD,-KED)
SPC=SPC+TINC*P1
SPD=SPD+TINC*P2

IF(TIME.LT.TMAX1)RETURN
CCI=CCI+CC
CMI=CMI+CM


```

```

RETURN
END

```

7.10 FRESNEL LENS SOLAR COLLECTOR



The Fresnel lens collector model performs a thermal analysis for a concentrating photovoltaic array which tracks the sun. The array may be cooled passively or by forced air or fluid. Fins may be used on the back to increase convective heat transfer to the environment. Figures 7.10-1 and 7.10-2 show the physical construction of the array and the equivalent thermal network for the focusing collector. The purpose of the model is to compute the cell temperature TC, and the fluid pump rate FMD when fluid cooling is used. The analysis is based on a similar thermal model in SOLCEL [4].




Figure 7.10-1 Equivalent Thermal Network for Fresnel Lens Collector

Temperature




Figure 7.10-2 Fresnel Lens Thermal Model

BASIC EQUATIONS

- 1) Energy absorbed by the collector per unit area

$$Q_H = ST \cdot \tau \cdot (ABC - EFF)$$

where

ST = direct beam solar insolation

τ = lens transmittance

ABC = cell absorptance

EFF = nominal cell efficiency

- 2) Heat balance equations for the thermal network of 7.10-1:

$$Q_h = Q_{TOP} + Q_{BOT}$$

$$Q_{TOP} = H_{TOP}(T_S - T_{ETOP}) = H_L(T_S - T_L)$$

$$Q_{BOT} = H_{BOT}(T_S - T_{EBOT}) = Q_{FIN} + Q_{FLU}$$

$$Q_{FIN} = H_{FIN}(T_S - T_A) = H_I(T_S - T_I)$$


$$Q_{FLU} = H_{FLU}(T_S - T_{FLU})$$

- 3) The temperature variation in the insulating bond between the cell and the heat sink is given by a radial conduction equation for $r > a$:

$$r^2 \frac{\partial^2 T_B}{\partial r^2} + \frac{\partial T_B}{\partial r} - \alpha r^2 T_B = 0,$$

with $\frac{\partial T_B}{\partial r}$ specified at the cell radius $r=a$ and at the equivalent lens radius $r=b$. This equation may be solved using modified Bessel functions to compute T_B at $r=a$ given the overall heat transfer coefficient

and equivalent temperature of the collector minus bonding. Thus the cell, bonding, and collector thermal diagram reduces to



where

$$AL = \text{lens area} = \pi b^2$$

$$TE = (H_{TOP} * T_{ETOP} + H_{BOT} * T_{EBOT}) / (H_{TOP} + H_{BOT})$$

Input Specification Notes

Minimum input parameters to specify FO are

- CMØ = Cooling mode option
- TFØ = Outlet fluid temperature (CMØ=2)
- NT = Number of cooling tubes (CMØ=2)
- HI = Thermal conductivity/thickness of back insulation (CMØ=2)
- AL = Area of lens
- NL = Number of lenses
- CL = Collector length
- CW = Collector width
- RC = Radius of solar cell
- FIR = Cooling fin/collector area ratio (CMØ=0)

The user should check inputs for consistency with those used in the photovoltaic model PV. For example

$$FO \text{ collector area} = CL * CW \stackrel{?}{\geq} AL * NL \stackrel{?}{\geq} PV \text{ array area}$$

$$FO \text{ concentration ratio} = AL / (\pi * RC^2) \stackrel{?}{\geq} PV \text{ concentration ratio}$$

$$FO \text{ cell area} = \pi * RC^2 \stackrel{?}{\geq} PV \text{ array area / number of cells}$$

<u>Inputs/Port</u>	<u>Description</u>	<u>Units</u>
ST	Direct beam solar insolation	w/m^2
WD	Air or wind velocity (default = 0.)	m/s
TA	Ambient temperature	$^{\circ}\text{C}$
TFI	Inlet fluid temperature	$^{\circ}\text{C}$
TFØ	Specified outlet fluid temperature	$^{\circ}\text{C}$
CMØ	Cooling mode (default = 0.)	-
	0 = natural air cooling	
	1 = forced air cooling	
	2 = fluid cooling	
AL	Lens area	m^2
TAU	Lens transmittance (default = 1.)	-
ABC	Cell absorptance (default = .95)	-
EFF	Nominal cell efficiency (default = .12)	-
SPA	Lens to heatsink space (default = .025)	m
EL	Emittance of lens (default = .9)	-
ES	Heatsink emittance (default = .5)	-
EI	Emittance of the back surface (default = .5)	-
CW	Collector width	m
CL	Collector length	m
NL	Number of lenses on collector	-
RC	Radius of solar cells (default = .025)	m
ABL	Absorptance of the lens (default = .05)	-
SPT	Specific heat of coolant (default = 4184)	j/kg-K
HI	Conductivity/thickness of the back insulation (default = 10^9 for no insulation)	$\text{w/m}^2\text{-K}$

<u>Inputs/Port</u> (cont'd)	<u>Description</u>	<u>Units</u>
FIR	Cooling fin to flat plate area ratio (default = 1 for no fin)	-
NT	Number of cooling tubes	-
MFM	Maximum fluid flow rate	kg/s
DT	Diameter of cooling tubes (default = .015)	m
CØS	Conductivity of heatsink (default = 202)	w/m-K
THS	Heatsink plate thickness (default = .003)	m
DEN	Coolant density (default = 980.)	kg/m ³
CØC	Conductivity of the coolant (default = .657)	w/m
HC	Conductivity/thickness of the cell insulator (default = 10 ⁹ for no insulation)	w/m ² -K
CC	Capital cost per unit collector area per year	\$/m ²
CM	Maintenance cost per year	\$
CØP	Cost of operating power	\$/kwh

<u>Outputs/Port</u>	<u>Description</u>	<u>Units</u>
TC	Cell temperature	°C
TS	Heatsink temperature	°C
FMD	Fluid flow rate	kg/s
T 1	Inlet fluid temperature	°C
T 2	Outlet fluid temperature	°C
PH	Collector energy absorbed	kw
P 1	Thermal energy collected	kw

<u>Outputs/Port</u> <u>(cont'd)</u>	<u>Description</u>	<u>Units</u>
REA	Reynolds number (air cooling)	-
REF	Reynolds number (fluid cooling)	-
LTI	Last time at which the collector calculations were performed	hr
ØP	Operating Power used (state)	kwh

CALCULATION SEQUENCE

$$RL = (AL/\pi)^{.5}$$

- 1) Solar Power Absorbed by the Collector

$$QH = ST \cdot \tau (ABC - EFF)$$

$$PH = QH \cdot AL \cdot NL / 1000.$$

If $QH \leq 0.1$ set $TC = TA$, $FMD = P1 = \dot{\phi}P = 0$ and return

If $LTI = TIME$ and $|TFI - T1| < .1$, return

$$LTI = TIME$$

- 2) Convert TA, TFO, TFI to $^{\circ}K$

- 3) Initial Temperature and Flow Rate Estimates

$$TS = TA + QH/20$$

$$TL = (TS + T\phi)^{.5}$$

$$TF = (TFI + TFO)^{.5}$$

$$TI = TL$$

$$FMD = IFLU = 0$$

If $CM\phi = 2$ and $TF\phi > TFI$, $IFLU = 1$

If $IFLU = 1$,

CALCULATION SEQUENCE (cont'd)

$$RO = NT * SPT * (TF\theta - TFI) / (AL * NL)$$

$$FMD = \text{MIN}(0.5 * QH / RO, MFM)$$

o Iterate 4) to 8) three times:

4) HTOP Heat Transfer Coefficient and TETOP

$$T_{SKY} = .0552 * TA^{1.5}$$

$$\left(\begin{matrix} HC1 \\ REA \end{matrix} \right) = \text{CNVC}(TL, TA, WD, CL)$$

Appendix
(2)-(3)

$$HR1 = \text{RADC}(TL, TSKY, EL, 1.) * \frac{(TL - TSKY)}{(TL - TA)}$$

Ibid,(8)

$$H1 = HC1 + HR1$$

$$TM = .5 * (TL + TS)$$

$$HC2 = (7.25 \times 10^{-5} * TM + 4.325 \times 10^{-3}) / SPA$$

$$HR2 = \text{RADC}(TS, TL, ES, EL)$$

Ibid,(8)

$$HL = HC2 + HR2$$

$$HTOP = (1/H1 + 1/HL)^{-1}$$

$$TETOP = TA + ST * (ABL + (1 - \tau) * \tau * ABC) / H1$$

5) Fin Factor and HFIN Heat Transfer Coefficient

$$HC = \text{CNVC}(TI, TA, WD, CL)$$

Ibid,(2)-(3)

$$HR = \text{RADC}(TI, TA, EI, 1.)$$

Ibid,(8)

$$FAC = 4.318 - 4.3375 * \text{EXP}(-.26795 * FIR)$$

(First pass)

$$HFIN = (1/HI + 1/(HC * FAC + HR))^{-1}$$

6) HFLU Heat Transfer Coefficient to Fluid and REF

$$HFLU = 0.$$

CALCULATION SEQUENCE (cont'd)

If IFLU = 0 go to (7)

$$\begin{pmatrix} \text{HFLU} \\ \text{REF} \end{pmatrix} = \text{FLUC}(\text{NT}, \text{DT}, \text{CW}, \text{C}\emptyset\text{S}, \text{THS}, \text{FMD}, \text{DEN}, \text{TF}, \text{C}\emptyset\text{C}) \quad \text{Ibid, (5)-(6)}$$

7) HBOT Heat Transfer Coefficient and Temperature TEBOT

$$\text{HBOT} = \text{HFIN} + \text{HFLU}$$

$$\text{TEBOT} = (\text{HFIN} \cdot \text{TA} + \text{HFLU} \cdot \text{TF}) / \text{HBOT}$$

8) Temperature and Flow Rate Updates

$$\text{H} = \text{HTOP} + \text{HBOT}$$

$$\text{TE} = (\text{HTOP} \cdot \text{TETOP} + \text{HBOT} \cdot \text{TEBOT}) / \text{H}$$

$$\text{TS} = \text{TE} + \text{QH} / \text{H}$$

$$\text{TL} = \text{TS} - \text{HTOP} \cdot (\text{TS} - \text{TETOP}) / \text{HL}$$

$$\text{TI} = \text{TS} - \text{HFIN} \cdot (\text{TS} - \text{TA}) / \text{HI}$$

$$\text{QFLU} = \text{HFLU} \cdot (\text{TS} - \text{TF})$$

$$\text{FMD} = 0.$$

If QFLU > 0, FMD = QFLU/RO

If QFLU > MFM*RO,

$$\text{FMD} = \text{MFM}$$

$$\text{RA} = \text{QFLU} / \text{MFM}$$

$$\text{TF} = \text{TFI} + \text{RA} \cdot \text{AL} \cdot \text{NL} \cdot .5 / (\text{SPT} \cdot \text{NT})$$

9) Check for QFLU < 0

If QFLU < 0 set IFLU = 0 and repeat (4)-(8) once

10) Cell Temperature

$$\text{ALPH} = \text{H} / (\text{C}\emptyset\text{S} \cdot \text{THS})$$

$$\text{X} = \text{SQRT}(\text{ALPH}) \cdot \text{RC}$$

CALCULATION SEQUENCE (cont'd)

$$Y = \text{SQRT}(\text{ALPH}) * \text{RL}$$

$$\text{BETA} = \text{QH} * \text{AL} / (2 \pi * \text{CØS} * \text{THS} * \text{X})$$

$$\text{A} = \text{BETA} * \text{I1}(\text{Y}) / (\text{K1}(\text{X}) * \text{I1}(\text{Y}) - \text{K1}(\text{Y}) * \text{I1}(\text{X}))$$

$$\text{B} = \text{BETA} * \text{K1}(\text{Y}) / (\text{K1}(\text{X}) * \text{I1}(\text{Y}) - \text{K1}(\text{Y}) * \text{I1}(\text{X}))$$

$$\text{TB} = \text{A} * \text{K0}(\text{X}) + \text{B} * \text{I0}(\text{X}) + \text{TE}$$

$$\text{TC} = \text{TB} + \text{QH} * \text{AL} / (\pi * \text{RC}^2 * \text{HC})$$

where I0, I1, K0, K1 are modified Bessel functions.

11) Output Calculation

$$\text{T2} = 2 * \text{TF} - \text{TFI}$$

Convert TC, TS, T1, T2, TA, TFI, TFØ to °C

$$\text{P1} = \text{QFLU} * \text{AL} * \text{NL} / 1000.$$

$$\text{TKP} = 5.E-4 * \text{CL} * \text{CW}$$

$$\dot{Q}P = \text{TKP} + \begin{cases} 0. & \text{if CMØ} = 0 \\ .0742 * (\text{CW} * \text{CL})^{.2835} * \text{WD}^{.567} & \text{if CMØ} = 1 \text{ and WD} > 0 \\ 7.85 \times 10^{-11} * \text{FMD}^{2.855} * \text{DT}^{(-4.702)} * \text{NT} * \text{CL} & \text{if CMØ} = 2 \text{ and FMD} > 0 \end{cases}$$

REFERENCES FOR FO

1. J. K. Linn, "Photovoltaic System Analysis Program-SOLCEL," Sandia Laboratories Report SAND77-1268, 1977.
2. E. L. Burgess and M. W. Edenburn, "One Kilowatt Photovoltaic Subsystem Using Fresnel Lens Concentrators," Paper 11.6, IEEE Photovoltaic Specialists Conference, Baton Rouge, November 1976.

CFC

SUBROUTINE FO(TC,TS,FMD,T1,T2,PH,P1,REA,REF,LTI,OP,OPD,IOP,
 1 ST,WD,TA,TFI,
 1 TFO,CMO,AL,TAU,ABC,EFF,SPA,EL,ES,EI,CW,CL,NL,
 2 RC,ABL,SPT,HI,FIR,NT,MFM,DT,COS,THS,DEN,COC,
 3 HC,CC,CM,CUP)

PURPOSE THIS COMPONENT COMPUTES THE TEMPERATURE OF
 THE SOLAR CELL IN THE FRESNEL LENS COLLECTOR,
 AND CALCULATES THE FLUID PUMP RATE WHEN FLUID
 COOLING IS USED

WRITTEN BY Y.K.CHAN, 10-19-76, VERSION 1

METHOD THERMAL ANALYSIS BASED ON SOLCEL MODEL OF SANDIA

CALL SEQUENCE

OUTPUTS

TC -CELL TEMPERATURE,C
 TS -HEATSINK TEMPERATURE,C
 FMD -FLUID FLOW RATE, KG/S
 T1 -INLET FLUID TEMPERATURE,C
 T2 -OUTLET FLUID TEMPERATURE,C
 PH -COLLECTOR ENERGY ABSORBED,KW
 P1 -THERMAL POWER COLLECTED,KW
 REA -REYNOLDS NUMBER(AIR COOLING)
 REF -REYNOLDS NUMBER(FLUID COOLING)
 LTI -LAST TIME AT WHICH THE COLLECTOR
 CALCULATION WAS PERFORMED,HR
 OP -ACCUMULATIVE OPERATING ENERGY,(STATE),KWH
 OPD -OPERATING POWER,KW
 IOP -INTEGRATOR CONTROL

INPUTS

ST -GLOBAL SOLAR INSOLATION,W/M2
 WD -AIR OR WIND VELOCITY,M/S,(DEFAULT=0)
 TA -AMBIENT TEMPERATURE,C
 TFI -SPECIFIED INLET FLUID TEMPERATURE,C
 TFO -SPECIFIED OUTLET FLUID TEMPERATURE,C
 CMO -COOLING MODE(DEFAULT=0)
 0=NATURAL AIR COOLING
 1=FORCED AIR COOLING
 2=FLUID COOLING
 AL -LENS AREA,M2,(DEFAULT=.09)
 TAU -LENS TRANSMITTANCE(DEFAULT=1.)
 ABC -CELL ABSORPTANCE(DEFAULT=.95)
 EFF -NOMIAL CELL EFFICIENCY(DEFAULT=.12)
 SPA -LENS TO HEATSINK SPACE,M,(DEFAULT=.025)
 EL -EMITTANCE OF LENS(DEFAULT=.9)
 ES -HEATSINK EMITTANCE(DEFAULT=.5)
 EI -BACK SURFACE EMITTANCE(DEFAULT=.5)
 CW -COLLECTOR WIDTH,M
 CL -COLLECTOR LENGTH,M
 NL -NUMBER OF LENSES ON COLLECTOR
 RC -RADIUS OF SOLAR CELLS,M,(DEFAULT=.025)
 ABL -ABSORPTANCE OF THE LENS(DEFAULT=.05)
 SPT -SPECIFIC HEAT OF COOLANT,J/KG-K,(DEFAULT=4184)
 HI -CONDUCTIVITY/THICKNESS OF THE BACK INSULATION,
 W/M2-K,(DEFAULT=10**9 FOR NO INSULATION)

ORIGINAL PAGE IS
 OF POOR QUALITY

FIR -COOLING FIN TO FLAT PLATE AREA RATIO
 (DEFAULT=1 FOR NO FIN)
 NT -NUMBER OF COOLING TUBES
 MFM -MAXIMUM FLUID FLOW RATE,KG/S
 DT -DIAMETER OF COOLING TUBES,M,(DEFAULT=.015)
 COS -CONDUCTIVITY OF HEAT SINK,W/M-K,(DEFAULT=202)
 THS -HEATSINK PLATE THICKNESS,M,(DEFAULT=.003)
 DEN -COOLANT DENSITY,KG/M3,(DEFAULT=980)
 CUC -CONDUCTIVITY OF THE COOLANT,W/M-K,(DEFAULT=.657)
 HC -CONDUCTIVITY/THICKNESS OF THE CELL INSULATOR,
 W/M2-K,(DEFAULT=10**9 FOR NO INSULATION)
 CC -CAPITAL COST PER UNIT COLLECTOR AREA PER YEAR,\$/M2
 CM -MAINTENANCE COST PER YEAR
 COP -COST OF OPERATING POWER,\$/KWH

COMMON /CIMPL/IMPL,ICNT,ITEST
 COMMON /CTIME/TIME /CSIMUL/DUM(7),TMAX
 COMMON /COST/CCAP,CMA,CPO
 REAL NL,NT,MFM,LTI

INITIALIZATION

IF(IMPL.GT.0)GO TO 100
 IF(WD.EQ..99999)WD=0.
 IF(CMD.EQ..99999)CMD=0.
 IF(AL.EQ..99999)AL=.09
 IF(TAU.EQ..99999)TAU=1.
 IF(ABC.EQ..99999)ABC=.95
 IF(EFF.EQ..99999)EFF=.12
 IF(SPA.EQ..99999)SPA=.025
 IF(EL.EQ..99999)EL=.9
 IF(ES.EQ..99999)ES=.5
 IF(EI.EQ..99999)EI=.5
 IF(RC.EQ..99999)RC=.025
 IF(ABL.EQ..99999)ABL=.05
 IF(SPT.EQ..99999)SPT=4184
 IF(HI.EQ..99999)HI=1.E9
 IF(FIR.EQ..99999)FIR=1.
 IF(DT.EQ..99999)DT=.015
 IF(COS.EQ..99999)COS=202
 IF(THS.EQ..99999)THS=.003
 IF(DEN.EQ..99999)DEN=980
 IF(CUC.EQ..99999)CUC=.657
 IF(HC.EQ..99999)HC=1.E9
 RL=SQRT(AL/3.1415926)
 FAC=4.318-4.3375*EXP(-.26795*FIR)
 TMAX1=TMAX*.99999

100 CONTINUE

SOLAR POWER ABSORBED BY THE COLLECTOR

QH=ST*TAU*(ABC-EFF)
 PH=QH*AL*NL/1000.
 IF(QH.GT..01)GO TO 201
 TS=TA
 TC=TA
 OPD=0.

FMD=0.

P1=0.

GO TO 920

201 IF((LTI.EQ.TIME).AND.(ABS(TFI-TI).LT..1))GO TO 920
LTI=TIME

CONVERT TA,TFO,TFI FROM CENTIGRADE TO KELVIN

TA=TA+273

TFO=TFO+273

TFI=TFI+273

INITIAL TEMPERATURE AND FLOW RATE ESTIMATES

TS=TA+QH/20.

TL=(TS+TA)*.5

TF=(TFI+TFO)*.5

TI=TL

IFLU=0.

FMD=0.

IF((ABS(CMO-2.).LT..1).AND.(TFO.GT.TFI))IFLU=1

IF(IFLU.NE.1)GO TO 301

RO=NT*SPT*(TFO-TFI)/(AL*NL)

FMD=MFM

IF(RO.GT.0.)FMD=AMIN1(.5*QH/RO,MFM)

301 CONTINUE

ITERATE HEAT COEFFICIENT CALCULATION THREE TIMES

LOOP=0

400 CONTINUE

H_{TOP}, HEAT TRANSFER COEFFICIENT, AND T_{TOP}, TOP EQUIVALENT TEMPERATURE

TSKY=.0552*(TA**1.5)

CALL CNVC(HC1,REA,TL,TA,WD,CL)

CALL RADC(HR1,TL,TSKY,EL,1.)

HR1=HR1*(TL-TSKY)/(TL-TA)

H1=HC1+HR1

TM=.5*(TL+TS)

HC2=(7.25*1.E-5*TM+4.325E-3)/SPA

CALL RADC(HR2,TS,TL,ES,EL)

HL=HC2+HR2

H_{TOP}=1./(1./H1+1./HL)

T_{TOP}=TA+ST*(ABL+(1-TAU)*TAU*ABC)/H1

HEAT TRANSFER COEFFICIENT H_{FIN}

CALL CNVC(HC2,RE,TI,TA,WD,CL)

CALL RADC(HR,TI,TA,EI,1.)

H_{FIN}=1./(1./H1+1./(HC2*FAC+HR))

FLUID HEAT TRANSFER COEFFICIENT H_{FLU} AND REYNOLDS NUMBER REF

H_{FLU}=0.

IF(IFLU.EQ.0)GO TO 700

CALL FLUC(H_{FLU},REF,NT,DT,CW,COS,THS,FMD,DEN,TF,COC)

EQUIVALENT BOTTOM TEMPERATURE AND HEAT TRANSFER COEFFICIENT

700 CONTINUE

H_{BOT}=H_{FIN}+H_{FLU}

```

C      TEBOT=(HFIN*TA+HFLU*TF)/HBOT
C      UPDATE TEMPERATURE AND FLOW RATE
      H=HTOP+HBOT
      TE=(HTOP*TETOP+HBOT*TEBOT)/H
      TS=TE+QH/H
      TL=TS-HTOP*(TS-TETOP)/HL
      TI=TS-HFIN*(TS-TA)/HI
      QFLU=HFLU*(TS-TF)
C      WRITE(6,108)HFIN,HBOT,TEBOT,HTOP,TETOP,H,TE,TS,TL,TI,QFLU,RO
C 108  FORMAT(1H,*,FO*,8E10.2,/,5X,8E10.2)
      FMD=0.
      IF(QFLU.LE.0.)GO TO 800
      IF(QFLU.GT.(MFM*RO))GO TO 799
      FMD=QFLU/RO
      GO TO 800
799  FMD=MFM
      RA=QFLU/MFM
      TF=TFI+RA*AL*NL*.5/(SPT*NT)
800  CONTINUE

C      LOOP=LOOP+1
      IF(LOOP.LE.2)GO TO 400

C      CHECK FOR EFFECTIVE FLUID COOLING
C
      IF(QFLU.GE.0.)GO TO 900
      IFLU=0.
      GO TO 400
900  CONTINUE


C      CELL TEMPERATURE
C
      ALPH=H/(COS*THS)
      X=SQRT(ALPH)*RC
      Y=SQRT(ALPH)*RL
      BETA=QH*AL/(2.*3.14159*COS*THS*X)
      CALL NATSI1(Y,BI1Y,1)
      CALL NATSKI(X,BK1X,1)
      CALL NATSI1(X,BI1X,1)
      CALL NATSKI(Y,BK1Y,1)
      CALL NATSKO(X,BK0X,1)
      CALL NATSIO(X,BIOX,1)
      A=BETA*BI1Y/(BK1X*BI1Y-BK1Y*BI1X)
      B=BETA*BK1Y/(BK1X*BI1Y-BK1Y*BI1X)
      TB=A*BK0X+B*BIOX+TE
      TC=TB+QH*AL/(3.14159*RC*RC*HC)

C      OUTPUT CALCULATION
C
      TC=TC-273
      TS=TS-273
      TI=TFI-273
      T2=2.*TF-TFI-273
      TA=TA-273
      TFI=TFI-273
      TFO=TFO-273
      P1=QFLU*AL*NL/1000.

```

```
RE1=0.  
IF(ABS(CMO-1.).LE..1 .AND. WD.GT.0.)RE1=.0742*((CW*CL)**.2835)*  
1 WD**.567  
IF(FMD.LE.0.)GO TO 909  
IF(CMO.GT.1.1)RE1=7.85E-11*(FMD**2.855)*(DT**(-4.702))*NT*CL  
909 CONTINUE  
TKP=5.E-4*CL*CW  
IF(IOP.NE.0)CPD=TKP+RE1  
920 IF(TIME.LT.TMAX1)RETURN  
IF(IMPL.LT.2)RETURN  
CCAP=CCAP+CC*AL*NL  
CMA=CMA+CM  
CPO=CPO+COP*OP  
RETURN  
END
```

7.11 FLAT PLATE SOLAR COLLECTOR



The flat plate component performs a thermal analysis on a nonconcentrating photovoltaic array. Three types of cooling may be used:

- Front surface cooling using natural or forced air.
- Back surface cooling using natural or forced air with or without a finned back surface.
- Fluid cooling using tubes on the back and N glass covers ($N = 0, 1, 2, 3$).

Figures 7.11-1 and 7.11-2 show the physical construction of the array and the equivalent thermal network for the flat plate component. The purpose of the analysis is to compute the cell temperature TC and the fluid pump rate FMD when fluid cooling is used. The analysis is based on the flat plate thermal model in SOLCEL [4], except that an empirical equation due to Klein is used to compute the top loss coefficient for 1 to 3 glass covers.

TEMPERATURES




Figure 7.11-1 Physical Diagram of Flat Plate Collector




Figure 7.11-2 Equivalent Thermal Network for Flat Plate Collector

BASIC EQUATIONS

The basic thermal equations for the model are the heat balance equations for the network of Figure 7.11-2.

$$Q_H = ST \cdot T_N (AB - EFF) = Q_{TOP} + Q_{BOT}$$

$$Q_{TOP} = H_{TOP} (T_{CELL} - T_{AMB})$$

$$Q_{BOT} = H_{BOT} (T_{CELL} - T_{EBOT}) = H_C (T_{CELL} - T_{PLATE}) \\ = Q_{FIN} + Q_{FLU}$$

$$Q_{FIN} = H_{FIN} (T_{PLATE} - T_{AMB}) = H_I (T_{PLATE} - T_{INSUL})$$

$$Q_{FLU} = FMD \cdot P (TF\emptyset - TFI) = H_{FLU} (T_{PLATE} - T_{FLUID})$$

where H_{TOP} , H_{BOT} , H_C ... denote heat transfer coefficients, and

T_N = transmittance of the N-covers

AB = collector cell absorptance

EFF = nominal cell efficiency

T_{EBOT} = equivalent bottom temp. (= T_{AMB} with no fluid cooling)

P = fluid specific heat/unit cell area * No. of cooling tubes

T_{FLUID} = average fluid temperature = $(TF\emptyset + TFI)/2$.

Input Specification Notes

Minimum input parameters to specify FO are

CM \emptyset	=	Cooling mode option
TF \emptyset	=	Outlet fluid temperature (CM \emptyset =2)
NG	=	Number of glass covers
HI	=	Conductivity/thickness of the back insulation
CW	=	Collector width
CL	=	Collector length
NT	=	Number of cooling tubes (CM \emptyset =2)
FIR	=	Cooling fin/collector area ratio (CM \emptyset =0)

The user should check the consistency of these inputs (e.g., collector area) with those of the tracking component SO and the photovoltaic component PV.

<u>Inputs/Port</u>	<u>Description</u>	<u>Units</u>
ST	Global solar insolation	w/m^2
TLT	Collector tilt	Deg
WD	Air or wind velocity (default = 0.)	m/s
TA	Ambient drybulb temperature	$^{\circ}\text{C}$
TFI	Inlet fluid temperature	$^{\circ}\text{C}$
TFØ	Specified outlet fluid temperature	$^{\circ}\text{C}$
MFM	Maximum fluid flow rate	kg/s
RE	Tracking power request	kw
CMØ	Cooling mode (default = 0.) 0 = natural air cooling 1 = forced air cooling 2 = fluid cooling	-
NG	Number of glass covers (default = 0.)	-
TN	Transmittance of the N-covers	-
AB	Collector cell absorptance (default = .9)	-
EFF	Nominal cell efficiency (default = .12)	-
EC	Emittance of cell (default = 0.5)	-
EG	Emittance of the glass covers (default = .9)	-
EP	Emittance of the back surface (default = .9)	-
CW	Collector width	m
CL	Collector length	m
SPT	Specific heat of coolant (default = 4184.)	j/kg-K
HI	Conductivity/thickness of the back insulation (default = 10^9 for no insulation)	$\text{w/m}^2\text{K}$

<u>Inputs/Port (cont'd)</u>	<u>Description</u>	<u>Units</u>
FIR	Cooling fin to flat plate area ratio (default = 1. for no fin)	-
NT	Number of cooling tubes (default = 1)	-
DT	Diameter of cooling tubes (default = .015)	m
CØP	Conductivity of mounting plate (default = 202.)	w/m-K
THP	Mounting plate thickness (default = .003)	m
DEN	Coolant density (default = 980.)	kg/m ³
CØC	Conductivity of the coolant (default = .657)	w/m-K
HC	Conductivity/thickness for cell insulation (default = 10 ⁹ for no insulation)	w/m ² -K
CC	Capital cost per unit area per year	\$/m ²
CM	Maintenance cost per year	\$
CPØ	Cost of operating power	\$/kwh
<u>Outputs/Port</u>	<u>Description</u>	<u>Units</u>
TC	Cell temperature	°C
TP	Mounting plate temperature	°C
FMD	Fluid flow rate	kg/s
T1	Inlet fluid temperature	°C
T2	Outlet fluid temperature	°C
PH	Collector energy absorbed	kw
P1	Thermal energy collected	kw
ØP	Operating power used (state)	kwh
REA	Reynolds number (air cooling)	-
REF	Reynolds number (fluid cooling)	-
LTI	Last time at which the flat plate array calculations were performed (used internally)	hr

CALCULATION SEQUENCE

- 1) Solar power absorbed by the collector

$$QH = ST \cdot TN \cdot (AB - EFF)$$

$$PH = QH \cdot CL \cdot CW / 1000$$

If $QH \leq 0.1$ set $TC = TA$, $FMD = P1 = \dot{O}P = 0$ and return

If $LTI = TIME$ and $|TFI - T1| < .1$, return

$$LTI = TIME$$

- 2) Convert TA , $TF\emptyset$, TFI to $^{\circ}K$

- 3) Initial temperature and flow rate estimates

$$TC = TA + QH/20$$

$$TI = (TC + TA) \cdot .5$$

$$TF = (TFI + TF\emptyset) \cdot .5$$

$$TP = TI$$

$$FMD = 0$$

$$IFLU = 0$$

If $CM\emptyset = 2$ and $TF\emptyset > TFI$, $IFLU = 1$

If $IFLU = 1$,

$$RO = NT \cdot SPT \cdot (TF\emptyset - TFI) / CW \cdot CL$$

$$FMD = \text{MIN}(MFM, 0.8 \cdot QH / RO)$$

- Iterate 4) to 8) three times:

- 4) HTOP heat transfer coefficient and REA

$$TSKY = .0552 \cdot TA^{1.5}$$

$$\begin{pmatrix} HC1 \\ REA \end{pmatrix} = CNVC(TC, TA, WD, CL)$$

See (2)-(3) in Appendix

If $NG = 0$,

CALCULATIONS (cont'd)

$$HR1 = RADC(TC, TSKY, EC, 1.) * \frac{(TC - TSKY)}{TC - TA} \quad \text{Ibid, (8)}$$

$$HTOP = HC1 + HR1$$

If NG > 0,

$$HTOP = HTGLAS(N, TA, TC, HC1, EC, EG, TLT) \quad \text{Ibid, (7)}$$

5) Fin factor FAC and HFIN heat transfer coefficient

$$HC2 = CNVC(TI, TA, WD, CL) \quad \text{Ibid, (3)}$$

$$HR2 = RADC(TI, TA, EP, 1.) \quad \text{Ibid, (8)}$$

$$FAC = 4.318 - 4.3375 * \exp(-.26795 * FIR) \quad \text{(first pass)}$$

$$HFIN = (1/HI + 1/(HC2 * FAC + HR2))^{-1}$$

6) HFLU heat transfer coefficient to fluid and REF

$$HFLU = 0.$$

If IFLU = 0 go to 7)

$$\left(\begin{matrix} HFLU \\ REF \end{matrix} \right) = FLUC(NT, DT, DW, CØP, THP, FMD, DEN, TF, CØC) \quad \text{Ibid, (5)-(6)}$$

7) HBOT heat transfer coefficient and equivalent temperature TEBOT

$$HBOT = (1/HC + 1/(HFIN + HFLU))^{-1}$$

$$TEBOT = (HFIN * TA + HFLU * TF) / (HFIN + HFLU)$$

8) Temperature and flow rate updates

$$TC = (QH + HTOP * TA + HBOT * TEBOT) / (HTOP + HBOT)$$

$$TP = TC - HBOT * (TC - TEBOT) / HC$$

$$TI = TP - HFIN * (TP - TA) / HI$$

$$QFLU = HFLU * (TP - TF)$$

CALCULATIONS (cont'd)

$$FMD = \begin{cases} 0. & \text{if } QFLU \leq 0. \\ QFLU/RO & \text{if } QFLU > 0. \end{cases}$$

If $QFLU > MFM \cdot RO$,

$$FMD = MFM$$

$$RA = QFLU/MFM$$

$$TF = TFI + RA \cdot CL \cdot CW \cdot .5 / (SPT \cdot NT)$$

9) Check for $QFLU < 0$

If $QFLU < 0$ set $IFLU = 0$ and repeat 4) to 8) once

10) Output calculations

$$T2 = 2 \cdot TF - TFI$$

Convert $TC, TP, T1, T2, TA, TFI, TF0$ to $^{\circ}C$

$$P1 = QFLU \cdot CL \cdot CW / 1000$$

If $CM0 = 0$

$$\dot{Q}P = RE$$

If $CM0 = 1$ and $WD > 0$

$$\dot{Q}P = RE + .0742 \cdot (CW \cdot CL) \cdot .2835 \cdot WD \cdot .567$$

If $CM0 = 2$ and $FMD > 0$

$$\dot{Q}P = RE + 7.85 \times 10^{-11} \cdot FMD^{2.855} \cdot DT^{(-4.702)} \cdot NT \cdot CL$$

REFERENCES FOR FP

1. S. A. Klein, M.S. Thesis, "The Effects of Thermal Capacitance Upon the Performance of Flat Plate Solar Collectors," University of Wisconsin, 1973.
2. J. A. Duffie and W. A. Beckman, Solar Energy Thermal Processes, Wiley, 1974.
3. F. Kreith, Principles of Heat Transfer, 3rd Edition, International Textbook Company, 1973.

CFP

SUBROUTINE FP(TC,TP,FMD,T1,T2,PH,P1,OP,OPD,IOP,REA,REF,LTI,
 1 ST,TLT,WD,TA,TFI,TFO,MFM,RE,CMD,NG,TN,AB,
 2 EFF,EC,EG,EP,CW,CL,SPT,HI,FIR,NT,DT,COP,THP,DEN,
 3 COC,HC,CC,CM,CPO)

PURPOSE THIS COMPONENT PERFORMS A THERMAL ANALYSIS
 ON A NONCONCENTRATING PHOTOVOLTAIC ARRAY.
 THREE TYPES OF COOLING MAY BE USED
 FRONT SURFACE COOLING USING NATURAL OR FORCED AIR
 BACK SURFACE COOLING USING NATURAL OR FORCED AIR
 WITH OR WITHOUT FINS.
 FLUID COOLING USING TUBES ON THE BACK AND NG
 GLASS COVERS (NG=0,1,2,3).

WRITTEN BY Y.K.CHAN, 11-6-78, VERSION 1

METHOD BASED ON THE FLAT PLATE THERMAL MODEL IN SOLCEL,
 EXCEPT THAT AN EMPIRICAL EQUATION DUE TO KLEIN IS USED
 TO COMPUTE THE TOP LOSS COEFFICIENT FOR 1 TO 3
 GLASS COVERS

CALLING SEQUENCE

OUTPUTS

ST -GLOBAL SOLAR INSOLATION,W/M2
 TC -CELL TEMPERATURE,C
 FMD -FLUID FLOW RATE,KG/S
 T1 -INLET FLUID TEMPERATURE,C
 T2 -OUTLET FLUID TEMPERATURE,C
 PH -COLLECTOR ENERGY ABSORBED,KW
 P1 -THERMAL ENERGY COLLECTED,KW
 OP -OPERATING POWER USED(STATE),KWH
 REA -REYNOLDS NUMBER(AIR COOLING)
 REF -REYNOLDS NUMBER(FLUID COOLING)
 LTI -LAST TIME AT WHICH THE FLAT PLATE ARRAY
 CALCULATIONS WERE PERFORMED(USED INTERNALLY)

INPUTS

TLT -COLLECTOR TILT,DEGREES
 WD -AIR OR WIND VELOCITY,M/S,(DEFAULT=0.)
 TA -AMBIENT DRYBULB TEMPERATURE,C
 TFI -SPECIFIED INLET FLUID TEMPERATURE,C
 TFO -SPECIFIED OUTLET FLUID TEMPERATURE,C
 MFM -MAXIMUM FLUID FLOW RATE,KG/S
 RE -TRACKING POWER REQUEST,KW
 CMD -COOLING MODE(DEFAULT=0)
 0=NATURAL AIR COOLING
 1=FORCED AIR COOLING
 2=FLUID COOLING
 NG -NUMBER OF GLASS COVERS(DEFAULT=0)
 TN -TRANSMITTANCE OF THE NG GLASS COVERS
 AB -COLLECTOR CELL ABSORPTANCE(DEFAULT=.9)
 EFF -NOMINAL CELL EFFICIENCY(DEFAULT=.12)
 EC -EMITTANCE OF CELL(DEFAULT=.5)
 EG -EMITTANCE OF GLASS COVERS(DEFAULT=.9)
 EP -EMITTANCE OF THE BACK SURFACE(DEFAULT=.9)
 CW -COLLECTOR WIDTH,M
 CL -COLLECTOR LENGTH,M
 SPT -SPECIFIC HEAT OF COOLANT,J/KG-K,(DEFAULT=4184)

```

C      HI      -CONDUCTIVITY/THICKNESS OF THE BACK INSULATION,W/M2-K,
C              (DEFAULT=1.E9 FOR NO INSULATION)
C      FIR      -COOLING FIN TO FLAT PLATE AREA RATIO(DEFAULT=1. FOR NO FIN
C      NT      -NUMBER OF COOLING TUBES(DEFAULT=1)
C      DT      -DIAMETER OF COOLING TUBES,M,(DEFAULT=.015)
C      COP      -CONDUCTIVITY OF MOUNTING PLATE,W/M-K,(DEFAULT=202)
C      THP      -MOUNTING PLATE THICKNESS,M,(DEFAULT=.003)
C      DEN      -COOLANT DENSITY,KG/M3,(DEFAULT=980)
C      COC      -CONDUCTIVITY OF COOLANT,W/M-K,(DEFAULT=.657
C      HC      -CONDUCTIVITY/THICKNESS FOR CELL INSULATION,W/M2-K,
C              (DEFAULT=1.E9 FOR NO INSULATION)
C      CC      -CAPITAL COST PER UNIT AREA PER YEAR,$/M2
C      CM      -MAINTENANCE COST PER YEAR,$
C      CPO      -COST OF OPERATING POWER,$/KWH
C

```

```

COMMON /CIMPL/IMPL
COMMON /CTIME/TIME /CSIMUL/DUM(7),TMAX
COMMON /COST/CCAP,CMA,CPOS
REAL LTI,MFM,NG,NT

```

INITIALIZATION

```

IF(IMPL.GT.0)GO TO 100
IF(WD.EQ..99999)WD=0.
IF(CMO.EQ..99999)CMO=0.
IF(NG.EQ..99999)NG=0.
IF(AB.EQ..99999)AB=.9
IF(EFF.EQ..99999)EFF=.12
IF(EC.EQ..99999)EC=.5
IF(EG.EQ..99999)EG=.9
IF(EP.EQ..99999)EP=.9
IF(SPT.EQ..99999)SPT=4184
IF(HI.EQ..99999)HI=1.E9
IF(FIR.EQ..99999)FIR=1.
IF(NT.EQ..99999)NT=1
IF(DT.EQ..99999)DT=.015
IF(COP.EQ..99999)COP=202.
  IF(THP.EQ..99999)THP=.003
IF(DEN.EQ..99999)DEN=980
IF(COC.EQ..99999)COC=.657
IF(HC.EQ..99999)HC=1.E9
TMAX1=TMAX*.99999
FAC=4.318-4.3375*EXP(-.26795*FIR)

```

```
100 CONTINUE
```

SOLAR POWER ABSORBED BY COLLECTOR

```

QH=ST*TN*(AB-EFF)
PH=QH*CL*CW/1000.
IF(QH.GT.0.01)GO TO 201
TP=TA
OPD=0.
TC=TA
FMD=0.
PI=0.
GO TO 920

```

```
201 IF((LTI.EQ.TIME).AND.(ABS(TFI-T1).LT..1))GO TO 920
LTI=TIME
```

CONVERT TA,TFO,TFI TO KELVIN

TA=TA+273
TFO=TFO+273
TFI=TFI+273

INITIAL TEMPERATURE AND FLOW RATE ESTIMATES

TC=TA+QH/20.
TI=(TC+TA)*.5
TF=(TFI+TFO)*.5
TP=TI
FMD=0.
IFLU=0
IF((ABS(CMO-2.)*LT..1).AND.(TFO.GT.TFI))IFLU=1
IF(IFLU.NE.1)GO TO 301
RO=NT*SPT*(TFO-TFI)/(CW*CL)
FMD=MFM
IF(RO.GT.0.)FMD=AMIN1(MFM,.8*QH/RO)
301 CONTINUE

ITERATE HEAT TRANSFER COEFFICIENT CALCULATION THREE TIMES

LOOP=0
400 CONTINUE

HTOP, HEAT TRANSFER COEFFICIENT AND REA, REYNOLDS NUMBER

TSKY=.0552*(TA**1.5)
CALL CNVC(HC1,REA,TC,TA,WD,CL)
IF(NG.GT.0.)GO TO 401
CALL RADG(HR1,TC,TSKY,EC,1.)
HR1=HR1*(TC-TSKY)/(TC-TA)
HTOP=HC1+HR1
GO TO 402
401 HTOP=HTGLAS(NG,TA,TC,HC1,EC,EG,TLT)
402 CONTINUE

HFIN HEAT TRANSFER COEFFICIENT

CALL CNVC(HC2,REN1,TI,TA,WD,CL)
CALL RADG(HR2,TI,TA,EP,1.)
HFIN=1./(1./HI+1./(HC2*FAC+HR2))

HFLU, HEAT TRANSFER COEFFICIENT TO FLUID AND REF, REYNOLDS NUMBER

HFLU=0.
IF(IFLU.EQ.0)GO TO 700
CALL FLUC(HFLU,REF,NT,DT,CW,COP,THP,FMD,DEN,TF,COC)

EQUIVALENT BOTTOM TEMPERATURE TEBOT AND HEAT TRANSFER COEFFICIENT HBOT

700 CONTINUE
HBOT=1./(1./HC+1./(HFIN+HFLU))
TEBOT=(HFIN*TA+HFLU*TF)/(HFIN+HFLU)


ORIGINAL PAGE IS
OF POOR QUALITY

```

C      UPDATE TEMPERATURE AND FLOW RATE
C
TC=(QH+HTOP*TA+HBOT*TEBOT)/(HTOP+HBOT)
TP=TC-HBOT*(TC-TEBOT)/HC
TI=TP-HFIN*(TP-TA)/HI
QFLU=HFLU*(TP-TF)
FMD=0.
IF(QFLU.LE.0.)GO TO 800
IF(QFLU.GT.(MFM*RO))GO TO 799
FMD=QFLU/RO
GO TO 800
799 FMD=MFM
RA=QFLU/MFM
TF=TF1+RA*CL*CW*.5/(SPT*NT)
800 CONTINUE
C
      LOOP=LOOP+1
      IF(LOOP.LE.2)GO TO 400
C
C      CHECK FOR EFFECTIVE FLUID COOLING
C
IF(QFLU.GE.0.)GO TO 900
IFLU=0
GO TO 400
900 CONTINUE
C
      OUTPUT CALCULATION
C
TC=TC-273.
TP=TP-273.
TI=TFI-273.
T2=2.*TF-TFI-273.
TA=TA-273.
TFI=TF1-273.
TFO=TFO-273.
P1=QFLU*CL*CW/1000.
RE1=0.
IF(ABS(CMG-1.).LE..1 .AND. WD.GT.0.)RE1=.0742*((CW*CL)**.2835)*
1 WD**.567
IF(FMD.LE.0.)GO TO 909
IF(ABS(CMO-2.).LE..1)RE1=7.85E-11*(FMD**2.855)*(DT**(-4.702))
1 *NT*CL
909 CONTINUE
IF(IOP.NE.0)OPD=RE+RE1
920 IF(TIME.LT.TMAX1)RETURN
IF(IMPL.LT.2)RETURN
CCAP=CCAP+CC*CL*CW
CMA=CMA+CM
CPOS=CPOS+CPO*OP
RETURN
END

```

7.12 ONE DIMENSION TABLE LOOKUP



Tables

FTA

Description

Tabular values of function

Inputs

Parameter/Port

FIN

Input quantity

AN

$ABS(AN) \leq 0.5$ for equispaced interpolation
($AN < 0$ prevents extrapolation)

Outputs

Variable/Port

F0

Output quantity

Calculation Sequence

$$F0 = FTA(FIN)$$

NOTE: A maximum of 18 points is allowed in the table.

CFU

SUBROUTINE FU(FTA,FO,FIN,AN)

PURPOSE - TO CALCULATE OUTPUT FO AS AN ARBITRARY FUNCTION OF
INPUT FIN USING TABULAR INPUT FTA GIVING $FO=F(FIN)$

METHOD - SELF EXPLANATORY

LIMITATIONS - MAXIMUM ARRAY SIZE IS 18

WRITTEN BY - ADAM LLOYD

LATEST REVISION

APRIL 77

INPUT/OUTPUT LIST

FTA	TABULAR INPUT $FO=F(FIN)$	ANY	INPUT TABLE
FG	OUTPUT	ANY	OUTPUT VAR
FIN	INPUT	ANY	INPUT VAR
AN	SET $ABS(AN).GT.0.5$ FOR UNEQUAL SPACED TABLE DATA---INPUT		
	SET $ABS(AN).LE.0.5$ FOR EQUI-SPACED TABLE DATA		
	A NEGATIVE VALUE OF AN WILL		
	PREVENT EXTRAPOLATION BEYOND		
	TABLE LIMITS		

DIMENSION FTA(1)

NA= SIGN(FTA(2),AN)

NB=FTA(2)+4

N=1


IF($ABS(AN).LE.0.5$) N=0

FO=TBLU1(FIN,FTA(4),FTA(NB),N,NA)

RETURN

END

7.13 TWO DIMENSION TABLE LOOKUP



Tables

FTA

Description

Table of functional relationships (maximum number of table values = 144)

Inputs

Parameter/Port

FNA	Input quantity (primary)
FNB	Input quantity (secondary)
AN	$ABS(AN) \leq 0.5$ for equal spaced FNA data*
BN	$ABS(BN) \leq 0.5$ for equal spaced FNB data*

Outputs

Variable/Port

F0	Output quantity
----	-----------------

Calculation Sequence

$$F0 = FTA(FNA, FNB)$$

* A negative value for AN or BN prevents extrapolation beyond the table boundaries.

CFV

SUBROUTINE FV(FTA,FO,FNA,FNB,AN,BN)

PURPOSE - TO CALCULATE OUTPUT FO AS AN ARBITRARY FUNCTION OF INPUT VARIABLES FNA AND FNB. INPUT TABLE FTA IS USED GIVING $FO=F(FNA,FNB)$

METHOD - TWO DIMENSIONAL TABLE LOOKUP

LIMITATIONS - MAX ALLOWABLE SIZE OF TABULAR ARRAY IS 12X12.

WRITTEN BY - GEORGE DULEBA

LATEST REVISION MAY 76

INPUT/OUTPUT LIST

FTA	TABULAR INPUT	---	INPUT TABLE
FO	OUTPUT		OUTPUT VAR
FNA	INPUT A	ANY	INPUT VAR
FNB	INPUT B	ANY	INPUT VAR
AN	SET $ABS(AN) \geq 0.5$ FOR UNEQUAL SPACED FNA DATA- A NEGATIVE VALUE INDICATES THAT THE NEAREST END POINT IS TO BE USED UPON EXTRAPOLATION.	ANY	INPUT PARM
BN	SET $ABS(BN) \geq 0.5$ FOR UNEQUAL SPACED FNB DATA- A NEGATIVE VALUE INDICATES THAT THE NEAREST END POINT IS TO BE USED UPON EXTRAPOLATION.		INPUT PARM

DIMENSION FTA(1)

N1=FTA(3)+4

N2=FTA(2)+FTA(3)+4

N3=FTA(2)

N4=FTA(3)

N5= SIGN(FTA(2),AN)

N6= SIGN(FTA(3),BN)

NAN=1

IF(ABS(AN).LE.0.5) NAN=0

NBN=1


IF(ABS(BN).LE.0.5) NBN=0

FO=TBLU2(FNA,FNB,FTA(N1),FTA(4),FTA(N2),NAN,NBN,N5,N6,N3,N4)

RETURN

END

7.14 AC INDUCTION GENERATOR



The induction generator produces electrical power proportional to rotor slip, i.e., difference between rotor speed and synchronous speed. This relationship is used to compute rotor speed given input power and the generator parameters. Two power losses are modeled: a constant multiplicative term due to resistive heating and an additive term due to mechanical friction. Default parameters are based on a conventional squirrel-cage induction motor/generator machine. This component can also be used as a synchronous generator with $RAS \leq .01$.

Basic Equations

Output power P2 and rotor speed RS are computed from the following equations:

$$P2 = EE * (P1 - C * RS^2)$$

$$\frac{P2}{RAP} = \frac{(RS/RSY - 1)}{RAS} \quad (\text{Power is proportional to slip})$$

where EE = electrical efficiency

Minimum input parameters to specify GE are

RAP = rated output power,

SR = stator resistance

Note: SR may be chosen to obtain a given efficiency EE using

$$SR = V\phi^2 (1/EE - 1) / (RAP * 1000)$$

Inputs

<u>Parameter/Port</u>	<u>Description</u>	<u>Units</u>
P 1	Input power	kw
RAP	Rated output power	kw
RSY	Synchronous rotor speed (D = 1800)	rpm
RAS	Rated power slip (D = 0.05)	-
DA	Mechanical damping (D = 0.0)	joule-sec
SR	Internal stator resistance (D = 6.4/RAP)	ohms
V0	Rated bus voltage (D = 400)	volts
EF 1	Input product efficiency	-
MP 1	Maximum input discharge rate (D = 1×10^8)	kw
CC	Capital cost/year	\$
CM	Maintenance cost/year	\$

Outputs

<u>Variable/Port</u>	<u>Description</u>	<u>Units</u>
P 2	Output power	kw
EE	Electrical efficiency	-
RS	Rotor speed	rpm
PL	Power loss	kw
EF 2	Output product efficiency	-
MP 2	Maximum output discharge rate	kw

Statistics

MPN	Maximum output power/rated power	kw
SP	Total output energy	kwh

D - Default values supplied.

Calculation Sequence

1) First pass only

$$EFF = 1$$

$$I_{RAT} = RAP * 1000 / V_0$$

$$EE = \frac{RAP}{RAP + SR * I_{RAT}^2 / 1000}$$

2) If P1 = 0 set P2 = 0, RS = RSY and go to 4)

Compute rotor speed ω in rad/sec using

$$\frac{EE(P1 * 1000 - \omega^2 * DA)}{RAP * 1000} = \frac{(\omega / \omega_0 - 1)}{RAS}$$

$$\text{with } \omega_0 = RSY * (2 \pi / 60)$$

3) Compute RS and output power

$$RS = \omega * (60 / 2 \pi)$$

$$P2 = RAP(RS / RSY - 1) / RAS$$

$$P2 > RAP \quad \Rightarrow \quad \text{DIAGNOSTIC}$$

$$EFF = P2 / P1$$

4) Compute loss, efficiency terms

$$PL = P1 - P2$$

$$EF2 = EF1 * EFF$$

5) Compute maximum output rate

$$MP2 = \text{MIN}(RAP, MP1 * EFF)$$

6) Compute Statistics and Costs

CGE

SUBROUTINE GE(P2,EE,RS,PL,EF2,PM2,PMN,SP,P1,RAP,RSY,RAS,DA,SR,VO,
1 EF1,PM1,CCI,CMI)

PURPOSE MODEL AC INDUCTION GENERATOR

METHOD MECHANICAL AND ELECTRICAL EFFICIENCIES ARE USED TO COMPUTE
OUTPUT POWER. ROTOR SPEED IS COMPUTED ASSUMING POWER IS
PROPORTIONAL TO SLIP.

WRITTEN BY A.W. WARREN

VERSION 1, MARCH 16 1971

CALL SEQUENCE

OUTPUTS

P2 - OUTPUT POWER, KW
EE - ELECTRICAL EFFICIENCY
RS - ROTOR SPEED, RPM
PL - POWER LOSS, KW
EF2 - OUTPUT PRODUCT EFFICIENCY
PM2 - MAXIMUM OUTPUT POWER, KW
PMN - MAX. OBSERVED OUTPUT POWER / RATED POWER
SP - TOTAL OUTPUT ENERGY, KWH

INPUTS

P1 - INPUT POWER, KW
RAP - RATED OUTPUT POWER, KW
RSY - SYNCHRONOUS ROTOR SPEED, RPMN
RAS - RATED POWER SLIP (DEFAULT = .05)
DA - MECHANICAL DAMPING, JOULE-SEC
SR - STATOR RESISTANCE, OHMS
VO - RATED BUS VOLTAGE, VOLTS
EF1 - INPUT PRODUCT EFFICIENCY
PM1 - MAXIMUM INPUT POWER, KW
CCI - CAPITAL COST/YEAR, \$
CMI - MAINTENANCE COST/YEAR, \$

COMMON /CIMPL/ IMPL,ICNT /CTIME/ TIME
COMMON /COST/ CC,CM,CO,CV /CSIMUL/ DUM(6),TINC,TMAX
INITIALIZATION

IF(IMPL.GT.0) GO TO 10
EFF = 1.
TMAX1 = TMAX* .99999
IF(RSY.EQ. .99999) RSY = 1800.
IF(RAS.EQ. .99999) RAS = .05
IF(DA .EQ. .99999) DA = 0.
IF(SR .EQ. .99999) SR = 6.4/RAP
IF(VO .EQ. .99999) VO = 400.
IF(PM1.EQ. .99999) PM1 = 1.E10
PMN = 0.0
SP = 0.0
RATI = RAP*1000./VO
EE = RAP/(RAP + SR*.001*RATI**2)

COMPUTE ROTOR SPEED AND OUTPUT POWER

10 IF(P1.GT. 0.) GO TO 20
P2 = 0.0

PL = 0.0
 RS = RSY
 GO TO 30

C

20 A = RAP/(EE*RAS)
 B = RSY/(A + RSY**2*DA*1.0966E-5)
 RS = B*(A + P1)
 P2 = RAP*(RS/RSY - 1.)/RAS
 IF (P2.GT.RAP.AND.IMPL.EQ.2) WRITE(6,100)
 100 FORMAT(1H0, 40X, 37HGENERATOR OUTPUT EXCEEDS RATED POWER /)

C

IF(P2.GT.RAP .AND. IMPL.EQ.2) ICNT=ICNT+1
 PL = P1 - P2
 EFF = P2/P1
 30 EF2 = EF1*EFF
 PM2 = AMIN1(RAP, PM1*EFF)

C

C

STATISTICS
 IF(IMPL.LE.1) RETURN
 PMN = AMAX1(PMN, P2/RAP)
 SP = SP + P2*.5*TINC

C


C

COST SUMMATION
 IF(TIME.LT.TMAX1) RETURN
 CC = CC + CC1
 CM = CM + CM1

C

RETURN
 END

7.15 FIXED RATIO TRANSMISSION



This component models a fixed gear ratio transmission. Power losses are modeled by a table lookup depending on input power. Rotor input speed is used as a feedback variable.




FIGURE 7.15: FIXED GEAR POWER LOSS

<u>Tables</u>	<u>Description</u>	<u>Units</u>
PLØ	Power loss versus input power	kw

InputsParameter/Port

GR*		Gear ratio	-
RS	2	Output rotor speed	rpm
P	1	Input power	kw
EF	1	Input product efficiency	-
MP	1	Maximum input power (Default = 1×10^8)	kw
CC		Capital cost/year	\$
CM		Maintenance cost/year	\$

OutputsVariable/Port

P	2	Output power	kw
TØ		Output torque	ft-lb
PL		Power loss	kw
EF	2	Output product efficiency	-
MP	2	Maximum output power	kw
RS	1	Input rotor speed	rpm

* A value for GR is supplied when connecting to the wind turbine component WT.

Calculation Sequence

1) $MP2 = MP1 - PL0(MP1)$ (First Pass Only)

If $P1 \leq 0$, set $PL = P2 = 0$ and go to 2)

$$PL = PL0(P1)$$

$$P2 = P1 - PL$$

$$RS1 = RS2/GR$$

$$EF2 = EF1 * P2 / P1$$

2) $T0 = P2 * 737.6 / (RS2 * 2 \pi / 60)$

3) Compute Costs

CGR

SUBROUTINE GR(PLO,P2,TO,PL,EF2,PM2,RS1,GRA,RS2,P1,EF1,PM1,CCI,CMI)

PURPOSE MODEL A FIXED GEAR RATIO TRANSMISSION

METHOD POWER LOSSES ARE INPUT AS A FUNCTION OF INPUT POWER P1.

WRITTEN BY A.W. WARREN

VERSION 1, MARCH 16 197

CALL SEQUENCE

TABLES

PLO - POWER LOSS IN KW VERSUS INPUT POWER IN KW

OUTPUTS

P2 - OUTPUT POWER, KW
 TO - OUTPUT TORQUE, FT-LB
 PL - POWER LOSS, KW
 EF2 - OUTPUT PRODUCT EFFICIENCY
 PM2 - MAXIMUM OUTPUT POWER, KW
 RS1 - INPUT ROTOR SPEED, RPM

INPUTS

GRA - GEAR RATIO
 RS2 - OUTPUT ROTOR SPEED, RPM
 P1 - INPUT POWER, KW
 EF1 - INPUT PRODUCT EFFICIENCY
 PM1 - MAXIMUM INPUT POWER, KW
 CCI - CAPITAL COST / YEAR, \$
 CMI - MAINTENANCE COST / YEAR, \$

DIMENSION PLO(1)

COMMON /CIMPL/IMPL /CTIME/ TIME

COMMON /COST/CC,CM,CO,CV /CSIMUL/ DUM(7),TMAX

INITIALIZATION

NP = PLO(2)

IF(IMPL.GT.0) GO TO 10

TMAX1 = .99999*TMAX

EF2=1.

RS2=1.

IF(PM1.EQ. .99999) PM1=1.E10

PM2 = PM1

IF(PM1.LE. PLO(3+NP)) PM2 = PM1-TBLU1(PM1,PLO(4),PLO(4+NP),1,-NP)

POWER LOSS AND ROTOR SPEED CALUCATIONS

10 PL=0.

P2=0.

IF(P1 .EQ. 0.) GO TO 20

PL = TBLU1(P1,PLO(4),PLO(4+NP),1,-NP)

P2 = P1 - PL

EF2 = EF1*P2/ P1

RS1 = RS2/GRA

20 IF(RS2 .GT. 0.) TO = P2*7043./RS2

COST SUMMATION

IF(IMPL.LE.1) RETURN

IF(TIME.LE.TMAX1) RETURN

GR


... CC = CC + CCI

CM = CM + CMI

RETURN

END

7.16 HISTOGRAM



The input quantity is monitored during a SIMULATE analysis. When time reaches TMAX a plotted histogram is produced with 16 intervals that span the range from FLO to FUP.

Inputs

<u>Variable/Port</u>	<u>Description</u>
FIN	Input quantity to be monitored
FUP	Upper limit for histogram
FLO	Lower limit for histogram
F1,...F16 ¹	Array containing histogram data
FA ¹	Measurement interval

Outputs

<u>Variable/Port</u>	
AV	Mean value (running sum during simulation)
SD	Standard deviation (running sum squared)
SAM	Number of samples

¹ These quantities do not require data input values.

CHG

SUBROUTINE HG(SAMP,AV,SD,F1,F2,F3,F4,F5,F6,F7,F8,F9,F10,F11,
1 F12,F13,F14,F15,F16,FA, FIN,FUP,FLO)

VERSION 2. REVISED: MARCH 1977

PURPOSE - DEVELOP A RUNNING HISTOGRAM OF AN INPUT SEQUENCE
CALL SEQUENCE

SAMP- OUTPUT NUMBER OF SAMPLES
AV - OUTPUT AVERAGE (RUNNING SUM)
SD - OUTPUT STANDARD DEVIATION (RUNNING SUM SQUARED)
F1-F16 - ARRAY WITH NUMBER OF OCCURENCES IN EACH INTERVAL
FA - OUTPUT CONTAINING MEASUREMENT INTERVAL
FUP - INPUT SPECIFYING UPPER MEASUREMENT LIMIT
FLO - INPUT SPECIFYING LOWER MEASUREMENT LIMIT
FIN - INPUT MEASUREMENT

DIMENSION F1(16),TDI(8),AX1(16)

DIMENSION GRAPH(114,46)

COMMON GRAPH

COMMON/CTIME/TIME/CSIMUL/DUM(7),TMAX

COMMON/CCVRLY/DUMM(3),CPUSEC /CIMPL/IMPL

DATA BLANK,VERT,HORIZ,POINT/1H ,1HI,1H-,1H*/

IF(IMPL.GT.0) GO TO 100

DO 50 I=1,16

50 F1(I)=0.

FA=(FUP-FLO)/14.

SD=0.

AV =0.0

SAMP=0.0

100 CONTINUE

IF(IMPL.LT.2) RETURN

DO 200 I=1,16

L=I

FAX=FLO+(I-1)*FA

IF(FIN.LE.FAX) GO TO 300

200 CONTINUE

300 F1(L)=F1(L)+1.

SAMP=SAMP+1.

AV=AV+FIN

SD=SD+FIN*FIN

IF(TIME.LT.TMAX*.99999)RETURN

SAMP=0.

DO 350 I=1,16

350 SAMP=SAMP+F1(I)

ISAMP=SAMP

ISAMP=MAX0(1,ISAMP)

AV=AV/ISAMP

SD=SQRT(SD/ISAMP-AV*AV)

XMAX=F1(1)

DO 360 I=1,16

360 IF(F1(I).GE.XMAX) XMAX=F1(I)

IF(XMAX.EQ.0.) XMAX=10.

HX=XMAX/44.

DO 370 I=1,46

GRAPH(1,I)=VERT

370 GRAPH(114,I)=VERT

DO 380 I=2,113

GRAPH(I,1)=HORIZ

380 GRAPH(I,46)=HORIZ

DO 400 I=5,103,14

```
400 GRAPH(I,46)=VERT
DO 450 I=8,106,7
450 GRAPH(I,1)=VERT
DO 500 I=2,45
DO 500 J=2,113
500 GRAPH(J,I)=BLANK
DO 600 IC=1,16
J=IFIX(45.5-F1(IC)/HX)
DO 600 J1=1,7
J2=(IC-1)*7+J1+1
DO 600 J3=J,45

600 GRAPH(J2,J3)=POINT
DO 700 I=1,16


700 AX1(I)=F1(I)/ISAMP
DO 800 I=1,8

800 TD1(I)=FLO+(I-1)*2.*FA-FA/2.

WRITE(6,900)(GRAPH(I,1),I=1,114)
900 FORMAT(1H1,9X,114A1/)
WRITE(6,1000)(AX1(I),I=1,16)
1000 FORMAT(1H+,9X,1HI,16F7.5,1HI/)
WRITE(6,1100)
1100 FORMAT(1H+,9X,1HI,112X,1HI/)
WRITE(6,1200)((GRAPH(I,J),I=1,114),J=2,46)
1200 FORMAT(1H+,9X,114A1/45(10X,114A1/))
WRITE(6,1300)(TD1(I),I=1,8)
1300 FORMAT(1H+,9X,8(F13.5,1X)//)
WRITE(6,1400) ISAMP,AV,SD
1400 FORMAT(1H+,10X,14HHISTOGRAM FOR ,I7,8H SAMPLES,
19H MEAN= ,F13.5,18H STANDARD DEV.= ,F13.5/)
RETURN
END
```

ORIGINAL PAGE IS
OF POOR QUALITY

7.17 HYDRO STORAGE VESSEL



The hydro storage vessel is modeled as an above ground reservoir with a large and constant surface area. The change in reservoir height between maximum and minimum levels is assumed small in comparison to the height of the water above the turbine. Hence, reservoir height is assumed constant. The reservoir has specified evaporation and leakage rates. Average input flow gained by rainfall is also specified. Energy storage is calculated based on the potential energy of the water in the reservoir relative to the turbine inlet.

Basic Equation

$$\dot{MA} = M1 - M2 - NE*AS - NL + MDR*AS/14052$$

Inputs

<u>Parameter/Port</u>		<u>Description</u>	<u>Units</u>
M	1	Input water mass flow rate	gal/h
NE		Evaporation coefficient (D = 0.03)	gal/ft ² -h
AS		Reservoir surface area	ft ²
NL		Leakage coefficient (D = 8.0)	gal/h
MDR		Rainfall rate	inches/year
MDM		Maximum allowable mass flow rate (D = 4X10 ⁵)	gal/h
MM		Maximum allowable reservoir capacity (D=5X10 ⁶)	gal
M0		Minimum allowable reservoir capacity	gal
H	1	Reservoir height above turbine	ft
MDE		Reservoir deadband for priority resequence	gal
RE	1	Power request (discharge)	kw
CR		Reservoir cost coefficient (D = 0.025)	\$/gal
EF	1	Input product efficiency	-
MP	1	Maximum input charging rate	kw
LE		Reservoir life expectancy	years
CM		Maintenance cost/year	\$

Outputs

<u>Variable/Port</u>			
M	2	Outlet water mass flow rate	gal/hr
E		Energy stored	kwh
H	2	Reservoir height above turbine (=H1)	ft
MA		Reservoir mass (state)	gal
CC0		Reservoir cost/year	\$
MP	2	Maximum discharge rate allowable	kw
INT		Priority interrupt flag	-
RE	2	Maximum charging rate request	kw

D - Default values supplied

<u>Statistics</u>	<u>Description</u>	<u>Units</u>
MDU	Maximum mass flow rate	gal/hr
MU	Maximum reservoir mass	gal
ML	Minimum reservoir mass	gal

The calculation sequence and default values assume a pond sized for 120kw storage for 24 hours (5×10^6 gallons of water 200 ft. above turbine inlet). The evaporation coefficient NE assures the pond drops $\frac{1}{2}$ " in height per 10 hours. To obtain a more accurate value for this parameter requires knowledge of local conditions. The leakage coefficient NL is based on the assumption of a loss of 0.1% of the maximum reservoir capacity in the rated storage time of 24 hours. The reservoir cost estimates are based on the compensation reservoir given in Reference 1.

-
1. "Preliminary Feasibility Evaluation of Compressed Air Storage Power Systems," United Technologies AER 74-00242, December 1976.

Calculation Sequence

$$C1 = \text{conversion constant} = 0.377 \times 10^{-6} \frac{\text{kwh}}{\text{ft-lb}}$$

$$C2 = \text{conversion constant} = 8.3398 \text{ lb/gal}$$

$$A = C1 * C2 * H1$$

1) Reservoir cost

$$CC = CR * MM / LE$$

2) Volume of water discharged

$$M2 = RE1 / A$$

3) Reservoir water volume

$$MA = M1 - M2 - NE * AS - NL + (MDR * AS / 14052.)$$

4) Energy stored

$$E = A * M$$

5) Checks

$$M1 > MDM \text{ or } M2 > MDM \Rightarrow \text{DIAGNOSTIC}$$

$$M > MM, \Rightarrow \text{DIAGNOSTIC}$$

$$M < M0 \Rightarrow \text{DIAGNOSTIC}$$

6) Priority interrupt

$$\text{If } M \leq M0, \text{ INT} = 1$$

$$\text{If } M > M0 + MDE \text{ and } \text{INT} = 1, \text{ INT} = 0$$

$$\text{If } M \geq MM, \text{ INT} = -1$$

$$\text{If } M < MM - DME \text{ and } \text{INT} = -1, \text{ INT} = 0$$

Calculation Sequence Cont.

7) Maximum charging rate request

$$MD1 = \text{MIN} (MDM, (MM-M)/TINC)$$

$$RE2 = \text{MIN} (MP1, MD1 * A) / EF1$$

Maximum discharge rate

$$MP2 = A * \text{MIN} (MDM, (M-M0)/TINC)$$

where TINC = integration step size in hrs

8) Compute Statistics and Costs

CHS

SUBROUTINE HS(M,DM,IM,M2,E,H2,CC,MP2,INT,RE2,MDU,MU,ML,M1,NE
1 ,AS,NL,MDR,MDM,MM,MO,H1,MDE,RE1,CR,EFl,MP1,LE,CM)

PURPOSE PERFORMANCE OF A LARGE RESERVOIR AS AN ENERGY STORAGE
DEVICE.

METHOD ENERGY IN STORAGE IS CALCULATED FROM THE POTENTIAL
BETWEEN THE RESERVOIR AND THE TURBINE INLET.

WRITTEN BY F. D. MAHONY

VERSION 1, MARCH 30 1977

CALL SEQUENCE OUTPUTS

M - RESERVOIR MASS (STATE VARIABLE), GAL
DM - RESERVOIR MASS FLOWRATE, GAL/HR
IM - STATUS INDICATOR
M2 - OUTLET WATER MASS FLOW RATE, GAL/HR
E - ENERGY STORED, KWH
H2 - RESERVOIR HEIGHT ABOVE TURBINE (=H1), FT
CC - RESERVOIR COST/YEAR, \$
MP2 - MAXIMUM DISCHARGE RATE ALLOWABLE, KW
INT - PRIORITY INTERRUPT FLAG
RE2 - MAXIMUM CHARGING RATE REQUEST, KW
MDU - MAXIMUM MASS FLOW RATE, GAL/HR
MU - MAXIMUM RESERVOIR MASS, GAL
ML - MINIMUM RESERVOIR MASS, GAL

INPUTS

M1 - INPUT WATER MASS FLOW RATE, GAL/HR
NE - EVAPORATION COEFFICIENT, GAL/FT**2-HR
AS - RESERVOIR SURFACE AREA, FT**2
NL - LEAKAGE COEFFICIENT
MDR - RAINFALL RATE, INCHES/YEAR
MDM - MAXIMUM ALLOWABLE MASS FLOW RATE, GAL/HR
MM - MAXIMUM ALLOWABLE RESERVOIR CAPACITY, GAL
MO - MINIMUM ALLOWABLE RESERVOIR CAPACITY, GAL
H1 - RESERVOIR HEIGHT ABOVE TURBINE, FT
MDE - RESERVOIR DEADBAND FOR PRIORITY RESEQUENCE, GAL
RE1 - POWER REQUEST (DISCHARGE), KW
CR - RESERVOIR COST COEFFICIENT
EFl - INPUT PRODUCT EFFICIENCY
MP1 - MAXIMUM INPUT CHARGING RATE, KW
LE - RESERVOIR LIFE EXPECTANCY, YEARS
CM - MAINTENANCE COST/YEAR, \$

COMMON/CIMPL/IMPL,ICNT/CTIME/TIME/CSIMUL/DUM(7),TMAX
COMMON/COST/CCI,CM1

REAL M2,MP2,MDU,MU,ML,M1,NE,NL,MDR,MDM,MM,MO,MDE,MP1,LE,INT,M
REAL MD1,MDM1

IF(IMPL.GT.0)GO TO 100

RE1=0.0

H2=H1

TMAX1=TMAX*0.99999

```
TINC=DUM(7)
C1 = 3.1441E-6
```

```
INT=0.0
MDU=0.0
MU =0.0
ML =1.0E10
IF(NL .EQ. .99999)NE =0.03
IF(NL .EQ. .99999)NL =8.0
IF(MDM.EQ. .99999)MDM=4.0E5
IF(MM .EQ. .99999)MM =5.0E6
IF(CR .EQ. .99999)CR =0.025
```

RESERVOIR COST

```
CC =CR*MM/LE
```

VOLUME OF WATER DISCHARGED

```
100 A=C1*H1
M2 =RE1/A
```

RESERVOIR MASS FLOW RATE

```
IF(IM.NE.0)DM=M1-M2-NE*AS-NL+MDR*AS/14052.0
```

ENERGY STORED

```
E =A*M
```

```
MDM1=MDM/.9999
```

```
IF(M1.LT.MDM1.AND.
```

```
1 M2.LT.MDM1)GO TO 200
```

```
IF(IMPL.EQ.2)WRITE(6,1010)M1,M2,MDM
IF(IMPL.EQ.2) ICNT=ICNT+1
```

```
200 IF(M .LT.MM+MDE)GO TO 300
```

```
IF(IMPL.EQ.2)WRITE(6,1020)M,MM
IF(IMPL.EQ.2)ICNT=ICNT+1
```

```
300 IF(M .GT.MO)GO TO 400
```

```
IF(IMPL.EQ.2)WRITE(6,1030)M,MO
IF(IMPL.EQ.2) ICNT=ICNT+1
```

PRIORITY INTERRUPT

```
400 IF(M .LE.MO)INT=1.0
IF(M .GT.(MO+MDE).AND.
```

```
1 INT.EQ.1.0)INT=0.0
```

```
IF(M .GT.MM)INT=-1.0
```

```
IF(M .LT.(MM-MDE).AND.
```

```
1 INT.EQ.-1.0)INT=0.0
```


MAXIMUM CHARGE RATE REQUEST AND DISCHARGE RATE

```

C      MD1=AMIN1(MDM,AMAX1(0.,(MM-M)/TINC))
      RE2=AMIN1(MP1,MD1*A)/EF1
      MP2=A*AMIN1(MDM,AMAX1(0.,(M-MD)/TINC))
C
C      IF(IMPL.LE.1)RETURN
C
C      STATISTICS
C
C      MDU=AMAX1(DM,MDU)
      MU =AMAX1(M ,MU )
      ML =AMIN1(M ,ML )
C
C      IF(TIME.LT.TMAX1)RETURN
C
C      CCI=CCI+CC
      CMI=CMI+CM
C
C      RETURN
C
1010  FORMAT(1H0,23HHS INLET MASS FLOW RATE,F12.3, 5H OR ,
      1      21HOUTLET MASS FLOW RATE,F12.3,
      2      26H IS GREATER THAN MAXIMUM,F12.3)
1020  FORMAT(1H0,19HHS RESERVOIR VOLUME,F12.3,
      1      30H EXCEEDED MAXIMUM ALLOWABLE,F12.3)
1030  FORMAT(1H0,19HHS RESERVOIR VOLUME,F12.3,
      1      24H DROPEO BELOW MINIMUM,F12.3)
C
      END

```


7.18 HYDRAULIC TURBINE



The hydraulic turbine model is based on a constant speed design and is typical of a reaction/Francis type turbine. The turbine is assumed to be designed to a specified operating point and output power.

For off design performance the pump efficiency is assumed to be functionally related to the first power of the mass flow rate. The equations are assumed to be valid over a specified range of values for the turbine parameter.

Basic Equations

$$P = \text{EFF} * M * C1 * C2 * H$$

$$\text{EFF} = 1 - (1 - \text{EFD}) * \text{MD} / M$$

where C1, C2 are conversion constants.

Inputs

<u>Parameter/Port</u>	<u>Description</u>	<u>Units</u>
M	Inlet mass flow rate	gal/h
H	Height of reservoir above turbine inlet	ft
EFD	Design pt. turbine efficiency (D = 0.90)	-
MD	Design pt. mass flow rate (D = 2×10^5)	gal/h
MM	Maximum mass flow rate (D = 3×10^5)	gal/h
EF	1 Input product efficiency	-
MP	1 Input maximum discharge rate	kw
CK	Turbine capacity cost coefficient ¹ (D = 0.011)	-
F0	Turbine exponent for cost calculations (D = 0.5)	-
RS	Angular velocity	rpm
X	Turbine head exponent for cost calculations (D = 0.25)	-

Outputs

<u>Variable/Port</u>		
CC0	Turbine cost/year	\$
EFF	Turbine efficiency	-
P	2 Output power	kw
EF	2 Output product efficiency	-
MP	2 Output maximum discharge rate	kw
CP	Turbine characteristic parameter	-

Statistics

CPU	Maximum CP	-
CPL	Minimum CP	-
PU	Maximum output power	kw

D - Default values

¹CK = Capital cost (known unit)/((MD*481.2)**F0**H**X*life expectancy)

The calculation sequence and default values assume a constant speed reaction type hydraulic turbine nominally rated for 120kw and located 200 ft. below the reservoir. The equations relating the various physical parameters are assumed to be valid for the indicated range of the characteristic turbine parameter, CP. The equations and cost estimates are based on the data given in Reference 1, and the cost estimates on data from Reference 2.

Calculation Sequence

$$C1 = 0.377 \times 10^{-6} \frac{\text{kwh}}{\text{ft-lb}}$$

$$C2 = 8.3398 \text{ lb/gal}$$

$$A = C1 * C2 * H$$

1) Costs

$$CC0 = CK * (MD * 481.2) * F0 * H * X$$

2) Efficiency

If $M \leq 0$ set $EFF = 1$ and go to 3)

$$EFF = 1 - (1 - EFD) * MD / M$$

$$EFF = \text{MAX}(EFF, 0.6)$$

-
1. L. Marks and T. Baumeister, "Mechanical Engineers Handbook", McGraw Hill, N.Y., 1958, Section 9, p. 207.
 2. Carson and Fogleman, "Comparison of Methods for Converting Existing Power Plants to Pumped Storage Facilities", International Engineering Company, Inc., 1974.

Calculation Sequence Cont.

3) Output Power

$$P2 = EFF * A * M$$

4) Product Efficiency

$$EF2 = EF1 * EFF$$

$$EFM = MM - (1 - EFD) * MD$$

5) Maximum Discharge Rate

$$MP2 = \text{Min} \{ MP1 * EFD, EFM * A \}$$

6) Turbine Characteristic Parameter

(If $P2 \leq 0$ go to 7)

$$CP = RS * \text{SQRT} (P2 * 0.746) / H * 1.25$$

If $CP > 100$ write DIAGNOSTIC

If $M > MM$ write DIAGNOSTIC

7) Compute Statistics and Costs

CHT

SUBROUTINE HT(CC,EFF,P,EF2,MP2,CP,CPU,CPL,PU,M,H,EFD,MD,MM,
1 ,EF1,MP1,CK,FO,RS,X)

PURPOSE PERFORMANCE OF A HYDRAULIC TURBINE

METHOD OFF DESIGN PERFORMANCE IS ASSUMED PROPORTIONAL TO
MASS FLOW RATE

WRITTEN BY F. G. MAHONY

VERSION 1, MARCH 30 1977

CALL SEQUENCE

OUTPUTS

CC - TURBINE COST/YEAR, \$
EFF - TURBINE EFFICIENCY
P - OUTPUT POWER, KW
EF2 - OUTPUT PRODUCT EFFICIENCY
MP2 - OUTPUT MAXIMUM DISCHARGE RATE, KW
CP - TURBINE CHARACTERISTIC PARAMETER
CPU - MAXIMUM CP
CPL - MINIMUM CP
PU - MAXIMUM OUTPUT POWER, KW

INPUTS

M - INLET MASS FLOW RATE, GAL/HR
H - HEIGHT OF RESERVOIR ABOVE TURBINE INLET, FT
EFD - DESIGN POINT TURBINE EFFICIENCY
MD - DESIGN POINT MASS FLOW RATE, GAL/HR
MM - MAXIMUM MASS FLOW RATE, GAL/HR
EF1 - INPUT PRODUCT EFFICIENCY
MP1 - INPUT MAXIMUM DISCHARGE RATE
CK - TURBINE CAPACITY COST COEFFICIENT
FO - TURBINE EXPONENT FOR COST CALCULATIONS
RS - ANGULAR VELOCITY, RPM
X - TURBINE HEAD EXPONENT FOR COST CALCULATIONS

COMMON/CIMPL/IMPL,ICNT/CTIME/TIME /CSIMUL/DUM(7),TMAX /COST/ CCI
REAL MP2,M,MD,MM,MP1

IF(IMPL.GT.0)GO TO 100

TMAX1=TMAX*0.99999

RS =3600.0

IF(EFD.EQ. .99999)EFD=0.9

IF(MD .EQ. .99999)MD =2.0E5

IF(MM .EQ. .99999)MM =3.0E5

IF(CK .EQ. .99999)CK =0.011

IF(FO .EQ. .99999)FO =0.5

IF(X .EQ. .99999)X =0.25

CPL=1.0E10

CPU=0.0

PU =0.0

C1 = 3.1441E-6


CC =CK*(MD*481.2)**FO*M**X

```

C
C      EFFICIENCY
100 EFF =1.0
C
C      IF(M.LE.0.0)GO TO 400
C
C      EFF=1.0-(1.0-EFD)*MD/M
C      IF(EFF.LT.0.6) EFF=0.6
C
C      OUTPUT POWER
400 P  =EFF*M*H*C1
C
C      PRODUCT EFFICIENCY
C
C      EF2=EF1*EFF
C
C      MAXIMUM DISCHARGE RATE
C
C      EFM =MM*.9999-(1.0-EFD)*MD
C
C      MP2=AMIN1(MP1*EFD,EFM*H*C1)
C
C      TURBINE CHARACTERISTIC PARAMETER
C
C      IF(P .LE. 0.0) GO TO 300
C      CP =RS*SQRT(P*0.746)/H**1.25
C
C      IF(CP.LT.100.0)GO TO 200
C
C      IF(IMPL.EQ.2)WRITE(6,1010)CP
C      IF(IMPL.EQ.2) ICNT=ICNT+1
C
C      200 IF(M.LT.MM)GO TO 300
C
C      IF(IMPL.EQ.2)WRITE(6,1020)M,MM
C      IF(IMPL.EQ.2) ICNT=ICNT+1
C
C      300 IF(IMPL.LE.1)RETURN
C
C      STATISTICS
C
C      CPU=AMAX1(CPU,CP)
C      CPL=AMIN1(CPL,CP)
C      PU =AMAX1(PU ,P )
C
C      IF(TIME.LT.TMAX1)RETURN
C
C      COST
C
C      CCI=CCI+CC
C
C      RETURN
C
1010 FORMAT(1H0,48HHT TURBINE CHARACTERISTIC PARAMETER OUT OF RANGE,
X F12.3)
1020 FORMAT(1H0,23HHT INLET MASS FLOW RATE,F12.3
1      ,37H      GREATER THAN MAXIMUM DESIGN VALUE,F12.3)
END
BCS 40262-1

```

7.19 ADIABATIC HEAT EXCHANGER



The purpose of the adiabatic heat exchanger is to recover a portion of the heat of compression from the high pressure, high temperature air exiting from the compressor. Figure 7.19-1 shows an adiabatic heat exchanger used in an underground, constant pressure compressed air energy storage system. The adiabatic heat exchanger operates in a manner similar to the high temperature thermal energy storage systems currently conceived for solar thermal power plants¹. In the storage charging mode, high pressure, high temperature air enters the top of the heat exchanger and deposits a portion of its thermal energy in the storage media as either sensible heat or latent heat of fusion. The exiting high pressure air is stored in an appropriate vessel, e.g., underground cavern. In the discharge cycle (HY), high pressure, low temperature air enters the bottom of the heat exchanger, recovers thermal energy from the storage media and exits to the turbine.

The adiabatic heat exchanger model is based on a two cell storage model. Given the stored energy in both cells, a linear temperature profile is computed

¹ BEC/EPRI RP 788-1, "Advanced Thermal Energy Storage Systems," November 1976.




FIGURE 7.19-1 KOUTZ-GLENDENNING ADIABATIC COMPRESSED AIR STORAGE SCHEME (SINGLE-STAGE HEAT-OF-COMPRESSION STORAGE)

for the media mass. Based on a given inlet mass flow rate, the convective film coefficient, unit thermal conductance, and heat exchanger exit temperature are calculated.

The rate of energy deposited (or withdrawn) is calculated and integrated to yield the stored energy state. For a phase change media, the temperature profile is approximated in the following way: Average cell temperatures TS1 and TS2 are determined from the enthalpy diagram (Figure 7.19-2) using average cell entropy EC1/MA and EC2/MA, respectively. Then a linear temperature profile is constructed as shown in Figure 7.19-3.

Basic Equations

$$\dot{EC1} = PX - PY - NU * EC1 - BE * (EC1 - EC2)$$

$$\dot{EC2} = (P2 - PX) - (P0 - PY) - NU * EC2 + BE * (EC1 - EC2)$$

where

EC1, EC2 = storage power in cells 1 and 2, respectively

PX = charging power in cell 1

PY = discharging power in cell 1

P2 - PX = charging power in cell 2

P0 - PY = discharging power in cell 2

NU = storage media leakage constant

BE = storage media mixing constant




FIGURE 7.19-2: ENTHALPY-TEMPERATURE DIAGRAM FOR HX




FIGURE 7.19-3: STORAGE TEMPERATURE VERSUS TUBE LENGTH

Inputs

<u>Parameter/Port</u>		<u>Description</u>	<u>Units</u>
NU		Storage energy loss coefficient (D = 0.002)	(h) ⁻¹
ST		Rated storage time ¹	h
BE		Storage energy mixing coefficient (D = 0.0)	h ⁻¹
T01		Minimum allowable storage temperature (D = 60)	°F
DTD		Media temperature swing ¹ (D = 400)	°F
PD		Rated storage thermal power	kw
TEM		Maximum allowable exit temperature (D = 240)	°F
XD		Design point fraction of molten media mass (D = 0.8)	-
EF	1	Input product efficiency	-
MP	1	Maximum input charging rate	kw
CP1		Storage media heat capacity (D = 2.93X10 ⁻⁴)	kwh/lb °F
H		Storage media heat of fusion ² (D = 0.0219)	kwh/lb
TMT		Storage media melt temperature ² (D = 147)	°F
CPF		Air heat capacity (D = 7.6X10 ⁻⁵)	kwh/lb °F
KF		Air thermal conductivity (D = 1.03X10 ⁻⁴)	kw/ft °F
MU		Air viscosity (D = 0.055)	lb/ft-h
NT		Number of tubes (D = 200)	-
D		Tube diameter (D = 0.03)	ft
L		Tube length (D = 4)	ft
DEL		Tube half spacing (D = 0.085)	ft
K		Storage media thermal conductivity (D = 0.0078)	kw/ft-°F
T	1	Inlet air temperature	°F
M	1	Inlet mass flow rate	lb/h
CM		Storage device yearly maintenance cost (D = 0.6)	\$/kw
CSA		Storage device capacity cost (D = 50)	\$/kw
CSB		Storage device energy cost (D = 15.6)	\$/kwh
LE		Unit life expectancy	years

- D - Default values specified
 1 - Design point conditions
 2 - Used for phase change media, H = 0 for sensible heat

Inputs

<u>Parameter/Port</u>	<u>Description</u>	<u>Units</u>
M 3	Discharge cycle mass flow rate from storage	lb/hr
T 3	Discharge cycle temperature from storage	°F
TA	Ambient temperature	°F
TS0	Storage vessel minimum temperature	°F

Outputs

<u>Variable/Port</u>	<u>Description</u>	<u>Units</u>
EC1	Stored energy (state) for cell 1 (hot side)	kwh
EC2	Stored energy (state) for cell 2 (cold side)	kwh
M 2	Outlet mass flow rate (=M1)	lb/hr
MP 2	Maximum discharge rate	kw
TS1,TS2	Average temperatures for cells 1 and 2	°F
T 2	Air exit temperature	°F
MA	Required storage media mass	lb
CC0	Storage device capital cost/year	\$
HF	Convective heat transfer coefficient	kwh/ft ² -°F
U	Unit thermal conductance	kwh/ft ² -°F
P 2	Charge rate into heat exchanger	kw
E1,E2	Energy stored at start and end of melt	kwh
PM	Maximum allowable charge rate	kw
EF 2	Output product efficiency	-
RT	Thermal resistance	°F/kw
P0	Discharge power taken from heat exchanger	kw
T0	Discharge cycle output temperature	°F
EF0	Discharge cycle efficiency	-

Statistics

TSU	Maximum storage temperature	°F
TSL	Minimum storage temperature	°F
ME	Maximum stored energy	kwh
MT	Maximum exit temperature	°F

The default values assume use of paraffin wax as the phase change storage medium. (In reality, paraffin wax may not be applicable to temperatures as high as 600°F. The selection of a phase change medium involves careful consideration of a number of factors [see Reference 1]). The heat exchanger geometric parameters, i.e., tube number, diameter, etc., and heat exchanger cost estimates are based on the baseline phase change storage device developed in Reference 1, but scaled down to reflect expected mass flow rates and required media mass. Although these data were developed for a different application (50 MWe, 6 hour storage, average temperature = 786°C), they can be considered representative until detail design data is available.

-
1. "Advanced Thermal Energy Storage," BEC/EPRI RP 788-1, July 1976.

Calculation Sequence

1) Initial Calculations

$$MA = \frac{PD \cdot ST \cdot 0.5}{XD \cdot H + CP1 \cdot DTD}$$

$$CC0 = (CSA + CSB \cdot ST) \cdot PD / LE$$

$$E1 = MA \cdot CP1 \cdot (TMT - T01)$$

$$E2 = MA \cdot [H + CP1 \cdot (TMT - T01)]$$

$$T3 = TS0 = TA$$

$$A = (D \cdot DEL + DEL \cdot D^2) / 5$$

$$RB(1) = D/2, RB(I+1) = \sqrt{RB(I)^2 + A} \quad I=1,5$$

$$RN(I) = \sqrt{(RB(I+1))^2 + RB(I)^2} / 2$$

$$RT = \frac{D}{2 \cdot k} \sum_{i=1}^4 \ln \left(\frac{RN(I+1)}{RN(I)} \right)$$

2) Storage Temperature (see Figure 7.19-2)

$$TS = \begin{cases} T01 + \frac{E}{MA \cdot CP1} & \text{if } E < E_1 \\ TMT & \text{if } E_1 \leq E \leq E_2 \\ T01 + \frac{\left(\frac{E}{MA} - H \right)}{CP1} & \text{if } E > E_2 \end{cases}$$

where $TS = TS1$ and $E = EC1$ for storage cell 1 and similarly for cell 2.

3) HX Exit Temperature Calculations

$$M2 = M1$$

$$P2 = 0$$

$$PX = 0$$

3) Cont.

$$T2 = TS2 - (TS1 - TS2)/2$$

$$\Delta T = TS1 - TS2$$

If $M1 = 0$, GO TO 7)

4) Convective Heat Transfer Coefficient¹

$$HF = \frac{KF}{D} \left[0.0215 * \left(\frac{M1}{NT} * \frac{4}{MU * PI * D} \right)^{0.8} * \left(\frac{CPF * MU}{KF} \right)^{0.6} \right]$$

5) Thermal Conductance

$$U = \left\{ \frac{1}{HF} + RT \right\}^{-1}$$

$$UA = U * PI * D * L * NT / (CPF * M1 * 2)$$

6) Exit Temperature and Charge Rate (See Equation A2. in HX Appendix)

$$TX = T1 - \Delta T - (1. - \exp(-UA)) * (T1 - TS1 - \Delta T/2 - \Delta T/UA)$$

$$T2 = TX - \Delta T - (1. - \exp(-UA)) * (TX - (TS1 + TS2)/2 - \Delta T/UA)$$

$$P2 = M1 * CPF * (T1 - T2)$$

$$PX = M1 * CPF * (T1 - TX)$$

7) HY Exit Temperature Calculations

$$T0 = TS1 + \Delta T/2$$

$$P0 = 0.$$

$$PY = 0.$$

If $M3 = 0$ GO TO 11)

¹ Kays, W. M., Convective Heat and Mass Transfer, McGraw Hill, N.Y., 1966, p. 173.

8) Convective Heat Transfer Coefficient

$$HF\theta = \frac{KF}{D} \left(.0215 * \left(\frac{M3}{NT} * \frac{4}{MU * PI * D} \right)^{0.8} * \left(\frac{CPF * MU}{KF} \right)^{0.6} \right)$$

9) Thermal Conductance

$$U\theta = \left(\frac{1}{HF\theta} + RT \right)^{-1}$$

$$UA = U\theta * PI * D * L * NT / (CPF * M3 * 2)$$

10) Exit Temperature and Discharge Rate (See Equation A3. in HX Appendix)

$$TY = T3 + \Delta T - (1. - EXP(-UA)) * (T3 - TS2 + \Delta T / 2 + \Delta T / UA)$$

$$T\theta = TY + \Delta T - (1. - EXP(-UA)) * (TY - (TS1 + TS2) / 2 + \Delta T / UA)$$

$$P\theta = M3 * CPF * (T\theta - T3)$$

$$PY = M3 * CPF * (T\theta - TY)$$

11) Energy Deposited

$$\dot{EC1} = PX - NU * EC1 - PY - BE * (EC1 - EC2)$$

$$\dot{EC2} = (P2 - PX) - NU * EC2 - (P\theta - PY) + BE * (EC1 - EC2)$$

If $T2 \geq TEM$, WRITE DIAGNOSTIC

12) Maximum Allowable Mass Flow Rate

$$MDM = PD / (CPF * DTD)$$

13) Maximum Allowable Charge Rate

$$PM = MDM * CPF * (T1 - TA)$$

14) Charging and Discharging Efficiency

$$EFF = 1$$

$$\text{If } T2 > TS0 \quad EFF = \frac{T2 - TS0}{T1 - TA}$$

$$EF0 = 1$$

$$\text{If } T3 > TS0 \quad EF0 = \frac{T0 - TA}{T3 - TS0}$$

$$MP2 = \text{MIN} (MP1, PM) * EFF$$


$$EF2 = EF1 * EFF$$

15) Compute Statistics and Cost Summation

HX Appendix: Temperature Equations for a Media with Constant Gradient

Assumptions

1) Constant Gradient Media Temperature:



2) Working Fluid Differential Equation:

$$A1. \quad \frac{\partial T_f}{\partial X} = \frac{UA}{L} (TS - T_f) \quad 0 < x < L$$

Main Results: Exit temperature in the charging and discharging cycles are given by

$$A2. \quad T_f(L) = T_f(0) + \Delta TS - (1 - \exp(-UA)) * \left(T_f(0) - TS0 + \frac{\Delta TS}{UA} \right)$$

$$A3. \quad T_f(0) = T_f(L) - \Delta TS - (1 - \exp(-UA)) * \left(T_f(L) - TSL - \frac{\Delta TS}{US} \right)$$

where $\Delta TS = TSL - TS0$.

Proof: Multiplying A1. by $\exp(UA \cdot X/L)$ and recombining terms yields:

$$A4. \quad \frac{\partial}{\partial X} \left(\exp(UA \cdot X/L) * T_f \right) = \frac{UA}{L} * \exp(UA \cdot X/L) * TS(X).$$

Integrating A4. and substituting $TS(X) = TS0 + \frac{\Delta TS}{L} * X$ yields

$$\begin{aligned}
 \text{A5. } T_f(X) &= \exp(-UA*X/L)*T_f(0) + \frac{UA}{L} \int_0^X \exp(-UA(x-y)/L)*TS(y)dy \\
 &= \exp(-UA*X/L)T_f(0) + (1-\exp(-UA*X/L))*(TS_0 - \Delta TS/UA) \\
 &\quad + \frac{\Delta TS}{L} * X
 \end{aligned}$$

Recombining terms in A5. and letting $X=L$ yields A2. Equation A3. follows from A2. by symmetry, i.e., substitute in A2:

$T_f(0)$ for $T_f(L)$

$T_f(L)$ for $T_f(0)$

TS_L for TS_0

TS_0 for TS_L .

CHX

SUBROUTINE HX(EC1,DE1,IE1,EC2,DE2,IE2,M2,MP2,TS1,TS2,T2,MA,
 1CC,HF,U,P,E1,E2,PM,EF2,PO,TO,EFO,R,TSU,TSL,ME,MT,NU,ST,BE,TO1,DTD
 2 ,PD,TEM,XD,EF1,MP1,CP1,H,TMT,CPF,KF,MU,NT,D,L,DEL,K,T1
 3 ,M1,CM,CSA,CSB,LE,M3,T3,TA,TSO)

PURPOSE PERFORMANCE OF ADIABATIC HEAT EXCHANGER DURING CHARGE
 CYCLE

METHOD HEAT STORAGE MEDIA ASSUMED TO CONTAIN NO TEMPERATURE
 GRADIENTS. ENERGY DEPOSITED IS A FUNCTION OF TEMPERATURE
 AND THERMAL CONDUCTANCE

WRITTEN BY F. C. MAHONY

VERSION 2, JUNE 1977

CALL SEQUENCE OUTPUTS

EC1 - STORED ENERGY (STATE) FOR STORAGE CELL 1, KWH
 DE1 - ENERGY RATE FOR EC1, KW
 IE1 - STATUS INDICATOR FOR EC1
 EC2 - STORED ENERGY STATE FOR STORAGE CELL 2, KWH
 DE2 - ENERGY RATE FOR EC2, KW
 IE2 - STATUS INDICATOR FOR EC2
 M2 - OUTLET MASS FLOW RATE, LB/HR
 MP2 - MAXIMUM DISCHARGE RATE ALLOWABLE, KW
 TS1 - STORAGE TEMPERATURE IN CELL 1, DEG F
 TS2 - STORAGE TEMPERATURE IN CELL 2, DEG F
 T2 - AIR EXIT TEMPERATURE, DEG F
 MA - REQUIRED STORAGE MEDIA MASS LB
 CC - STORAGE DEVICE CAPITAL COST/YEAR, \$
 HF - CONVECTIVE HEAT TRANSFER COEFFICIENT, KWH/FT2-F
 U - UNIT THERMAL CONDUCTANCE, KWH/FT2-F
 P - CHARGE RATE OF HEAT EXCHANGER
 E1 - ENERGY STORED AT START OF MELT PHASE, KWH
 E2 - ENERGY STORED AT END OF MELT PHASE, KWH
 PM - MAXIMUM ALLOWABLE CHARGE RATE, KW
 EF2 - OUTPUT PRODUCT EFFICIENCY
 PO - DISCHARGE POWER TAKEN FROM HEAT EXCHANGER, KW
 TO - DISCHARGE CYCLE OUTPUT TEMPERATURE, DEG F
 EFO - DISCHARGE CYCLE EFFICIENCY
 R - THERMAL RESISTANCE, DEG F/KW

STATISTICS

TSU - MAXIMUM STORAGE TEMPERATURE, DEG F
 TSL - MINIMUM STORAGE TEMPERATURE, DEG F
 ME - MAXIMUM STORED ENERGY, KWH
 MT - MAXIMUM EXIT TEMPERATURE, DEG F

INPUTS

NU - STORAGE ENERGY LOSS COEFFICIENT
 ST - RATED STORAGE TIME, HR
 BE - STORAGE ENERGY MIXING COEFFICIENT, 1/HR
 TO1 - MINIMUM ALLOWABLE STORAGE TEMPERATURE, DEG F
 DTD - MEDIA TEMPERATURE SWING, DEG F
 PD - RATED THERMAL STORAGE POWER, KW

TEM - MAXIMUM ALLOWABLE EXIT TEMPERATURE, DEG F
 XD - DESIGN POINT FRACTION OF MOLTEN MEDIA MASS
 EF1 - INPUT PRODUCT EFFICIENCY
 MP1 - MAXIMUM INPUT CHARGING RATE
 CP1 - STORAGE MEDIA HEAT CAPACITY, KWH/LB-F
 H - STORAGE MEDIA HEAT OF FUSION, KWH/LB
 TMT - STORAGE MEDIA MELT TEMPERATURE, DEG F
 CPF - AIR HEAT CAPACITY, KWH/LB-F
 KF - AIR THERMAL CONDUCTIVITY, KWH/FT-F
 MU - AIR VISCOSITY, LB/FT-HR
 NT - NUMBER OF H/X TUBES
 D - TUBE DIAMETER, FT
 L - TUBE LENGTH, FT
 DEL - TUBE HALF SPACING, FT
 K - STORAGE MEDIA THERMAL CONDUCTIVITY
 T1 - INLET AIR TEMPERATURE, DEG F
 M1 - INLET MASS FLOW RATE, LB/HR
 CM - STORAGE DEVICE YEARLY MAINTENANCE COST \$/KW
 CSA - STORAGE DEVICE CAPACITY COST, \$/KW
 CSB - STORAGE DEVICE ENERGY COST, \$/KWH
 LE - UNIT LIFE EXPECTANCY, YEARS
 M3 - DISCHARGE CYCLE MASS FLOW RATE FROM CS, LB/HR
 T3 - DISCHARGE CYCLE TEMPERATURE FROM CS, DEG F
 TA - AMBIENT TEMPERATURE, DEG F
 TSD - STORAGE VESSEL MINIMUM TEMPERATURE FROM CS, DEG F

COMMON /CIMPL/IMPL,ICNT/CTIME/TIME /CSIMUL/DUM(7),TMAX
 COMMON /COST/ CCI,CMI
 REAL M3,NU,M2,MP2,MA,ME,MT,MP1,MU,NT,M1,LE,KF,K,L,MDM
 DIMENSION RB(6),RW(5)
 DATA PI/3.14159/

IF(IMPL.GT.0)GO TO 100

IF(NU .EQ. .99999)NU =0.002
 IF(BE .EQ. .99999)BE = 0.0
 IF(TO1.EQ. .99999)TO1=60.0
 IF(DTD.EQ. .99999)DTD=400.0
 IF(TEM.EQ. .99999)TEM=240.0
 IF(CP1.EQ. .99999)CP1=2.93E-4
 IF(H .EQ. .99999)H =2.168E-2
 IF(XD .EQ. .99999)XD =0.8
 IF(TMT.EQ. .99999)TMT=147.0
 IF(CPF.EQ. .99999)CPF=7.6E-5
 IF(KF .EQ. .99999)KF =1.03E-4
 IF(MU .EQ. .99999)MU =0.055
 IF(NT .EQ. .99999)NT =200.0
 IF(D .EQ. .99999)D =3.0E-2
 IF(L .EQ. .99999)L =4.0
 IF(DEL.EQ. .99999)DEL=8.5E-2
 IF(K .EQ. .99999)K =7.6E-3
 IF(CM .EQ. .99999)CM =0.6
 IF(CSA.EQ. .99999)CSA=50.0
 IF(CSB.EQ. .99999)CSB=15.6

TSL=1.0E8
 PO=0.0
 PM= 0.0

```

TSU=0.0
ME=0.0
MT=0.0
M3=0.0
T3=TA
TSO=TA
MA =PD*0.5*ST/(XD*H+CP1*DTD)
CC = (CSA+CSB*ST)*PD/LE
CM= CM*PD
E1 =MA*CP1*(TMT-T01)
E2 =MA*(H+CP1*(TMT-T01))
TMAX1=TMAX*0.99999
A  =(D*DEL+DEL**2)/5.0

```

``` COMPUTE THERMAL RESISTANCE OF MEDIA ```

```

RB(1)=D/2.0
DO 20 I=1,5
RB(I+1)=SQRT(RB(I)**2+A)
20 RN(I)=SQRT((RB(I+1)**2+RB(I)**2)/2.0)
R=0.0
DO 30 I=1,4
30 R=R+ALOG(RN(I+1)/RN(I))
R=R*D/2.0/K

```

``` STORAGE TEMPERATURES ```

```

100 TS1=TMT
IF(EC1.LT.E1) TS1= T01+ EC1/(MA*CP1)
IF(EC1.GT.E2) TS1= T01+ (EC1/MA - H)/CP1
TS2=TMT
IF(EC2.LT.E1) TS2= T01+ EC2/(MA*CP1)
IF(EC2.GT.E2) TS2= T01+ (EC2/MA - H)/CP1

```

```

DELT= TS1 - TS2
TSH= TS1+ .5*DELT
TSC= TS2 - .5*DELT

```

```

T2= TSC
M2=M1
P =0.0
PX=0.0
U=1.0/R

```

```

IF(M1.LE..001)GO TO 200

```

``` CONVECTIVE HEAT TRANSFER COEFFICIENT ```

```

HF =KF/D*(0.0215*(M1/NT*4.0/MU/PI/D)**0.8*(CPF*MU/KF)**0.6)

```

``` UNIT THERMAL CONDUCTANCE ```

U = 1.0/(1.0/HF+R)
 UA= U*PI*D*L*NT/(M1*CPF*2.)
 TEMP= DELT/UA
 UA= 1. - EXP(-UA)

EXIT TEMPERATURE

TX= T1 - DELT - UA*(T1-TSH-TEMP)
 T2= TX- DELT - UA*(TX-(TS1+TS2)*.5-TEMP)

CHARGE RATE

P =M1*CPF*(T1-T2)
 PX = M1*CPF*(T1-TX)

HY EXIT TEMPERATURE CALCULATIONS

200 TO = TSH
 PO =0.0
 PY=0.0
 IF(M3.EQ.0.0)GO TO 300

CONVECTIVE HEAT TRANSFER COEFFICIENT

HFO =KF/D*(0.0215*(M3/NT*4.0/MU/PI/D)**0.8*(CPF*MU/KF)**0.6)

UNIT THERMAL CONDUCTANCE

UO=1.0/(1.0/HFO+R)
 UA= UO*PI*D*L*NT/(M3*CPF*2.)
 TEMP= DELT/UA
 UA= EXP(-UA) - 1.

EXIT TEMPERATURE AND DISCHARGE RATE

TY= T3+ DELT+ UA*(T3-TSC+TEMP)
 TO= TY+ DELT + UA*(TY-(TS1+TS2)*.5+TEMP)
 PO =M3*CPF*(TO-T3)
 PY= M3*CPF*(TO-TY)

ENERGY DEPOSITED

300 IF(IE1.NE.0) DE1= PX- PY -NU*EC1 -BE*(EC1-EC2)
 IF(IE2.NE.0) DE2= P-PX - (PO-PY) -NU*EC2 +BE*(EC1-EC2)

IF (T2.LT.TEM) GO TO 500

IF(IMPL.EQ.2)WRITE(6,1010)T2,TEM
 IF(IMPL.EQ.2)ICNT=ICNT+1

MAXIMUM ALLOWABLE CHARGE AND FLOW RATES

500 MDM= PD/(CPF*DTD)
 PM =MDM*CPF*(T1-TA)


CHARGING AND DISCHARGING EFFICIENCY

```

C      EFF=1.0
C      IF(T2.GE.TSO)EFF=(T2-TSO)/(T1-TA)
C      EFO =1.0
C      IF(T3.GT.TSO)EFO=(T3-TSO)/(T3-TA)
C      MP2=AMIN1(MP1,PM)*EFF
C      EF2=EF1*EFF
C
C      STATISTICS
C
C      IF(IMPL.LE.1)RETURN
C      TSU =AMAX1(TSU,TS1)
C      TSL =AMIN1(TSL,TS2)
C      ME = AMAX1(ME, EC1+EC2)
C      MT  =AMAX1(MT ,T2)
C
C      IF(TIME.LT.TMAX1)RETURN
C
C      CCI =CCI+CC
C      CMI=CMI+CM
C      CM= CM/PD
C
C      RETURN
C
1010 FORMAT(1H0,20HX EXIT TEMPERATURE ,F12.3
1      ,35H GREATER THAN MAXIMUM ALLOWABLE ,F12.3)
C
      END

```


7.20 ADIABATIC HEAT EXCHANGER - DISCHARGING CYCLE



HY is the discharge cycle complement to HX. All the calculations to obtain the exit temperature and heat exchange power deposited or withdrawn are done in HX. The results are then passed to HY for summary.

Inputs

<u>Parameter/Port</u>		<u>Description</u>	<u>Units</u>
M	1	Air mass flow rate from storage	lb/hr
T0		Exit temperature from HX	°F
P	1	Discharge power from storage	kw
EF0		Discharge cycle efficiency from HX	-
MP	1	Maximum power from storage	kw

Outputs

<u>Variable/Port</u>			
M	2	Exit air mass flow rate (=M1)	lb/hr
T		Exit temperature (=T0)	°F
P	2	Discharge power	kw
MP	2	Maximum discharge power	kw
EF	2	Output product efficiency	-

Statistics

TL	Minimum exit temperature	°F
TU	Maximum exit temperature	°F
SP	Total energy discharged	kwh

Calculation Sequence

1) $M2 = M1$

$T = T0$

$MP2 = MP1 * EF0$

$EF2 = EF0$

$P2 = P1 * EF0$

2) Compute Statistics

CHY

SUBROUTINE HY(M2,T,P2,MP2,EF2,TL,TU,SP,M1,TO,P1,EFO,MP1)

PURPOSE PERFORMANCE OF ADIABATIC HEAT EXCHANGER DURING DISCHARGE
CYCLEMETHOD COMPUTE EXIT CONDITIONS USING HEAT EXCHANGER STATE
DETERMINED IN HX

WRITEN BY F. O. MAHONY

VERSION 1, MARCH 27 1977

CALL SEQUENCE

OUTPUTS

M2 - EXIT AIR MASS FLOW RATE (=M1), LB/HR
 T - EXIT TEMPERATURE (=TO), DEG F
 P2 - TOTAL DISCHARGE POWER, KW
 MP2 - MAXIMUM DISCHARGE POWER, KW
 EF2 - OUTPUT PRODUCT EFFICIENCY

STATISTICS

TL - MINIMUM EXIT TEMPERATURE, DEG F
 TU - MAXIMUM EXIT TEMPERATURE, DEG F
 SP - TOTAL ENERGY DISCHARGED, KWH

INPUTS

M1 - AIR MASS FLOW RATE FROM STORAGE, LB/HR
 TO - EXIT TEMPERATURE FROM HX, DEG F
 P1 - DISCHARGE POWER FROM STORAGE, KW
 EFO - DISCHARGE CYCLE EFFICIENCY
 MP1 - MAXIMUM POWER FROM STORAGE, KW

COMMON /CIMPL/IMPL /CSIMUL/DUM(6),TINC

REAL M2,MP2,M1,MP1

IF(IMPL.GT.0)GO TO 100

TU =0.0

SP =0.0

TL =1.0E10

100 M2 =M1

T =TO

P2 =P1*EFO

MP2=MP1*EFO

EF2=EFO

IF(IMPL.LE.1)RETURN

TL =AMIN1(TL ,T)


TU =AMAX1(TU ,T)

SP =SP +P2*TINC/2.0

RETURN

END

7.21 INTEGRATOR WITH SATURATION

InputsParameter/PortDescription

FIN	Input
GKI	Integration gain
GKL	Saturation limiter gain
AMA	Upper limit of output (Default = 10^{36})
AMI	Lower limit of output (Default = -10^{36})

OutputsVariable/Port

FO	Output (state)
----	----------------

Calculation Sequence

- $FO = GKI * [FIN - GKL * (FO - AMA)]$ if $FO > AMA$
- $FO = GKI * FIN$ if $AMI \leq FO \leq AMA$
- $FO = GKI * [FIN - GKL * (FO - AMI)]$ if $FO < AMI$

CIT

SUBROUTINE IT(FO,FODOT,IFO,FIN,GKI,GKL,AMA,AMI)
 VERSION 2.
 REVISED: OCT 8 1976

PURPOSE - SIMULATION OF AN INTEGRATOR WITH SATURATION

METHOD - SEE CODING

LIMITATIONS - EXCESSIVELY HIGH VALUES OF GKL MAY RESULT IN POOR
 STEADY STATE CONVERGENCE

WRITTEN BY - ADAM LLOYD

LATEST REVISION - NOV 75

INPUT/OUTPUT LIST


FO	INTEGRATOR OUTPUT	ANY	OUTPUT STATE
FODOT	OUTPUT DERIVATIVE	ANY	OUTPUT DERIV
IFO	INTEGRATOR CONTROL	---	PROGRAM VAR
FIN	FUNCTION INPUT	ANY	INPUT VAR
GKI	INTEGRATOR GAIN	ANY	INPUT PARAM
GKL	DERIVATIVE LIMITER GAIN	ANY	INPUT PARAM
AMA	UPPER LIMIT OF OUTPUT	ANY	INPUT PARAM
AMI	WHERE DERIV. LIMITER STARTS	ANY	INPUT PARAM
	LOWER LIMIT OF OUTPUT		
	WHERE DERIV. LIMITER STARTS		

EPS=FIN

PROVIDE DEFAULTS THAT ELLIMINATE SATURATION

IF(AMA.EQ..99999)AMA=1.E36
 IF(AMI.EQ..99999)AMI=-1.E36
 IF(FO.GT.AMA)EPS = FIN - GKL*(FO-AMA)
 IF(FO.LT.AMI)EPS = FIN - GKL*(FO-AMI)
 IF(IFO.NE.0)FODOT=GKI*EPS
 RETURN
 END

7.22 DC-AC INVERTER



This component models a solid state inverter/transformer. Power losses due to resistive heating and contact potential loss are modeled. A step-up transformer may also be needed to boost output voltage up to that of the bus. Default parameter values are based on rated power = 200 kw.




FIGURE 7.22 INVERTER FUNCTIONAL DIAGRAM

Inputs*

<u>Parameter/Port</u>		<u>Description</u>	<u>Units</u>
P	1	DC input power	kw
RT		Transformer resistance (D = 0)	ohms
VDC		Rated DC voltage (D = 100)	volts
DI		Inverter contact potential (D = 0)	volts
RI		Inverter resistance (D = 0.005)	ohms
RAP		Rated input power	kw
EF	1	Input product efficiency	-
MP	1	Maximum input power	kw
CC		Inverter cost/year	\$

Outputs

<u>Variable/Port</u>			
P	2	AC output power	kw
IDC		DC input current	amps
PL		Power loss	kw
EF	2	Output product efficiency	-
MP	2	Maximum output power	kw

* Minimum inputs to specify IV are:

RI = inverter resistance,

RAP = rated input power.

RI may be used as an adjustment parameter to obtain a specified efficiency at rated power.

D - Default values supplied.

Calculation Sequence

If $P_1 \leq 0$, $P_2 = IDC = PL = 0$, $EFF = 1$ and go to 3)

1) Input and output current

$$IDC = P_1 * 1000 / VDC$$

$$IAC = \sqrt{6} * IDC / \pi$$

2) Power loss and output power

$$PL = (IDC * (DI + RI * IDC) + \sqrt{3} * RT * IAC^2) / 1000$$

$$P_2 = P_1 - PL$$

$$EFF = P_2 / P_1$$

$$P_2 \leq 0 \Rightarrow \text{Diagnostic, } EFF = 1$$

3) Efficiency and maximum power

$$EF2 = EF1 * EFF$$

$$MP2 = \text{MIN}(MP1, RAP) * EFF$$

4) Compute Costs

CIV

SUBROUTINE IV(P2,IDC,PL,EF2,MP2,P1,RT,VDC,DI,RI,RAP,EF1,MP1,CC)

PURPOSE SOLID STATE INVERTER/TRANSFORMER MODEL

METHOD COMPUTE AC POWER AS A FUNCTION OF
INPUT DC POWER

WRITTEN BY Y.K.CHAN VERSION 1, JUNE 2, 1977

CALL SEQUENCE

OUTPUTS

P2 -AC OUTPUT POWER, KW
IDC -DC INPUT CURRENT, AMPS
PL -POWER LOSS, KW
EF2 -OUTPUT POWER EFFICIENCY
MP2 -MAXIMUM OUTPUT POWER, KW

INPUTS

P1 -DC INPUT POWER, KW
RT -TRANSFORMER RESISTANCE, OHMS
VDC -RATED DC VOLTAGE, VOLTS
DI -INVERTER CONTACT POTENTIAL, VOLTS
RI -INVERTER RESISTANCE, OHMS
RAP -RATED OUTPUT POWER, KW
EF1 -INPUT PRODUCT EFFICIENCY
MP1 -MAXIMUM INPUT POWER, KW
CC -INVERTER COST/YEARCOMMON /CIMPL/IMPL,ICNT/CTIME/TIME/CSIMUL/DUM(7),TMAX/COST/CCI
REAL IDC,MP2,MP1,IAC
DATA PI/3.14159/IF(IMPL.GT.0) GO TO 100
IF(RT.EQ..99999)RT=0.
IF(VDC.EQ..99999)VDC=100.
IF(DI.EQ..99999)DI=0.
IF(RI.EQ..99999)RI=.005
TMAXI=TMAX*.99999

COMPUTE INPUT AND OUTPUT CURRENT

100 IF(P1.GT.0.)GO TO 200

P2=0.
IDC=0.
PL=0.
EF2=EF1
MP2=AMIN1(MP1,RAP)
GO TO 400200 IDC=P1*1000./VDC
IAC=SQRT(6.)*IDC/PI

POWER LOSS AND OUTPUT POWER

PL=(IDC*(DI+RI*IDC)+SQRT(3.)*RT*IAC*IAC)/1000.
P2=P1-PL
EFF=P2/P1

EFFICIENCY AND MAXIMUM POWER

C

```
EF2=EF1*EFF  
MP2=AMIN1(MP1,RAP)  
MP2=MP2*EFF  
IF(P2.GT.G.)GO TO 400
```


C

```
EF2=EF1  
MP2=AMIN1(MP1,RAP)  
IF(IMPL.EQ.2)WRITE(6,208)PL,P1  
208 FORMAT(1H0,14HIV POWER LOSS ,F12.3,21H EXCEEDS INPUT POWER ,F12.3,  
128H CHECK RATED DC VOLTAGE VDC )  
IF(IMPL.EQ.2)ICNT=ICNT+1  
P2=0.
```

C

```
400 IF(IMPL.LE.1)RETURN  
IF(TIME.LT.TMAX1)RETURN  
CCI=CCI+CC  
RETURN  
END
```

7.23 FIRST ORDER LAG

InputsParameter/PortDescription

FIN	Input quantity
GAI	Gain
TC	Time constant ¹ (hours)

F0 Output variable (state)

Calculation Sequence

$$\dot{F0} = (GAI * FIN - F0) / TC$$

NOTE: d.c. gain = GAI; time constant = TC

infinite frequency gain = 0

pole location = $\frac{1}{TC}$ rad/sec.

¹ If TC = 0, then F0 = FIN * GAI

CLA

SUBROUTINE LA(FO,FODOT,IFO,FIN,GAI,TC)

PURPOSE - TO SIMULATE FIRST ORDER LAG

$$\frac{FO}{FIN} = \frac{GAI}{(1.+TC*S)}$$

METHOD - SEE CODING

WRITTEN BY - ADAM LLOYD

LATEST REVISION

NOV 75

INPUT/OUTPUT LIST

FO	TRANSFER FUNCTION OUTPUT	ANY	OUTPUT STATE
FODOT	TRANSFER FUNCTION OUTPUT DERIV.	ANY	OUTPUT STATE
IFO	INTEGRATOR CONTROL	---	PROGRAM VAR
FIN	TRANSFER FUNCTION INPUT	ANY	INPUT VAR
GAI	TRANSFER FUNCTION GAIN	---	INPUT PARAM
TC	TIME CONSTANT	SECS	INPUT PARAM

COMMON/CIO/IREAD,IWRITE,IDIAG

IF(TC.NE.0.) GO TO 10

FO= GAI*FIN


RETURN

10 IF(IFO.NE.0) FODOT=(GAI*FIN-FO)/TC

RETURN

END

7.24 LEAD LAG



Inputs

Parameter/Port

Description

FIN	Input quantity
TC1	Numerator time constant (hours)
TC2	Denominator time constant (hours)
GAI	Gain

Outputs

Variable/Port

X1	Intermediate quantity (state)
F0	Output quantity (variable)

Calculation Sequence

$$F0 = (X1 + FIN*TC1*GAI)/TC2$$

$$\dot{X1} = GAI*FIN - F0$$

NOTE: d.c. gain = GAI

$$\text{infinite gain} = \frac{GAI*TC1}{TC2}$$

$$\text{zero location} = - \frac{1}{TC1}, \text{ rad/sec}$$

$$\text{pole location} = - \frac{1}{TC2}, \text{ rad/sec}$$

CLL

SUBROUTINE LL(X1,X1DOT,IX1,FO,FIN,TC1,TC2,GAI)

PURPOSE - TO SIMULATE LEAD LAG TRANSFER FUNCTION

$$\frac{FO}{FIN} = \frac{GAI*(1.+TC1*S)}{(1.+TC2*S)}$$

METHOD - SELF EXPLANATORY

LIMITATIONS - NONE

WRITTEN BY - ADAM LLOYD


LATEST REVISION NOV 75

INPUT/OUTPUT LIST

X1	STATE VARIABLE	ANY	OUTPUT STATE
X1DOT	STATE VARIABLE DERIVATIVE	ANY	OUTPUT STATE
IX1	INTEGRATOR CONTROL	---	PROGRAM VAR
FO	TRANSFER FUNCTION OUTPUT	ANY	OUTPUT VAR
FIN	TRANSFER FUNCTION INPUT	ANY	INPUT VAR
TC1	TIME CONSTANT (NUMERATOR)	SECS	INPUT PARAM
TC2	TIME CONSTANT (DENOMINATOR)	SECS	INPUT PARAM
GAI	TRANSFER FUNCTION GAIN	---	INPUT PARAM

COMMON/CIO/IREAD,IWRITE,IDIAG
 FO=(X1+FIN*TC1*GAI)/TC2
 IF(IX1.NE.0)X1DOT= GAI*FIN-FO
 RETURN
 END

7.25 ELECTRICAL LOAD



This component represents electrical load either by a user-specified data file time history or by a set of random numbers with user-specified daily, weekly, and yearly average profiles and user-specified random variation. It also computes the value of the power delivered to the load by the system. This value delivered is determined from a user-specified value per kwh. This value may be input in tabular form as a function of time of day, time of year, or any other system parameter.

If the user selects to have the electrical load represented by random numbers, then the load (LO2) is generated from the following equation:

Basic Equation

$$LO2 = [PD(TD) + CN(t)] * PW(DW) * PY(WY) * NC$$

where

PD, PW, PY are the daily, weekly, and yearly profiles, respectively, and TD, DW, WY are the time of day, day of the week, and week of the year, respectively. NC is a normalizing constant.

CN is a colored noise term with user-specified correlation time, standard deviation and mean.

<u>Tables</u>		<u>Description</u>	<u>Units</u>
PD		Daily profile (tabular with TD)	kw
PW		Weekly profile (tabular with DW)	arbitrary
PY		Yearly profile (tabular with WY)	arbitrary
<u>Inputs</u>			
<u>Parameter/Port</u>			
P	1	Power delivered	kw
MP	1	Maximum Input Power deliverable ($D = 1 \times 10^{10}$)	kw
NC		Normalizing constant	
VE		Value of Electrical Energy	\$/kwh
LØ	1	Electrical load data file input	kw
TD		Time of day	-
DW		Day of week	-
WY		Week of year	-
CT		Correlation time of random noise	hr
MN,STD		Mean ($D = 0$) and std. deviation of random noise	kw
EF	1	Input Power Efficiency	-
<u>Outputs</u>			
<u>Variable/Port</u>			
RE	1	Power request	kw
VDE		Value of energy delivered (state)	\$
LØ	2	Electrical load	kw
TIM		Last time a random sample was used	hr
CN		Colored noise sample	kw
<u>Statistics</u>			
SRE		Total energy requested	kwh
SDE		Total energy delivered	kwh
PC		Percentage of load met	-

D - Default values supplied

Calculation Sequence

1) Initialize CN(0) (first pass)

2) Check for data file input

 If L01 = .99999 go to 3)

 L02 = L01 and go to 5)

3) Generate colored noise CN

 If TIM = TIME go to 5)

$$A = \begin{cases} \exp(-\Delta/CT), & CT > 0, \Delta = \text{integration step size, hr} \\ 0, & CT = 0 \end{cases}$$

$$CN = A * CN + W,$$

Where W is white noise generated by RN with

$$\text{Mean} = MN * (1-A) \text{ and standard deviation} = STD * \sqrt{1-A^2}$$

4) Compute L02

$$L02 = (PD(TD) + CN) * PW(DW) * PY(WY) * NC$$

$$TIM = TIME$$

5) Power request and value delivered

$$RE = \text{MIN}(MP, L02) / EF1$$

6) Statistics

$$VDE = P1 * VE$$

$$SRE = SRE + L02 * \Delta / 2$$

$$SDE = SDE + P1 * \Delta / 2$$

$$PC = 100. * SDE / SRE$$

CLO

SUBROUTINE LO (PD,PW,PY,VDE,DVD,IVD,RE,LO2,SRE,SDE,PC,TIMO,XN,
1 TD,DW,WY,XNC,CT,XMN,STD,VE,LO1,PMAX,PO,EF)

PURPOSE GENERATE ELECTRICAL LOAD FROM DAILY, WEEKLY, YEARLY AND
RANDOM PROFILE DATA AND EVALUATE PERFORMANCE STATISTICS

METHOD COLORED NOISE IS ADDED TO A MEAN DAILY PROFILE AND MULTIPLIED
BY WEEKLY AND YEARLY WEIGHTING FCNS. POWER REQUESTED IS EITHER
THE GENERATED LOAD OR THE MAX. POWER DELIVERABLE.

WRITTEN BY A.W.WARREN

VERSION 1, MARCH 9 197

CALL SEQUENCE

TABLES

PD - MEAN DAILY PROFILE, KW
PW - MEAN WEEKLY PROFILE, -
PY - MEAN YEARLY PROFILE, -

OUTPUTS

VDE - VALUE OF ENERGY DELIVERED (STATE), \$
DVD - DERIVATIVE OF VDE
IVD - INDICATOR FOR VDE
RE - POWER REQUEST, KW
LO2 - ELECTRICAL LOAD DEMAND, KW
SRE - SUM OF ENERGY DESIRED, KWH
SDE - SUM OF ENERGY DELIVERED, KWH
PC - CUMULATIVE PERCENT OF LOAD DELIVERED, -
TIMO - LAST TIME A RANDOM SAMPLE WAS USED, HR
XN - COLORED NOISE SAMPLE, KW

INPUTS

TD - TIME OF DAY, HR
DW - DAY OF WEEK (1-7)
WY - WEEK OF YEAR (1-52)
XNC - NORMALIZING CONSTANT, -
CT - CORRELATION TIME OF RANDOM NOISE, HR
XMN - MEAN OF RANDOM NOISE, KW
STD - STANDARD DEVIATION OF RANDOM NOISE, KW
VE - VALUE OF ELECTRICAL ENERGY, \$/KWH
LO1 - ELECTRICAL LOAD DATA FILE INPUT, XW
PMAX - MAX. INPUT POWER DELIVERABLE, KW
PO - POWER DELIVERED TO LOAD, KW
EF - INPUT POWER EFFICIENCY

DIMENSION PD(1),PW(1),PY(1)

REAL LO1,LO2

COMMON /CIMPL/ IMPL /CSIMUL/ DUM(6),TINC,TMAX/CTIME/TIME

COMMON /COST/CC,CM,CO,CV,CDE,CRE

DATA AX/.99999/

INITIALIZATION

ND = PD(2)

NW = PW(2)

NY = PY(2)

IF(IMPL.GT.0) GO TO 10

IF(XMN.EQ. .99999)XMN=0.

```

TMAX1 = TMAX*.99999
TIMO=-1.
SRE =0.0
SDE =0.0
PC =0.0
CALL RN(XN,AX,STD,XMN)
IF(PMAX.EQ. .99999) PMAX = 1.E10

```

```

C
C
C      CHECK FOR DATA FILE INPUT

```

```

10 IF(LO1.EQ. .99999) GO TO 100
   LO2 = LO1
   GO TO 150

```

```

C
C
C      GENERATE COLORED NOISE SAMPLE XN

```

```

100 IF( TIMC.EQ.TIME) GO TO 150
   A=0.
   IF(CT.GT.0.) A = EXP(-TINC/CT)
   WMN = XMN*(1.-A)
   WSD = STD*SQRT(1.-A*A)
   CALL RN(W,AX,WSD,WMN)
   XN = XN*A + W

```

```

C
C
C      COMPUTE ELECTRICAL LOAD DEMAND

```

```

   DLO = TBLU1(TD,PD(4),PD(ND+4),1,-ND)
   WLO = TBLU1(DW,PW(4),PW(NW+4),1,-NW)
   YLO = TBLU1(WY,PY(4),PY(NY+4),1,-NY)
   LO2 = (DLO+XN)*WLO * YLO*XNC
   TIMO = TIME
150 RE = AMIN1(PMAX,LO2)/EF

```

```

C
C
C      PERFORMANCE STATISTICS

```

```

   IF(IMPL.LE.1) RETURN
   IF(IVD.NE. 0) DVD = PC*VE
   SRE = SRE + LO2*0.5*TINC
   SDE = SDE + PC*0.5*TINC
   IF(SRE.GT.0.) PC = 100.*SDE/SRE


```

```

C
   IF(TIME.LT.TMAX1) RETURN
   CV = CV + VDE
   CDE= CDE + SDE- PC*0.5*TINC
   CRE= CRE + SRE- LO2*0.5*TINC
   RETURN
   END

```

7.26 MULTIPLY AND ADD



Inputs

Parameter/Port

Description

FIN	Input quantity
C1	Input quantity
C2	Input quantity

Outputs


Variable/Port

F0	Output quantity
----	-----------------

Calculation Sequence

$$F0 = C1 * FIN + C2$$

7.27 MULTIPLY, DIVIDE, AND ADD



Inputs

<u>Parameter/Port</u>	<u>Description</u>
FNA	Input quantity
FNB	Input quantity
C1	Input quantity
C2	Input quantity
C3	Input quantity
C4	Input quantity
C5	Input quantity

Outputs

<u>Variable/Port</u>	
F0	Output quantity

Calculation Sequence

$$F0 = C1 * FNA + C2 * FNB + C3 * FNA * FNB + C4 * FNA / FNB + C5$$

[illegible]


LATEST REVISION MAY 76

INPUT/OUTPUT LIST

FO	OUTPUT VARIABLE	ANY	OUTPUT
FNA	INPUT VARIABLE A	ANY	INPUT
FN8	INPUT VARIABLE B	ANY	INPUT
C1	MULTIPLIER 1	ANY	INPUT
C2	MULTIPLIER 2	ANY	INPUT
C3	MULTIPLIER 3	ANY	INPUT
C4	MULTIPLIER 4	ANY	INPUT
C5	ADDITIVE VARIABLE	ANY	INPUT

END

7.28 MULTIPLY AND ADD



Inputs

<u>Parameter/Port</u>	<u>Description</u>
FIN	Input quantity
FI0	Input quantity
FIP	Input quantity
C1	Input quantity
C2	Input quantity
C3	Input quantity
C4	Input quantity

Outputs

<u>Variable/Port</u>	
F0	Output quantity

Calculation Sequence

$$F0 = C1*FIN + C2*FI0 + C3*FIP + C4$$

CMC

SUBROUTINE MC(FO,FIN,FIO,FIP,C1,C2,C3,C4)

PURPOSE - TO SIMULATE THE EQUATION $FO=C1*FIN+C2*FIO+C3*FIP+C4$

METHOD - SEE CODING

WRITTEN BY - ADAM LLOYD

LATEST REVISION NOV 75

LIMITATIONS - NONE

INPUT/OUTPUT LIST


FO	OUTPUT VARIABLE	ANY	OUTPUT	VAR
FIN	INPUT VARIABLE	ANY	INPUT	VAR
FIO	INPUT VARIABLE	ANY	INPUT	VAR
FIP	INPUT VARIABLE	ANY	INPUT	VAR
C1	CONSTANT MULTIPLIER	---	INPUT	PARAM
C2	CONSTANT MULTIPLIER	---	INPUT	PARAM
C3	CONSTANT MULTIPLIER	---	INPUT	PARAM
C4	CONSTANT ADDITION	---	INPUT	PARAM

$FO=C1*FIN+C2*FIO+C3*FIP+C4$

RETURN

END

7.29 AC INDUCTION MOTOR



The induction motor produces mechanical power and torque proportional to slip speed, i.e. power and torque approach zero as the rotor approaches synchronous speed. Two power losses are modeled: a constant multiplicative term due to resistive heating and an additive term due to mechanical friction. Default parameters are based on a conventional squirrel-cage induction motor/generator machine.

Basic Equations

$$P2 = EE * P1 + DA * RS^2 * C$$

where

$P1, P2$ = input and output power

EE = electrical efficiency

DA = mechanical damping

C = conversion constant

Inputs

<u>Parameter/Port</u>		<u>Description</u>	<u>Units</u>
P	1	Input power	kw
DA		Mechanical damping ($D = 0$)	joule-sec
RS		Rotor speed	rpm
RSY		Synchronous rotor speed ($D = 1800$)	rpm
SR		Stator resistance ($D = 8/RAP$)	ohms
VØ		Rated input voltage ($D = 400$)	volts
RAP		Rated input power	kw
RAS		Rated power slip ($D = 0.05$)	-
EF	1	Input product efficiency	-
MP	1	Maximum input power ($D = 1 \times 10^8$)	kw
CC		Capital cost/year	\$
CM		Maintenance cost/year	\$

Outputs

<u>Variable/Port</u>			
P	2	Output mechanical power	kw
EE		Electrical efficiency	-
TØ		Mechanical torque	ft-lb
PL		Power loss	kw
EF	2	Output product efficiency	-
MP	2	Output maximum power	kw

Statistics

MT		Maximum torque	ft-lb
MPN		Maximum output power/rated power	-
SP		Output energy sum	kwh

D - Default values supplied.

Calculation Sequence

- 1) Compute electrical efficiency (first pass only)

$$I_{RAT} = RAP * 1000 / V_0$$

$$EE = 1 - SR * I_{RAT}^2 / RAP * 1000$$

- 2) Diagnostics

$$P_1 > RAP \Rightarrow \text{DIAGNOSTIC}$$

$$SLIP = 1 - RS / RSY > RAS \Rightarrow \text{DIAGNOSTIC}$$

- 3) Output power and power loss

$$\omega = RS * (2\pi / 60)$$

$$P_2 = EE * P_1 - DA * \omega^2 / 1000$$

$$PL = P_1 - P_2$$

- 4) If $P_2 > 0$ go to 5)

$$P_1 > 0 \Rightarrow \text{DIAGNOSTIC}$$

$$EF2 = EF1, MP2 = \text{MIN}(MP1, RAP)$$

Go to 7)

- 5) Compute torque

$$T_0 = P_2 * 1000 / \omega * k$$

$$k = 1.3558 \text{ joules/ft-lb}$$

Calculation Sequence Cont.

6) Efficiency and maximum output power

$$EF2 = EF1 * (P2/P1)$$

$$MP2 = \text{MIN}(MP1, RAP) * (P2/P1)$$

7) Compute Statistics and Costs

CMO

SUBROUTINE MU(P2,EE,TO,PL,EF2,MP2,MT,MPN,SP,
P1,DA,RS,RSY,SR,VO,RAP,RAS,EF1,MP1,CC,CM)

PURPOSE AC INDUCTION MOTOR MODEL

METHOD MECHANICAL POWER AND TORQUE CALCULATED
FROM INPUT AC POWER AND ROTOR SPEED

WRITTEN BY Y.K.CHAN

VERSION 1, JUNE 13, 1977

CALL SEQUENCE

OUTPUTS

P2 -OUTPUT MECHANICAL POWER,KW
EE -ELECTRICAL EFFICIENCY
TO -MECHANICAL TORQUE,FT-LB
PL -POWER LOSS,KW
EF2 -OUTPUT POWER EFFICIENCY
MP2 -OUTPUT MAXIMUM POWER,KW

STATISTICS

MT -MAXIMUM TORQUE,FT-LB
MPN -MAXIMUM OUTPUT POWER/RATED POWER
SP-OUTPUT POWER SUM

INPUTS

P1 -INPUT POWER,KW
DA -MECHANICAL DAMPING,JOULE-SEC
RS -ROTOR SPEED,RPM
RSY -SYNCHRONOUS ROTOR SPEED,RPM
SR -STATOR RESISTANCE,OHMS
VO -RATED INPUT VOLTAGE,VOLTS
RAP -RATED INPUT POWER,KW
RAS -RATED PWER SLIP
EF1 -INPUT PRODUCT EFFICIENCY
MP1 -MAXIMUM INPUT POWE,KW
CC -CAPITAL COST/YEAR,\$
CM -MAINTENANCE COST/YEAR,\$

COMMON /CIMPL/IMPL,ICWT/CTIME/TIME/CSIMUL/DUM(7),TMAX
X /COST/CCI,CMI,COP,VDE,TDE,TLD,UTV,UTD
REAL MP2,MT,MPN,MP1

IF(IMPL.GT.0)GO TO 100
IF(DA.EQ..99999)DA=0.
IF(RSY.EQ..99999)RSY=1800.
IF(SR.EQ..99999)SR=8./RAP
IF(VO.EQ..99999)VO=400.
IF(MP1.EQ..99999)MP1=1.E8
IF(RAS.EQ..99999)RAS=.05
TMAX1=TMAX*.99999
MT=0.
MPN=0.
SP=0.
TINC=DUM(7)*.5

COMPUTE ELECTRICAL EFFICIENCY

EE=1.-SR*RAP*1000./(VO*VO)
100 IF(P1.LE.RAP*1.001)GO TO 200

```

      IF(IMPL.EQ.2)WRITE(6,208)P1,RAP
208  FORMAT(1H0,18H MOTOR INPUT POWER,F12.3,23H .GT.RATED INPUT POWER ,
      1  F12.3)

```

```

      IF(IMPL.EQ.2)ICNT=ICNT+1
200  SLIP=1.-(RS/RSY)
      IF(SLIP.LE.RAS)GO TO 300
      IF(IMPL.EQ.2)WRITE(6,308)SLIP,RAS
308  FORMAT(1H0,11H MOTOR SLIP,F12.3,25H EXCEEDS RATED POWER SLIP,
      1  F12.3)

```

```

      IF(IMPL.EQ.2)ICNT=ICNT+1

```

COMPUTE POWER AND POWER LOSS

```

300  OMEGA=RS*3.14159/30.

```

```

      P2=EE*P1-DA*OMEGA*OMEGA/1000.

```

```

      PL=P1-P2

```

```

      TO=0.

```

```

      IF(P2.GT.0.)GO TO 400

```

```

      IF(P1.LE.0.)GO TO 409

```

```

      IF(IMPL.EQ.2)WRITE(6,408)SR,DA

```

```

408  FORMAT(1H0,19H STATOR RESISTANCE ,F12.3,12H OR DAMPING ,
      XF12.3,20H TOO HIGH FOR MOTOR )
      IF(IMPL.EQ.2)ICNT=ICNT+1

```

EFFICIENCY AND MAXIMUM OUTPUT POWER

```

409  CONTINUE

```

```

      P2=0.

```

```

      EF2=EF1

```

```

      MP2=AMIN1(MP1,RAP)

```

```

      GO TO 500

```

```

400  EF2=EF1*P2/P1

```

```

      MP2=AMIN1(MP1,RAP)*P2/P1

```

```

      IF(RS.NE.0.)TO=P2*737.6/OMEGA

```

```

500  IF(IMPL.LE.1)RETURN

```

STATISTICS

```

      MT=AMAX1(TO,MT)

```

```

      MPN=AMAX1(P2/RAP,MPN)

```

```

      SP=SP+P2*TINC

```

```

      IF(TIME.LT.TMAX1)RETURN

```

```

      CCI=CCI+CC

```

```

      CMI=CMI+CM

```

```

      RETURN


```

```

      END

```

7.30 POWER ACCUMULATOR



This component sums power from four input ports and allocates power requests to each port's source of power generation. An input power request is allocated according to user-supplied weights within the ports of highest priority. If an input power request (load) exceeds the maximum power that can be delivered by the ports of highest priority, then the remaining load is allocated to the next priority ports. (See 1.2.2 and 7c for further discussion.)

Inputs¹

<u>Parameter/Port</u>	<u>Description</u>	<u>Units</u>
RE 0	Load request	kw
EF 1,2,3,4	Input efficiency from port i	-
P 1,2,3,4	Input power from port i (default = 0.)	kw
PS 1,2,3,4	Priority sequence (default = 1,2,3,4)	-
F 1,2,3,4	Allocation weight (for equal priorities)	-
MP 1,2,3,4	Maximum power (default = 0.)	kw

Outputs

Variable/Port


MP 0	Maximum deliverable power ($\sum MP(i)$)	kw
RE 1,2,3,4	Power request for port i	kw
P 0	Power output	kw
SP	Supplemental power request to meet load (Power deficit = $RE_0 - \sum MP_i$)	kw


Statistics

SRE	Sum of energy requested	kwh
PC 1,2,3,4	Percent of cumulative load request delivered by port i	%

¹ No capital costs assigned since this is an allocation component, not a physical device.

CALCULATION LOGIC





CPA

```

SUBROUTINE PA(MPO,
1      R1, R2, R3, R4,
2      PO, SP,
3      SR, PC1, PC2, PC3, PC4,
4      RO,
4      EF1, EF2, EF3, EF4,
5      P1, P2, P3, P4,
6      PR1, PR2, PR3, PR4,
7      W1, W2, W3, W4,
8      MP1, MP2, MP3, MP4)

```

PURPOSE. MODEL POWER ACCUMULATOR

METHOD. PRIMARY REQUEST ALLOCATION RESULTING FROM PRIORITY ASSIGNMENTS. SECONDARY REQUEST ALLOCATION RESULTING FROM WEIGHT ASSIGNMENTS.

THAT IS, REQUESTS ARE ALLOCATED ACCORDING TO:

- * PORT PRIORITY (HIGHEST PRIORITY = 1)
- * PORT WEIGHTS (IN CASE OF EQUAL PRIORTIES.)

FORMAL ARGUMENT DEFINITION.

R1, ..., R4 :	POWER REQUESTS IN KW	(OUTPUTS)
MPO :	TOTAL MAXIMUM POWER	(OUTPUT)
SP :	SURPLUS REQUEST	(OUTPUT)
PO :	TOTAL LOAD IN KW	(OUTPUT)
SR :	SUM OF ENERGY REQUESTED, KWH	(OUTPUT)
PC1, ..., PC4 :	PERCENT OF CUM LOAD DELIVERED	(OUTPUT)
RO :	TOTAL POWER REQUESTED, KW	(INPUT)
P1, ..., P4 :	INPUT POWER IN KW	(INPUTS)
PR1, ..., PR4 :	PORT PRIORITIES	(INPUTS)
W1, ..., W4 :	PORT WEIGHTS	(INPUTS)
MP1, ..., MP4 :	MAXIMUM POWERS	(INPUTS)
EF1, ..., EF4 :	EFFICIENCIES	(INPUTS)

COMMON STORAGE

COMMON/ CIMPL / IMPL

COMMON / CSIMUL / DUM(6), TINC, TMAX

REAL MPO, MP1, MP2, MP3, MP4

LOCAL VARIABLES

R(K) IS THE POWER REQUEST AT PORT K
REAL R(4)

PR(K) IS THE PRIORITY ASSIGNED TO PORT K
REAL PR(4)

W(K) IS THE WEIGHT ASSIGNED TO PORT K
REAL W(4)

MP(K) IS MAXIMUM POWER TO BE ALLOCATED TO PORT K
REAL MP(4)

SW(I) IS THE SUM OF THE WEIGHTS ASSIGNED TO PRIORITY-I PORTS
REAL SW(4)

SMP(I) IS THE SUM OF THE MAXIMUM POWER AT PRIORITY-I PORTS

REAL SMP(4)

FRU IS FAIR SHARE UNIT FOR PRIORITY-1 PORTS

FR(K) IS THE COMPUTED FAIR SHARE REQUEST FOR PORT K
REAL FR(4)

LL IS THE LOAD LEFT AT EACH POINT IN THE ITERATION
REAL LL,LOLD

IF IMPL IS ZERO, THEN ASSIGN DEFAULT VALUES

IF (IMPL .GT. 0) GO TO 40

RO = 0.0

IF (PR1 .EQ. 0.99999) PR1 = 1.0

IF (PR2 .EQ. 0.99999) PR2 = 2.0

IF (PR3 .EQ. 0.99999) PR3 = 3.0

IF (PR4 .EQ. 0.99999) PR4 = 4.0

IF (MP1 .EQ. 0.99999) MP1 = 0

IF (MP2 .EQ. 0.99999) MP2 = 0

IF (MP3 .EQ. 0.99999) MP3 = 0

IF (MP4 .EQ. 0.99999) MP4 = 0

IF (P1 .EQ. .99999) P1=0.0

IF (P2 .EQ. .99999) P2=0.0

IF (P3 .EQ. .99999) P3= 0.0

IF (P4 .EQ. .99999) P4=0.0

SR=0.

PC1=0.

PC2=0.

PC3=0.

PC4=0.

TINC1= 0.5*TINC

40 CONTINUE

IF THE TOTAL MAXIMUM POWER IS .LE. TOTAL POWER
REQUESTED, THEN SUBMIT REQUESTS AT MAX-POWER, SET REQUEST
SURPLUS EQUAL TO THE DIFFERENCE, AND RETURN

PO = P1 + P2 + P3 + P4

IF (PR1.LE.0.0) MP1=0.

IF (PR2.LE.0.0) MP2=0.

IF (PR3.LE.0.0) MP3=0.

IF (PR4.LE.0.0) MP4=0.

MPO = MP1 + MP2 + MP3 + MP4

IF (MPO .GT. RO) GO TO 80

R1 = MP1/EF1

R2 = MP2/EF2

R3 = MP3/EF3

R4 = MP4/EF4

SP = RO - MPO

GO TO 500

80 CONTINUE

PROCEED WITH ALLOCATION ALGORITHM SINCE THE SUM OF
ALL MAXIMUM POWER INPUTS EXCEEDS THE TOTAL REQUEST RO

INITIALIZATION

LL = RO

R1 = 0.0

R2 = 0.0

R3 = 0.0
 R4 = 0.0
 SP = 0.0

C
 C

IF THE TOTAL REQUEST (OR LOAD) IS ZERO, THEN RETURN
 IF (RO .LE. 0.0) GO TO 500

R(1)=R1
 R(2)=R2
 R(3)=R3
 R(4)=R4
 PR(1) = PR1
 PR(2) = PR2
 PR(3) = PR3
 PR(4) = PR4
 W(1) = W1
 W(2) = W2
 W(3) = W3
 W(4) = W4
 MP(1) = MP1
 MP(2) = MP2
 MP(3) = MP3
 MP(4) = MP4

C
 C
 C
 C

ITERATE ON PRIORITY I FOR I = 1, 2, 3, 4

DO 1000 I = 1, 4

C

XI = I

C

OBTAIN SUM OF MAXIMUM POWER FOR PORTS WITH PRIORITY I
 SMP(I) = 0.0

DO 100 K = 1, 4

IF (PR(K) .EQ. XI) SMP(I) = SMP(I) + MP(K)

100 CONTINUE

C

IF NO PRIORITY-I MAXIMUM POWER EXISTS, THEN PROCEED WITH
 THE NEXT HIGHER PRIORITY

IF (SMP(I) .EQ. 0.0) GO TO 1000

C

IF THE SUM OF ALL PRIORITY-I MAXIMUM POWER .GT. LOAD
 LEFT, THEN GO AROUND

IF (SMP(I) .GT. LL) GO TO 400

C

THE SUM OF ALL PRIORITY-I MAXIMUM POWER .LE. LOAD
 LEFT, SO SUBMIT EACH PRIORITY-I REQUEST

DO 200 K = 1, 4

IF (PR(K) .EQ. XI) R(K) = MP(K)

200 CONTINUE

C

UPDATE LOAD LEFT

LL = LL - SMP(I)

C

IF THE REMAINING LOAD IS ZERO, THEN EXIT THE ITERATION
 IF (LL .LE. 0.0) GO TO 2000

C

OTHERWISE, PROCEED WITH NEXT HIGHER PRIORITY
 GO TO 1000

C

C

C

C

400 CONTINUE

THE SUM OF THE PRIORITY-I MAXIMUM POWER EXCEEDS THE
LOAD LEFT, SO COMPUTE AND SUBMIT FAIR SHARE REQUESTS
TO EACH PRIORITY-I PORT

600 CONTINUE

SAVE LL FOR LATER REFERENCE
LOLD = LL

DETERMINE FAIR SHARE UNITS FOR ALL PRIORITY-I
PORTS TO WHICH NO REQUEST HAS BEEN SUBMITTED

SW(I) = 0.0

DO 700 K = 1, 4

IF (R(K) .NE. 0.0) GO TO 700

IF (PR(K) .EQ. XI) SW(I) = SW(I) + W(K)

700 CONTINUE

FRU = 1.0 / SW(I)

FIRST, SUBMIT FAIR SHARE REQUESTS TO PORTS FOR WHICH THE
FAIR SHARE REQUEST EXCEEDS THE MAXIMUM POWER. CONSIDER ONLY
PORTS TO WHICH NO REQUEST HAS BEEN SUBMITTED

DO 800 K = 1, 4

IF (R(K) .NE. 0.0) GO TO 800

IF (PR(K) .NE. XI) GO TO 800

COMPUTE FAIR SHARE

FR(K) = (W(K) * FRU) * LL

IF FAIR SHARE EXCEEDS MAXIMUM POWER, THEN SUBMIT REQUEST

IF (FR(K) .GE. MP(K)) R(K) = MP(K)

-- AND REDUCE LOAD LEFT TALLY

IF (FR(K) .GE. MP(K)) LL = LL - MP(K)

800 CONTINUE

IF LL .NE. LOLD, THEN LL WAS REDUCED DURING THE
PROCESSING IN THE DO 800 LOOP ABOVE. THIS CHANGES
THE FAIR SHARE COMPUTATION. IT IS THEREFORE
NECESSARY TO GO BACK THROUGH THE DO 800 LOOP IN
ORDER TO RECONSIDER ANY PORT WHICH MAY NOW
SATISFY THE REQUIREMENT THAT FR(K) .GE. MP(K). ONLY
PRIORITY-I PORTS TO WHICH NO REQUEST HAS BEEN
MADE ARE ELIGIBLE FOR RECONSIDERATION
IF (LL .LT. LOLD) GO TO 600

FINALLY, SUBMIT REQUESTS TO THOSE PORTS FOR WHICH THE FAIR SHARE
.LT. THEIR MAXIMUM POWER. CONSIDER ONLY
PRIORITY-I PORTS TO WHICH NO REQUEST HAS BEEN SUBMITTED

DO 900 K = 1, 4

IF (R(K) .NE. 0.0) GO TO 900

IF (PR(K) .NE. XI) GO TO 900

R(K) = FR(K)

900 CONTINUE

LL=0.0

GO TO 2000

1000 CONTINUE

C
2000 CONTINUE

C
C
C FINALLY, ASSIGN OUTPUTS TO NON-SUBSCRIPTED FORMAL PARAMETERS.
C ALSO, MODIFY ALL REQUESTS ACCORDING TO THE INPUT EFFICIENCIES

R1 = R(1) / EF1

R2 = R(2) / EF2

R3 = R(3) / EF3

R4 = R(4) / EF4

SP = LL

500 IF(IMPL.LE.1) RETURN

SRO= SR

SR=SR+ R0*TINC1

IF(SR.LE.0.) RETURN

SRO=SRO/SR

SRI= TINC1*100./SR

PC1= PC1*SRO + P1*SRI

PC2= PC2*SRO + P2*SRI


PC3= PC3*SRO + P3*SRI

PC4= PC4*SRO + P4*SRI

RETURN

END

7.31 POWER DIVIDER



This component allocates power to four ports plus surplus based on priority and allocation weights for equal priority ports. Each port is assigned a priority sequence from 1 to 4, and a weighting $F_i > 0$, $i=1,2,3,4$ for proportional allocation among equal priority ports. If power available exceeds the power requested for the ports of highest priority, then the remaining power is allocated to ports having the next highest priority. If power available is less than the power requested for ports of equal priority, then power is allocated among them in proportion to their respective allocation weights.

The total power request is the sum of the port requests divided by input efficiency. The maximum power outputs MP_1, \dots, MP_4 are necessary for direct

connections to a power accumulator PA. These variables may be used as maximum power inputs to other components, although such connections are not required. (See 1.2.2 and 7c for further discussion.)


<u>Inputs¹</u>			
<u>Parameter/Port</u>		<u>Description</u>	<u>Units</u>
P	0	Input power	kw
RE	1,2,3,4	Power request of output ports	kw
PS	1,2,3,4	Priority sequence (default = 1,2,3,4)	kw
F	1,2,3,4	Allocation weight (for equal priorities)	-
MP		Maximum input power (default = P0)	kw
EF		Input efficiency	-

<u>Outputs</u>			
<u>Variable/Port</u>			
P	1,2,3,4	Output power for port i	kw
RE	0	Output power request	kw
MP	1,2,3,4	Output maximum power based on MP	kw


<u>Statistics</u>			
SP		Surplus power	kw

¹ No capital costs assigned since this is an allocation component, not a physical device.

CALCULATION LOGIC



PD FAIR SHARE ALLOCATION



SUBROUTINE PD(

```

1      P1, P2, P3, P4,
2      R0,
3      SP, PM1, PM2, PM3, PM4,
4      P0,
5      R1, R2, R3, R4,
6      PR1, PR2, PR3, PR4,
7      W1, W2, W3, W4, PM, EF)

```

PURPOSE. MODEL POWER DIVIDER

METHOD. PRIMARY FLOW ALLOCATION RESULTING FROM PRIORITY ASSIGNMENTS. SECONDARY FLOW ALLOCATION RESULTING FROM WEIGHT ASSIGNMENTS.

THAT IS, TOTAL AVAILABLE POWER IS ALLOCATED ACCORDING TO:

- * PORT REQUESTS
- * PORT PRIORITY (HIGHEST PRIORITY = 1)
- * PORT WEIGHTS (IN CASE OF EQUAL PRIORTIES)

ALLOCATION SCHEME.

IS SUM OF ALL REQUESTS .LT. POWER AVAILABLE P0
YES.

FULFILL EACH REQUEST
UPDATE POWER AVAILABLE
EXIT

NO.

IS SUM OF ALL PRIORITY-1 REQUESTS .LT. P0
YES.

FULFILL EACH PRIORITY-1 REQUEST
UPDATE POWER AVAILABLE (TO PL)
GO ON TO PRIORITY-2 REQUESTS

NO.

ALLOCATE FAIR SHARE TO EACH PRIORITY-1 PORT
EXIT.

IS SUM OF ALL PRIORITY-2 REQUESTS .LT. PL

AND SO ON AND SO FORTH

FORMAL ARGUMENT DEFINITION.

P1, ..., P4 :	POWER ALLOCATIONS IN KW	(OUTPUTS)
R0 :	TOTAL POWER REQUESTED	(OUTPUT)
SP :	SURPLUS POWER	(OUTPUT)
PM1, ..., PM4:	PORT MAXIMUM OUTPUT POWER IN KW	(OUTPUT)
P0 :	TOTAL POWER INPUT IN KW	(INPUT)
PM :	MAXIMUM INPUT POWER IN KW	(INPUT)
EF :	INPUT EFFICIENCY	(INPUT)
R1, ..., R4 :	PORT REQUESTS IN KW	(INPUTS)
PR1, ..., PR4 :	PORT PRIORITIES	(INPUTS)
W1, ..., W4 :	PORT WEIGHTS	(INPUTS)

COMMON STORAGE

COMMON/ CIMPL / IMPL

LOCAL VARIABLES

P(K) IS THE POWER ALLOCATED TO PORT K

```

C      REAL P(4)
C      R(K) IS THE POWER REQUEST AT PORT K
C      REAL R(4)
C      PR(K) IS THE PRIORITY ASSIGNED TO PORT K
C      REAL PR(4)
C      W(K) IS THE WEIGHT ASSIGNED TO PORT K
C      REAL W(4)
C      SW(I) IS THE SUM OF THE WEIGHTS ASSIGNED TO PRIORITY-I PORTS
C      REAL SW(4)
C      SR(I) IS THE SUM OF THE REQUESTS AT PRIORITY-I PORTS
C      REAL SR(4)
C      FRU IS FAIR SHARE UNIT FOR PRIORITY-I PORTS
C      FR(K) IS THE COMPUTED FAIR SHARE ALLOCATION TO PORT K
C      REAL FR(4)
C      PL IS THE POWER LEFT AT EACH POINT IN THE ITERATION
C      REAL PL
C      IF IMPL IS ZERO, THEN ASSIGN DEFAULT VALUES
C      IF (IMPL .GT. 0) GO TO 40
C      R1 = 0.0
C      R2 = 0.0
C      R3 = 0.0
C      R4 = 0.0
C      IF (PR1 .EQ. 0.99999) PR1 = 1.0
C      IF (PR2 .EQ. 0.99999) PR2 = 2.0
C      IF (PR3 .EQ. 0.99999) PR3 = 3.0
C      IF (PR4 .EQ. 0.99999) PR4 = 4.0
C
C 40 CONTINUE
C
C      IF THE TOTAL POWER REQUESTED IS .LE. TOTAL POWER
C      INPUT, THEN SATISFY REQUESTS, SET POWER SURPLUS
C      EQUAL TO THE DIFFERENCE,
C      IF (PR1.LE.0.0) R1=0.0
C      IF (PR2.LE.0.0) R2=0.0
C      IF (PR3.LE.0.0) R3=0.0
C      IF (PR4.LE.0.0) R4=0.0
C      R0 = R1 + R2 + R3 + R4
C      IF (R0 .GT. P0) GO TO 80
C      P1 = R1
C      P2 = R2
C      P3 = R3
C      P4 = R4
C      PL = P0 - R0
C      GO TO 60
C 80 CONTINUE
C
C      PROCEED WITH ALLOCATION ALGORITHM SINCE THE SUM OF
C      ALL REQUESTS EXCEEDS THE TOTAL AVAILABLE POWER P0
C

```

C INITIALIZATION

PL = P0
P1 = 0.0
P2 = 0.0
P3 = 0.0
P4 = 0.0

C

60 PMA= PM
IF(PM.EQ. .99999) PMA=P0
P(1) = P1
P(2) = P2
P(3) = P3
P(4) = P4
R(1) = R1
R(2) = R2
R(3) = R3
R(4) = R4
PR(1) = PR1
PR(2) = PR2
PR(3) = PR3
PR(4) = PR4
W(1) = W1
W(2) = W2
W(3) = W3
W(4) = W4

C

C

C

C

ITERATE ON PRIORITY 1 FOR I = 1, 2, 3, 4

C

DO 1000 I = 1, 4

C

XI = I

C

OBTAIN SUM OF REQUESTS FROM PORTS WITH PRIORITY I

SR(I) = 0.0

WT=0.0

DO 100 K = 1, 4

IF (PR(K) .EQ. XI) SR(I) = SR(I) + R(K)

IF (PR(K) .EQ. XI) WT= WT+ W(K)

100 CONTINUE

C

IF (PR1 .EQ. XI) PM1= PMA*W1/WT

IF (PR2 .EQ. XI) PM2= PMA*W2/WT

IF (PR3 .EQ. XI) PM3= PMA*W3/WT

IF (PR4 .EQ. XI) PM4= PMA*W4/WT

PMA= AMAX1(PMA- SR(I),0.)

IF (PL.LE.0.) GO TO 1000

C

C

C

IF NO PRIORITY-I REQUESTS EXIST, THEN PROCEED WITH
THE NEXT HIGHER PRIORITY

IF (SR(I) .EQ. 0.0) GO TO 1000

IF (R0.LE.P0) GO TO 1000

C

C

C

IF THE SUM OF ALL PRIORITY-I REQUESTS .GT. POWER
AVAILABLE, THEN GO AROUND

IF (SR(I) .GT. PL) GO TO 400

C

C

C

THE SUM OF ALL PRIORITY-I REQUESTS .LE. POWER
AVAILABLE, SO FULFILL EACH PRIORITY-I REQUEST

```

DO 200 K = 1, 4
IF (PR(K) .EQ. XI) P(K) = R(K)
200 CONTINUE

```

```

C
C   UPDATE POWER AVAILABLE
C   PL = PL - SR(I)

```

```

C   GO TO 1000

```

```

C
400 CONTINUE

```

```

C   THE SUM OF THE PRIORITY-I REQUESTS EXCEEDS THE
C   POWER AVAILABLE, SO COMPUTE AND ALLOCATE FAIR
C   SHARE TO EACH PRIORITY-I PORT

```

```

C
600 CONTINUE

```

```

C   SAVE PL FOR LATER REFERENCE
C   POLD = PL

```

```

C   DETERMINE FAIR SHARE UNITS FOR ALL PRIORITY-I
C   PORTS FOR WHICH NO ALLOCATION HAS BEEN MADE
C   SW(I) = 0.0

```

```

DO 700 K = 1, 4

```

```

IF (P(K) .NE. 0.0) GO TO 700

```

```

IF (PR(K) .EQ. XI) SW(I) = SW(I) + W(K)

```

```

700 CONTINUE

```

```

FRU = 1.0 / SW(I)

```

```

C
C   FIRST, ALLOCATE FAIR SHARE TO PORTS FOR WHICH THE
C   FAIR SHARE EXCEEDS THE REQUEST. CONSIDER ONLY PRIORITY-I
C   PORTS, AND CONSIDER ONLY PORTS TO WHICH NO ALLOCATION
C   HAS YET BEEN MADE

```

```

DO 800 K = 1, 4

```

```

IF (P(K) .NE. 0.0) GO TO 800

```

```

IF (PR(K) .NE. XI) GO TO 800

```

```

C   COMPUTE FAIR SHARE

```

```

FR(K) = (W(K) * FRU) * PL

```

```

C   IF FAIR SHARE EXCEEDS REQUEST, THEN FULFILL REQUEST
C   IF (FR(K) .GE. R(K)) P(K) = R(K)

```

```

C   -- AND REDUCE AVAILABLE POWER

```

```

IF (FR(K) .GE. R(K)) PL = PL - P(K)

```

```

800 CONTINUE

```

```

C   IF PL .NE. POLD, THEN PL WAS REDUCED DURING THE
C   PROCESSING IN THE DO 800 LOOP ABOVE. THIS CHANGES
C   THE FAIR SHARE COMPUTATION. IT IS THEREFORE
C   NECESSARY TO GO BACK THROUGH THE DO 800 LOOP IN
C   ORDER TO RECONSIDER ANY PORT WHICH MAY NOW
C   SATISFY THE REQUIREMENT THAT FR(K) .GE. R(K). ONLY
C   PRIORITY-I PORTS FOR WHICH NO ALLOCATION HAS BEEN
C   MADE ARE ELIGIBLE FOR RECONSIDERATION
C   IF (PL .NE. POLD) GO TO 600

```

```

C   FINALLY, ALLOCATE POWER TO THOSE PORTS REQUESTING
C   MORE THAN THEIR FAIR SHARE. CONSIDER ONLY


```


C PRIORITY-I PORTS FOR WHICH NO ALLOCATION HAS BEEN MADE
 DO 900 K = 1, 4
 IF (P(K) .NE. 0.0) GO TO 900
 IF (PR(K) .NE. XI) GO TO 900
 P(K) = FR(K)
900 CONTINUE
 PL = 0.0

C
1000 CONTINUE

C
C
C FINALLY, ASSIGN OUTPUTS TO NON-SUBSCRIPTED
C FORMAL PARAMETERS
 P1 = P(1)
 P2 = P(2)
 P3 = P(3)
 P4 = P(4)
 IF(IMPL.GT.1) SP=PL
 RO=AMIN1(RO,PM)/EF
 RETURN
 END

7.32 PRIORITY INTERRUPT



This component is used by the storage components to change priority of the power requests when minimum or maximum capacity is approached.

Inputs

<u>Parameter/Port</u>	<u>Description</u>
PS 1	Input priority for PS2 output (0 to 4)
PS 3	Input priority for PS4 output (default=PS1)
PMX	Maximum priority for PS2 (default = 1)
INT	Interrupt flag (0,-1,1)

Outputs

<u>Variable/Port</u>		
PS	2	Output priority for charge cycle
PS	4	Output priority for discharge cycle

Equations

PS2 = PS1	if INT=0
PS2 = PMX	if INT > 0
PS2 = 0	if INT < 0
PS4 = PS3	if INT ≤ 0
PS4 = 0	if INT > 0

CPI

SUBROUTINE PI(PS2,PS4,PS1,PS3,PMX,INT)

PURPOSE CHANGE PRIORITY OF POWER ALLOCATION TO STORAGE COMPONENTS

WRITTEN BY A.W.WARREN

VERSION 1, APRIL 14 1971

CALL SEQUENCE

PS2 - OUTPUT PRIORITY (0 TO 4)
 PS4 - OUTPUT PRIORITY (COMPLEMENT TO PS2)
 PS1 - INPUT PRIORITY FOR PS2
 PS3 - INPUT PRIORITY FOR PS4
 PMX - MAXIMUM PRIORITY FOR PS2
 INT - INTERRUPT FLAG
 0= NO INTERRUPT
 1= INCREASE ALLOCATION PRIORITY
 -1= DECREASE ALLOCATION PRIORITY

REAL INT

COMMON /CIMPL/IMPL

IF(IMPL.GT.0) GO TO 10

IF(PS3.EQ..99999) PS3=PS1

IF(PMX.EQ..99999)PMX=1.

10 PS2=PS1

PS4=PS3

IF(INT.GT.0.) PS2=PMX


IF(INT.LT.0.) PS2=0.

IF(INT.GT.0) PS4= 0.

RETURN

END

7.33 HYDRAULIC PUMP



The hydraulic pump model is based on a constant speed design. The pump is assumed to be designed to a nominal operating point and input power. For off-design performance the pump efficiency is assumed to be functionally related to the square root of the mass flow rate.

Basic Equations

The output mass flow rate is based on the equations

$$M = P1 * EFF / (C1 * C2 * H1)$$

$$EFF = 1 - (1 - EFD) * SQRT(MD / M)$$

where C1, C2 are conversion constants

Inputs

<u>Parameter/Port</u>		<u>Description</u>	<u>Units</u>
P	1	Input power	kw
H	1	Height of water above inlet	ft
EFD		Pump efficiency at design pt. (D = 0.90)	-
MD		Mass flow rate at design pt. (D = 2×10^5)	gal/h
EF	1	Input product efficiency	-
MP	1	Input maximum charging rate	kw
MM		Maximum allowable mass flow rate (D = 3×10^5)	gal/h
CK		Pump capacity cost coefficient ¹ (D = 0.011)	
FO		Pump exponent for cost calculations (D = 0.5)	-
Y		Pumphead exponent for cost calculations (D=0.25)	-

Outputs

<u>Variable/Port</u>			
M		Output mass flow rate	gal/h
EFF		Pump efficiency	-
CC0		Pump cost/year	\$
EF	2	Output product efficiency	-
MP	2	Maximum output power	kw

Statistics

M2U	Maximum output mass flow rate	gal/h
-----	-------------------------------	-------

D - default values

¹CK = capital cost (known unit)/((MD*481.2)**FO*H1 **Y * expected life time)

The calculation sequence and default values assume a constant speed hydraulic pump nominally rated for 120KW and located 200 ft. below a reservoir. The equations relating the various physical quantities and the cost estimates are based on first principles and the data presented in Reference 1, and the cost estimates on Reference 2.

Calculation Sequence

$$C1 = 0.377 \times 10^{-6} \frac{\text{kwh}}{\text{ft-lb}}$$

$$C2 = 8.3398 \text{ lb/gal}$$

1) Costs (first pass only)

$$CC = CK * (MD * 481.2)^{F0} * H1 * Y$$

-
1. L. Marks and T. Baumeister, "Mechanical Engineers Handbook", McGraw Hill, N.Y., 1958, Section 14, p. 19.
 2. Carson and Fogleman, "Comparison of Methods for Converting Existing Power Plants to Pumped Storage Facilities", International Engineering Company, Inc., 1974.

Calculation Sequence Cont.

2) Mass flow rate and pump efficiency

If $P_1 \leq 0$, set $EFF = 1$, $M = 0$ and go to 3)

Solve the basic equations for M and EFF using:

$$X^3 - XA + B = 0$$

where

$$A = P_1 / (C_1 * C_2 * H_1)$$

$$B = A * (1 - EFD) * \sqrt{MD}$$

$$M = X^2$$

$$EFF = 1 - (1 - EFD) * \sqrt{MD} / X$$

3) Product efficiency and maximum charge rate

$$EF2 = EF1 * EFF$$

$$MP2 = \min(MP1 * EFF, MW * C_1 * C_2 * H_1)$$

4) Compute Statistics and Costs

CPU

SUBROUTINE PU(M,EFF,CC,EF2,MP2,M2U,P1,H1,EFD,MD,EF1,MP1,MM
1 ,CK,FO,Y)

PURPOSE PERFORMANCE OF HYDRAULIC PUMP

METHOD COMPUTE PUMP FLOW RATES ASSUMING CONSTANT SPEED WITH
EFFICIENCY A FUNCTION OF SQRT(FLOW RATE)

WRITTEN BY F. O. MAHONY

VERSION 1, MARCH 29 1977

CALL SEQUENCE

OUTPUTS

M - OUTPUT MASS FLOW RATE, GAL/HR
EFF- PUMP EFFICIENCY
CC - PUMP COST/YEAR, \$
EF2 - OUTPUT PRODUCT EFFICIENCY
MP2 - MAXIMUM OUTPUT CHARGE RATE, KW
M2U - MAXIMUM OUTPUT MASS FLOW RATE, GAL/HR

INPUTS

P1 - INPUT POWER, KW
H1 - HEIGHT OF WATER ABOVE INLET, FT
EFD - PUMP EFFICIENCY AT DESIGN POINT
MD - MASS FLOW RATE AT DESIGN POINT, GAL/HR
EF1 - INPUT PRODUCT EFFICIENCY
MP1 - INPUT MAXIMUM CHARGING RATE, KW
MM - MAXIMUM ALLOWABLE MASS FLOW RATE, GAL/HR
CK - PUMP CAPACITY COST COEFFICIENT
FO - PUMP EXPONENT FOR COST CALCULATIONS
Y - PUMP HEAD EXPONENT FOR COST CALCULATIONS

COMMON /CIMPL/IMPL /CTIME/TIME/CSIMUL/DUM(7),TMAX /COST/CCI

REAL M,MP2,M2U,MD,MP1,MM

IF(IMPL.GT.0)GO TO 100

TMAX1=TMAX*.99999

C1= 3.1441E-6

IF(EFD.EQ. .99999)EFD=0.9
IF(MD .EQ. .99999)MD =2.0E5
IF(MP1.EQ. .99999)MP1=1.E8
IF(MM .EQ. .99999)MM =3.0E5
IF(CK .EQ. .99999)CK =0.011
IF(FO .EQ. .99999)FO =0.5
IF(Y .EQ. .99999)Y =0.25
CC =CK*(MD*481.2)**FO*H1**Y

M2U =0.0

100 EFF= 1.0

M= 0.0

IF(P1 .LE. 0.0) GO TO 200

SOLVE CUBIC EQUATION FOR M AND EFF

A3= -P1/(C1*H1)
A4 =-A3*(1.0-EFD)*SQRT(MD)

CALL CUBIC(A3,A4,ANS)
IF(ANS.LE.0.) GO TO 200

M =ANS**2
EFF=1.0-(1.0-EFD)*SQRT(MD)/ANS

PRODUCT EFFICIENCY AND CHARGE RATE

200 EF2=EF1*EFF
MP2=AMIN1(MP1*EFF,MM*H1*C1)

IF(IMPL.LE.1)RETURN

STATISTICS


M2U=AMAX1(M2U,M)

IF(TIME.LT.TMAX1)RETURN


CCI=CCI+CC

RETURN
END

7.34 SOLAR-PHOTOVOLTAIC ARRAY



The photovoltaic cell is modeled by the circuit below. Power is delivered at terminal voltage V and is dependent on the cell temperature and insolation. Default for V is the maximum power point. A square array of solar cells is assumed with both parallel and series connections.



Basic Equations

Output current I as a function of terminal voltage V is given by the implicit relation

$$I = I_L + I_0 * (1 - \exp((V + I * R_S) * Q_B K / (T + 273))) \quad (1)$$

where

- IL = light current (amps)
- I_0 = diode reverse saturation current (amps)
- T = temperature ($^{\circ}\text{C}$)
- RS = internal resistance (ohms)
- QBK = device constant (default = electron charge/Boltzmann's constant)

The light current IL is computed by a bivariate expansion of insolation and cell temperature. It has been reported that this model fits observed solar cell characteristics within 5% at high temperatures and insolations and within less than 1% under more moderate conditions (ref. 2). The reverse saturation current I_0 is given by

$$I_0(T) = KD \cdot A_0 \cdot ((T+273)^{-3}) \cdot \exp(-EG_0/(T+273)) \quad (2)$$

where

- KD = a device constant
- A_0 = a material constant
- EG_0 = band gap at 0 $^{\circ}\text{K}$ /Boltzmann's constant

<u>Tables</u>	<u>Description</u>	<u>Units</u>
EFF	Efficiency of maximum power tracker versus fractional load (default table provided)	-
$\emptyset P$	Optimum cell power versus insolation and temperature (computed table)	kw
$\emptyset V$	Optimum cell voltage versus insolation and temperature (computed table)	volts

<u>Inputs/Port</u>	<u>Description</u>	<u>Units</u>
VT	Array terminal voltage (default = maximum power voltage)	volts
TC	Cell temperature	°C
TL*	Low temperature value (default = 28)	°C
TH*	High temperature value (default = 120)	°C
TR	Temperature range (default = TH)	°C
ST	Collector solar insolation	w/m ²
SL*	Low insolation value (default = 1000)	w/m ²
SH*	High insolation value (default = 25000)	w/m ²
SR	Insolation range (default = SH)	w/m ²
RC	Concentration ratio (default = 25)	-
AA	Total illuminated cell area (default = .00015*NS*NP)	m ²
NS	Number of cells in series (default = 300)	-
NP	Number of cells in parallel (default = 500)	-
I1*	Cell short circuit current at TL,SL (default = .06)	Amps
I2*	Cell short circuit current at TL,SH (default = 1.5)	Amps
I3*	Cell short circuit current at TH,SL (default = .06)	Amps

*These inputs may be ignored if IL1,DS,DT,DST,KD coefficients are supplied.

<u>Inputs/Port (cont'd)</u>	<u>Description</u>	<u>Units</u>
I4*	Cell short circuit current at TH,SH (default = 1.56)	Amps
V1*	Cell open circuit voltage at TL,SL (default = .6)	Volts
RS	Cell internal resistance (default = .055)	Ohms
AO	Material constant (default = 1.54E33 for silicon)	-
EGO	Band-gap at 0°K normalized by Boltzmann's constant (default = 1.4E4 for silicon)	°K
IL1	Coefficients in bivariate expansion for the light current IL. If not provided, they will be computed from the inputs I1,...,I4,	m^2V^{-1}
DS		m^2W^{-1}
DT		$1/°C$
DST		$m^2/W°C$
KD	Device constant, if not provided will be computed from I1,V1	-
CF	Lens radiation transmission coefficient	-
QBK	Device constant (default = 1.161E4)	°K/V
RAP	Rated power of maximum power point tracker (default computed)	kw
CC	Capital cost/year/unit cell area	\$/m ²
CM	Maintenance cost/year	\$

Note: Minimum input parameters to specify PV are cell area AA, number of cells in series NS and in parallel NP, concentration ratio RC, and rated power RAP. These parameters must be consistent with those for the collector model F0 or FP.

* These inputs may be ignored if IL1,DS,DT,DST,KD coefficients are supplied.

<u>Output/Port</u>	<u>Description</u>	<u>Units</u>
V	Array terminal voltage	Volts
P	Array output power	kw
I	Array output current	Amps
EF1	Solar cell efficiency	-
EF2	Maximum power tracker efficiency	-

Statistics

SP	Sum of energy delivered	kwh
----	-------------------------	-----

Calculation Sequence

First Pass

- 1) Compute parameter KD (if not input)

$$KD = I1 / \left[A0 * ((TL+273)**3) * EXP(-EG0/(TL+273)) * (EXP(QBK*V1/(TL+273)) - EXP(QBK*I1*RS/(TL+273))) \right]$$

- 2) Compute coefficients IL1,DS,DT,DST (if not input) in the light current bivariate expansion in temperature T and insolation S:

$$IL = IL1 * S * (1 + DS * (S - SL) + DT * (T - TL) + DST * (S - SL) * (T - TL)) \quad (3)$$

Define

$$FIL(I,T) = I - I0(T) * (1 - EXP(QBK*I*RS/(T+273)))$$

Then

$$IL1 = FIL(I1,TL)/SL$$

$$DS = (FIL(I2,TL) - IL1*SH)/(IL1*SH*(SH-SL))$$

$$DT = (FIL(I3,TH) - IL1*SL)/(IL1*SL*(TH-TL))$$

$$DST = (FIL(I4,TH) - IL1*SH - IL1*SH*DS*(SH-SL) - IL1*SH*DT*(TH-TL))/(IL1*SH*(SH-SL)*(TH-TL))$$

- 3) If a terminal voltage V_T is not input, calculate the optimal cell voltage $V = \emptyset V(S, T)$ with S ranging through 10 values equally spaced between 0 and SR , and with T ranging through 10 values equally spaced between 0 and TR , resulting in a 10×10 matrix $\emptyset V(S, T)$. The calculation is as follows: Given S and T , the open circuit voltage VOC is given by

$$VOC = (T+273) * A \log(1 + I_L / I_0) / QBK,$$

where I_L and I_0 are computed from (2) and (3).

A binary search is performed in the range from 0 to VOC . For a value V in this range, Newton-Raphson iterations are used to solve for the terminal current I satisfying (1). The corresponding power P (in kw) is

$$P = I * V / 1000 .$$

The iterative search process to maximize P is given by

- (i) Take the initial interval $[VL, VH]$ to be $[0, VOC]$.
- (ii) Compute a numerical derivative of P at the midpoint VM of $[VL, VH]$:

$$P' = (P(VM+1E-5) - P(VM)) / 1E-5$$

- (iii) If $P' \geq 0$, set $VL = VM$.

If $P' < 0$, set $VH = VM$.

- (iv) If $V_H - V_L > 2E-5$ and the number of iterations performed is 10, go to (ii). Otherwise P is maximized and

$$\emptyset V(S,T) = V_M$$

$$\emptyset P(S,T) = P$$

The 10 x 10 matrices $\emptyset V(S,T)$ (optimal cell voltage) and $\emptyset P(S,T)$ (maximal cell power) are stored for use in subsequent passes.

Subsequent Passes

- 4) Compute insulation S at the cells

$$S = ST \cdot RC \cdot CF$$

- 5) If terminal voltage VT is not input, the cell terminal voltage V and power P are obtained by interpolation from the arrays $\emptyset V(S,T)$ and $\emptyset P(S,T)$. (A diagnostic is printed if $S > SR$ or $TC > TR$).

- 6) If VT is used as an input voltage, then the cell voltage and power are determined using

$$V = VT / NS$$

$$I = IL(S, TC) + I_0(TC) \cdot (1 - \exp(QBK \cdot (V + I \cdot RS) / (TC + 273)))$$

$$P = I \cdot V / 1000$$

- 7) Array outputs prior to maximum power tracker:

$$V = V \cdot NS$$

$$P = P \cdot NS \cdot NP$$

$$I = P \cdot 1000 / V$$

$$EF1 = P \cdot 1000 / (S \cdot AA) \quad \text{if } S > 0$$

$$EF2 = 1.$$

- 8) If the maximum power tracker is used,

$$EF2 = EFF(P/RAP)$$

$$P = P*EF2$$

REFERENCES FOR PV

1. J. K. Linn, "Photovoltaic System Analysis Program-SOLCEL," Sandia Laboratories Report SAND77-1268, 1977.
2. L. H. Goldstein and G. R. Case, "PVSS-A Photovoltaic System Simulation Program," Sandia Laboratories, 1976.

SUBROUTINE PV(EFF,OP,OV,V,P,I,EF1,EF2,SP,
1VT,TC,TL,TH,TR,ST,SL,SH,SR,RC,AA,NS,NP,
2I1,I2,I3,I4,V1,RS,AO,EGO,IL1,DS,DT,DST,KD,
3CF,QBK,RAP,CC,CM)

PURPOSE THIS COMPONENT COMPUTES THE POWER AND VOLTAGE
OUTPUT OF A PHOTO-VOLTAIC CELL ARRAY GIVEN THE
TEMPERATURE AND INSOLATION
WRITTEN BY Y.K.CHAN, 10-21-78, VERSION 1

METHOD NEWTON RALPHSON METHOD IS USED TO CALCULATE CELL
CURRENT AS FUNCTION OF INSOLATION, TEMPERATURE, AND
TERMINAL VOLTAGE. IF TERMINAL VOLTAGE IS NOT INPUT,
POWER IS COMPUTED AT OPTIMAL VOLTAGE. THIS IS DONE
FOR A RANGE OF 10 VALUES OF TEMPERATURE AND 10
VALUES OF INSOLATION IN THE FIRST PASS.
AT SUBSEQUENT PASSES,
INTERPOLATION IS USED.

CALL SEQUENCE

TABLES

EFF -EFFICIENCY OF MAXIMUM POWER TRACKER
VS FRACTIONAL LOAD (DEFAULT TABLE)
OP -OPTIMAL POWER,KW, VS INSOLATION,W/M2, AND
TEMPERATURE,C
OV -OPTIMAL TERMINAL VOLTAGE,V, VS INSOLATION,W/M2, AND
TEMPERATURE,C

OUTPUTS

V -ARRAY TERMINAL VOLTAGE,VOLTS
P -ARRAY OUTPUT POWER,KW
I -ARRAY OUTPUT CURRENT,AMPS
EF1 -SOLAR CELL EFFICIENCY
EF2 -MAXIMUM POWER TRACKER EFFICIENCY

STATISTICS

SP -SUM OF ENERGY DELIVERED,KWH

INPUTS

VT -ARRAY TERMINAL VOLTAGE,VOLTS,(DEFAULT=MAXIMUM
POWER VOLTAGE)
TC -CELL TEMPERATURE,C
TL -LOW TEMPERATURE VALUE,C,(DEFAULT=28)
TH -HIGH TEMPERATURE VALUE,C,(DEFAULT=120)
TR -TEMPERATURE RANGE,C,(DEFAULT=TH)
ST -COLLECTOR SOLAR INSOLATION,W/M2
SL -LOW INSOLATION VALUE,W/M2,(DEFAULT=1000)
SH -HIGH INSOLATION VALUE,W/M2,(DEFAULT=25000)
SR -INSOLATION RANGE,W/M2,(DEFAULT=SH)
RC -CONCENTRATION RATIO(DEFAULT=25)
AA -TOTAL COLLECTOR CELL AREA,M2,(DEFAULT=2.5E-3)
NS -NUMBER OF CELLS IN SERIES(DEFAULT=300)
NP -NUMBER OF CELLS INPARALLEL(DEFAULT=500)
I1 -CELL SHORT CIRCUIT CURRENT AT TL,SL, AMPS
(DEFAULT=.06)
I2 -CELL SHORT CIRCUIT CURRENT AT TL,SH, AMPS
(DEFAULT=1.5)
I3 -CELL SHORT CIRCUIT CURRENT AT TH,SL, AMPS
(DEFAULT=.06)
I4 -CELL SHORT CIRCUIT CURRENT AT TH,SH, AMPS

(DEFAULT=1.56)
 V1 -CELL OPEN CIRCUIT VLOTAGE AT TL,SL, VOLTS
 (DEFAULT=.6)
 RS -CELL INTERNAL RESISTANCE, OHMS,(DEFAULT=.055)
 A0 -MATERIAL CONSTANT(DEFAULT=1.54E33 FOR SILICON)
 EGO -BAND GAP AT OK NORMALIZED BY BOLTZMANN S
 CONSTANT(DEFAULT=1.4E4 FOR SILICON)
 IL1,DS,DT,DST
 -COEFFICIENTS IN BIVARIATE EXPANSION FOR THE
 LIGHT CURRENT IL. IF NOT PROVIDED, THEY WILL
 BE COMPUTED FROM THE INPUTS I1,...,I4.
 THE UNITS FOR IL1,DS,DT,DST ARE RESPECTIVELY
 M2V-1,M2W-1,C-1,M2(WC)-1
 KD -DEVICE CONSTANT. IF NOT PROVIDED, IT WILL BE
 COMPUTED FROM I1,V1
 QBK -DEVICE CONSTANT,K/V,(DEFAULT=ELECTRON CHARGE/
 BOLTZMANN S CONSTANT=1.161E4)
 CF -LENS RADIATION TRANSMITTANCE COEFFICIENT
 RAP -RATED POWER OF MAXIMUM POWER POINT TRACKER,KW
 (DEFAULT=LARGEST OPTIMAL POWER FOR THE RANGE
 OF TC AND ST)
 CC -CAPITAL COST/YEAR/UNIT CELL AREA, \$/M2
 CM -MAINTENANCE COST/YEAR, \$

REAL I,NS,NP,I1,I2,I3,I4,IL1,KD,IL,I0,IM,IME
 DIMENSION EFF(1),EFF1(14),OP(1),OV(1)
 COMMON /CIMPL/IMPL,ICNT,ITEST
 COMMON /CTIME/TIME /CSIMUL/DUM(7),TMAX
 COMMON /COST/CCAP,CMA,COP
 DATA EFF1/0.,.1,.2,.3,.4,.5,1.,.338,.44,.53,.61,.70,.75,.9/
 IL(S,T)=IL1*S*(1.+DS*(S-SL)+DT*(T-TL)+DST*(S-SL)*(T-TL))
 I0(T)=KD*A0*((1+273)**3)*EXP(-EGO/(T+273))
 FIL(I,T)=I-I0(T)*(1.-EXP(QBK*I*RS/(T+273)))
 IF(IMPL.GT.0)GO TO 100
 SP=0.
 TMAX1=TMAX*.99999
 TINC1=DUM(7)*0.5

INITIALIZATION

1F(EFF(2).NE.1.99999)GO TO 11
 EFF(2)=7
 DO 12 II=4,17
 12 EFF(II)=EFF1(II-3)
 11 CONTINUE
 OP(2)=10.
 OP(3)=10.
 OV(2)=10.
 OV(3)=10.
 IF(TL.EQ..99999)TL=28
 IF(TH.EQ..99999)TH=120
 IF(TR.EQ..99999)TR=TH
 IF(SL.EQ..99999)SL=1000
 IF(SH.EQ..99999)SH=25000
 IF(SR.EQ..99999)SR=SH
 IF(RC.EQ..99999)RC=25
 IF(NS.EQ..99999)NS=300
 IF(NP.EQ..99999)NP=500

ORIGINAL PAGE IS
OF POOR QUALITY

```

IF(AA.EQ..99999)AA=1.5E-4*NS*NP
IF(I1.EQ..99999)I1=.06
IF(I2.EQ..99999)I2=1.5
IF(I3.EQ..99999)I3=.06
IF(I4.EQ..99999)I4=1.56
IF(V1.EQ..99999)V1=.6
IF(RS.EQ..99999)RS=.055
IF(A0.EQ..99999)A0=1.54E33
IF(EG0.EQ..99999)EG0=1.4E4
IF(QBK.EQ..99999)QBK=1.161E4

```

```

C
IF(KD.EQ..99999)KD=I1/(A0*((TL+273)**3)*EXP(-EG0/
1 (TL+273))*(EXP(QBK*V1/(TL+273))-
2 EXP(QBK*I1*RS/(TL+273))))
IF(IL1.EQ..99999)IL1=FIL(I1,TL)/SL
IF(DS.EQ..99999)DS=(FIL(I2,TL)-IL1*SH)/(IL1*SH*(SH-SL))
IF(DT.EQ..99999)DT=(FIL(I3,TH)-IL1*SL)/(IL1*SL*(TH-TL))
IF(DST.EQ..99999)DST=(FIL(I4,TH)-IL1*SH-
1 IL1*SH*DS*(SH-SL)-IL1*SH*DT*(TH-TL))/
2 (IL1*SH*(SH-SL)*(TH-TL))

```

```

C
C
C
C
C
C
CALCULATE OPTIMAL POWER GP AND CELL VOLTAGE

```

```

IF TERMINAL VOLTAGE IS NOT INPUT

```

```

IF(VT.NE..99999)GO TO 100
S=0.
DO 33 J=1,10
JO=J+3
OP(JO)=(J-1)*TR/9.
33 OV(JO)=OP(JO)
DO 3 K=1,10
T=0.
DO 4 J=1,10
AIL=IL(S,T)
BIO=IO(T)
VOC=(T+273)*ALOG(1.+AIL/BIO)/QBK
VL=0.
VH=VOC

```

```

C
C
C
BINARY SEARCH FOR MAX POWER POINT

```

```

DO 5 M=1,10
VM=(VL+VH)*.5
VME=VM+1.E-5
IM=AINR(AIL,BIO,QBK,VM,RS,T)
PM=IM*VM
IME=AINR(AIL,BIO,QBK,VME,RS,T)
PME=IME*VME
PMP=PME-PM
IF(PMP.GE.0.)VL=VM
IF(PMP.LT.0.)VH=VM
IF((VH-VL).LE.2.E-5)GO TO 6
5 CONTINUE
6 CONTINUE
IKJ=13+K+J*10
OV(IKJ)=VM

```

```


      OP(1KJ)=PM/1000.
      T=T+TR/9.
4    CONTINUE
      IKJ0=13+K
      OP(1KJ0)=S
      OV(1KJ0)=S
      S=S+SR/9.
3    CONTINUE
C
      IF(RAP.EQ..99999)RAP=OP(33)*NS*NP
C      WRITE(6,101)(OP(1K),IK=24,123)
C      WRITE(6,101)(OV(1K),IK=24,123)
C 101 FORMAT(1H0,3HPV ,/,(5X,10E10.2))
C
100 CONTINUE
C
      COMPUTE INSOLATION AT THE CELLS
C
      S=ST*RC*CF
C
      COMPUTE CELL VOLTAGE AND POWER
      IF(VT.NE..99999)GO TO 900
      IF(IMPL.NE.2)GO TO 809
      IF((S.GT.SR).OR.(TC.GT.TR))WRITE(6,808)
808  FORMAT(1H0,62HPV  WARNING  INSOLATION OR TEMPERATURE AT CELL EXCEE
1D RANGE
      )
      IF((S.GT.SR).OR.(TC.GT.TR))ICNT=ICNT+1
809  CONTINUE
      V=TBLU2(S,TC,OV(14),OV(4),OV(24),1,1,10,10,10,10)
      P=TBLU2(S,TC,OP(14),OP(4),OP(24),1,1,10,10,10,10)
      GO TO 901
900  CONTINUE
      V=V/NS
      AIL=IL(S,TC)
      BIO=IO(TC)
      I=AINR(AIL,BIO,QBK,V,RS,TC)
      P=I*V/1000.
901  CONTINUE
C
      COMPUTE ARRAY VOLTAGE AND POWER
C
      V=V*NS
      P=P*NS*NP
      I=0.
      IF(V.GT.0.)I=P*1000./V
      EF1=1.
      EF2=1.
      IF(S.GT.0.)EF1=P*1000/(S*AA)
      IF(VT.NE..99999)GO TO 904
      PRAT=P/RAP
      NEF=EFF(2)
      EF2=TBLU1(PRAT,EFF(4),EFF(4+NEF),1,-NEF)
      P=P*EF2
904  CONTINUE
      IF(IMPL.LE.1)RETURN
      SP=SP+P*TINC1
      IF(TIME.LT.TMAX1)RETURN
      CCAP=CCAP+CC*AA

```

CMA=CMA+CM
RETURN
END

PV

7.35 AC-DC RECTIFIER



This component models a solid-state rectifier/transformer. Power losses due to resistive heating and contact potential loss are modeled. Default parameter values determining power losses are based on 200 kw rated power.




FIGURE 7.35: RECTIFIER FUNCTIONAL DIAGRAM

Inputs*

<u>Parameter/Port</u>		<u>Description</u>	<u>Units</u>
P	1	AC input power	kw
RT		Transformer resistance (D = 0)	ohms
XT		Transformer reactance (D = 0.03)	ohms
VAC		Rated AC voltage (D = 440)	volts
DR		Rectifier contact potential (D = 0)	volts
RR		Rectifier resistance (D = 0.02)	ohms
RAP		Rated input power	kw
EF	1	Input product efficiency	-
MP	1	Maximum input power (D = 1×10^8)	kw
CC		Rectifier cost/year	\$

Outputs

<u>Variable/Port</u>			
P	2	DC output power	kw
IAC		AC input current	amps
PL		Power loss	kw
EF	2	Output product efficiency	-
MP	2	Maximum output power	kw

* Minimum input parameters to specify RE are:

RR = rectifier resistance,

RAP = rated input power.

RR may be used as an adjustment parameter to obtain a specified efficiency at rated power.

D - Default values supplied.

Calculation Sequence

- 1) Compute transformer power angles

$$Y = \sin(\theta) = \sqrt{3} * X_T * P_1 * 1000 / VAC^2$$

$$ABS(Y) > 1 \Rightarrow \text{DIAGNOSTIC}$$

- 2) Input and output current

If $P_1 \leq 0$ set $P_2 = IAC = PL = 0.$, $EFF = 1$ and go to 4)

$$IAC = VAC \sqrt{2-2\cos(\theta)} / (\sqrt{3} * X_T)$$

$$" = VAC \sqrt{2-2 * \sqrt{1-Y^2}} / (\sqrt{3} * X_T)$$

$$IDC = \pi * IAC / \sqrt{6}$$

- 3) Power loss and output power

$$PL = (\sqrt{3} * R_T * IAC^2 + IDC * (DR + IDC * RR)) / 1000$$

$$P_2 = P_1 - PL$$

$$EFF = P_2 / P_1$$

$$P_2 \leq 0 \Rightarrow \text{DIAGNOSTIC, } EFF = 1$$

- 4) Efficiency and maximum power

$$EF2 = EF1 * EFF$$

$$MP2 = \min(MP1, RAP) * EFF$$

- 5) Compute Costs

CRE

SUBROUTINE RE(P2,IAC,PL,EF2,MP2,P1,RT,XT,VAC,DR,RR,RAP,EF1,MP1,CC)

PURPOSE SOLID STATE RECTIFIER/TRANSFORMER MODEL

METHOD COMPUTE OUTPUT DC POWER AS A FUNCTION
OF INPUT AC POWER

WRITTEN BY Y.K.CHAN

VERSION 1, JUNE 1, 1977

CALL SEQUENCE

OUTPUTS

P2 -DC OUTPUT POWER, KW
IAC -AC INPUT CURRENT, AMPS
PL -POWER LOSS, KW
EF2 -OUTPUT PRODUCT EFFICIENCY
MP2 -MAXIMUM OUTPUT POWER, KW

INPUTS

P1 -AC INPUT POWER, KW
RT -TRANSFORMER RESISTANCE, OHMS
XT -TRANSFORMER REACTANCE, OHMS
VAC -RATED AC VOLTAGE, VOLTS
DR -RECTIFIER CONTACT POTENTIAL, VOLTS
RR -RECTIFIER RESISTANCE, OHMS
RAP -RATED INPUT POWER, KW
EF1 -INPUT PRODUCT EFFICIENCY
MP1 -MAXIMUM INPUT POWER, KW
CC -RECTIFIER COST/YEAR, \$

COMMON /CIMPL/IMPL,ICNT/CTIME/TIME/CSIMUL/DUM(7),TMAX/COST/CC1

REAL IAC,MP2,MP1,IDC

DATA PI/3.14159/

DATA ROOT3/1.73205/

IF(IMPL.GT.0) GO TO 100
IF(MP1.EQ..99999)MP1=1.E8
IF(RT.EQ..99999) RT=0.
IF(XT.EQ..99999) XT=.03
IF(VAC.EQ..99999) VAC=440.
IF(DR.EQ..99999) DR=0.
IF(RR.EQ..99999) RR=.02
TMAX1=TMAX*.99999

COMPUTE TRANSFORMER POWER ANGLES

100 Y=ROOT3*XT*P1*1000./(VAC*VAC)

YY=Y*Y

IF(YY.LE.1.)GO TO 200

IF(IMPL.EQ.2)WRITE(6,106)P1,XT,VAC

108 FORMAT(1H0,19HRE, AC INPUT POWER ,F12.3,49H TOO LARGE IN RELATION TO
1TO TRANSFORMER REACTANCE ,F12.3,22H AND RATED AC VOLTAGE ,F12.3)

IF(IMPL.EQ.2)ICNT=ICNT+1

200 YY=AMIN1(1.,YY)

INPUT AND OUTPUT CURRENT

IF(P1.GT.0.)GO TO 300

P2=0.

RE

```
IAC=0.  
PL=0.  
EFF=1.  
GO TO 400
```

```
C  
300 IAC=VAC*SQRT(2.-2.*SQRT(1.-YY))/(ROOT3*XT)  
IDC=PI*IAC/SQRT(6.)
```

POWER LOSS AND OUTPUT POWER


```
C  
C  
C  
PL=(ROOT3*RT*IAC*IAC+IDC*(DR+IDC*RR))/1000.  
P2=P1-PL  
EFF=P2/P1  
IF(P2.GT.0.) GO TO 400  
IF(IMPL.EQ.2)WRITE(6,308)PL,P1  
308 FORMAT(1H0,11HPOWER LOSS ,F12.3,23HRE EXCEEDS INPUT POWER ,F12.3,  
156H CHECK RATED AC VOLTAGE VAC AND TRANSFORMER REACTANCE XT )  
IF(IMPL.EQ.2)ICNT=ICNT+1  
P2=0.  
EFF=1.
```

EFFICIENCY AND MAXIMUM POWER

```
C  
C  
C  
400 EF2=EF1*EFF  
MP2=AMIN1(MP1,RAP)  
MP2=MP2*EFF  
IF(IMPL.LE.1)RETURN  
IF(TIME.LT.TMAX1)RETURN  
CCI=CCI+CC
```

```
C  
RETURN  
END
```

7.36 RANDOM NUMBERS



This component generates an uncorrelated sequence of normally distributed random numbers with a specified mean and standard deviation.

Inputs

Parameter/Port

Description

MN	Mean value of sequence
SIG	Standard deviation of sequence
NST ¹	Start parameter. (Use any odd integer greater than 1). Default supplied.

Outputs

Variable/Port

F0	Random number output
----	----------------------

¹ If RESET parameter > 0 then succeeding simulations use NST to start random sequence.

RN

CRN

SUBROUTINE RN(U,AX,SIG,AMN)
VERSION 2. REVISED MAY 1977
PURPOSE - GENERATES A NORMALLY DISTRIBUTED RANDOM NUMBER
CALL SEQUENCE


U - RANDOM NUMBER OUTPUT
AX - A START PARAMETER WHICH CONTROLS THE BEGINNING POINT
OF THE OUTPUT SEQUENCE. AX SHOULD BE ANY ODD INTEGER
GREATER THAN ONE. THE DEFAULT VALUE OF AX IS 431469.
AX IS UPDATED FOR NEW CALLS TO THE SUBROUTINE.
SIG - THE DESIRED STANDARD DEVIATION OF THE SEQUENCE
AMN - THE DESIRED MEAN OF THE SEQUENCE

DESIGNED BY ROGER W. CALL

SEPT 1976

COMMON /CIMPL/IMPL,ICNT,ITEST
DATA Y /253967./,AX0/0./
IF(IMPL.GT.0)GO TO 5
IF(AX.EQ..99999) AX=431469.
IF(AX0.EQ.0.)AX0=AX
IF(ITEST.EQ.1)AX=AX0
5 X =AX
SUM=0.
DO 1 I=1,12
X= AMOD(X*Y,16777216.)
SUM= SUM+ X/16777215.
1 AX= X
U=(SUM-6.0)*SIG+AMN
RETURN
END

7.37 SATURATION FUNCTION

InputsParameter/PortDescription

FIN	Input quantity
C1	Slope $0 < FIN < C3$
C2	Slope $FIN > C3$
C3	Positive saturation intercept
C4	Slope $0 > FIN > C6$
C5	Slope $FIN < C6$
C6	Negative saturation intercept

OutputsVariable/Port

F0	Output quantity
----	-----------------

Calculation Sequence

$F0 = C1 * C3 + C2 * (FIN - C3)$	if $FIN > C3$
$F0 = C1 * FIN$	if $0 < FIN < C3$
$F0 = C4 * FIN$	if $0 > FIN > C6$
$F0 = C4 * C6 + C5 * (FIN - C6)$	if $FIN < C6$

SUBROUTINE SA(FO,FIN,C1,C2,C3,C4,C5,C6)

PURPOSE - TO SIMULATE SATURATION

METHOD - SEE CODING. C3 AND C6 ARE VALUES OF THE INPUT AT WHICH SATURATION OCCURS. C3 IS GREATER THAN C6. THE ROUTINE CAN SIMULATE A CHANGE OF SLOPE AT THE ORIGIN (C1.NE.C4) PROVIDED C6 IS LESS THAN ZERO. SIMILARLY THE SLOPES IN THE SATURATION REGION (C2 AND C5) CAN DIFFER. THE SLOPES CAN BE POSITIVE OR NEGATIVE

WRITTEN BY - ADAM LLOYD

LATEST REVISION - NOV 75

LIMITATIONS - USE OF ZERO SLOPES ($C2=0$ OR $C5=0$) IN THE SATURATION REGION SHOULD BE AVOIDED. IT IS DESIRABLE THAT THE SLOPE RATIOS $C1/C2$ AND $C4/C5$ SHOULD NOT EXCEED 100. EXCESSIVE SLOPE RATIOS MAY RESULT IN VERY SLOW CONVERGENCE

INPUT/OUTPUT LIST

FO	OUTPUT VARIABLE	ANY	OUTPUT	VAR
FIN	INPUT VARIABLE	ANY	INPUT	VAR
C1	SLOPE) FIRST	ANY	INPUT	PARAM
C2	SATURATION SLOPE) SLOPE	ANY	INPUT	PARAM
C3	SATURATION INTERCEPT)	ANY	INPUT	PARAM
C4	SLOPE) SECOND	ANY	INPUT	PARAM
C5	SATURATION SLOPE) SLOPE	ANY	INPUT	PARAM
C6	SATURATION INTERCEPT)	ANY	INPUT	PARAM

```
IF(FIN.GT.C3)GO TO 10
IF(FIN.LT.C6)GO TO 20
IF(FIN.LT.O.)GO TO 30
FO=C1*FIN
GO TO 100
```

POSITIVE SATURATION

```
10  FO=C1*C3+C2*(FIN-C3)
    GO TO 100
```

NEGATIVE SATURATION


```
20  FO=C4*C6+C5*(FIN-C5)
    GO TO 100
```

NEGATIVE UNSATURATED

30 FO=C4*FIN

100 RETURN
END

7.38 SOLAR ORIENTATION



The Solar Orientation model computes flat plate collector insolation for five types of solar tracking:

- Tilted orientation, facing south
- Tracking about a horizontal EW axis
- Tracking about a horizontal NS axis
- Tilted, tracking about a vertical axis
- Two axis tracking

Array insolation is the sum of beam and diffuse components. The beam component is the product of normal incidence radiation and a geometry-dependent incidence factor. The diffuse component is approximated as the product of horizontal diffuse insolation times a geometry factor plus ground reflectance.

BASIC EQUATIONS

$$\begin{aligned}
 ST1 &= SB1 + SD1 + SR1 \\
 &= SB*IF + SD*RD + ST*RR \\
 SD &= ST - SB*SIN(EL) \\
 RD &= .5*(1 + COS(TLT)) \\
 RR &= .5*PR*(1 - COS(TLT)),
 \end{aligned}$$


where

IF = solar incidence factor (incidence angle cosine)
 TLT = collector tilt angle from horizontal
 PR = ground reflectance

<u>Inputs/Port</u>	<u>Description</u>	<u>Units</u>
LA	Collector latitude*	Deg
DY	Day-of-the-year (1-365)	-
TD	Time-of-day (0-24)	hr
MØ	Tracking mode	-
	1 = fixed orientation and tilt (default)	
	2 = horizontal EW axis tracking	
	3 = horizontal NS axis tracking	
	4 = tilted, vertical axis tracking	
	5 = two axis tracking	
TL	Collector tilt (MØ = 1, 4 inputs)	Deg
SB	Direct normal beam insolation	w/m ²
ST	Global insolation on a horizontal surface	w/m ²
PR	Ground reflectance (default = 0.2)	-

*For TMY stations, see Table 7.8 of the Environmental Data Component ED.

<u>Inputs/Port</u> (cont'd)		<u>Description</u>	<u>Units</u>
AA		Collector array area	m^2
SBT		Insolation threshold for tracking (default = 100.)	w/m^2
<u>Outputs/Port</u>		<u>Description</u>	<u>Units</u>
SE		SIN (Solar Elevation Angle)*	-
SA		SIN (Solar Azimuth Angle)*	-
IF		COS (Solar Incidence Angle)	-
RE	1	Tracking power required	kw
SB	1	Collector beam insolation	w/m^2
SD	1	Collector diffuse insolation	w/m^2
SR	1	Collector reflected insolation	w/m^2
ST	1	Collector total insolation	w/m^2
TLT		Collector tilt angle	Deg



* FIGURE 7.38 SOLAR ORIENTATION ANGLES

CALCULATION SEQUENCE

$$RPD = \pi/180$$

If $SB \leq 0$ and $M\emptyset > 1$ return

1) Solar azimuth and elevation

$$W = 15 \cdot (12 - TD) \cdot RPD$$

$$\delta = 23.45 \cdot \sin(2\pi \cdot (284 + DY)/365) \cdot RPD$$

$$LA' = LA \cdot RPD$$

$$SE = \sin \delta \cdot \sin LA' + \cos \delta \cdot \cos W \cdot \cos LA'$$

$$CE = (1. - SE \cdot SE)^{1/2}$$

$$\tan(AZ) = \cos \delta \cdot \sin W / (\cos W \cdot \sin LA' \cdot \cos \delta - \sin \delta \cdot \cos LA')$$

$$CA = 1 / (1 + \tan^2(AZ))^{1/2}$$

$$SA = \tan(AZ) \cdot CA$$

2) Horizontal diffuse insolation

$$SD = ST - SB \cdot SE$$

3) Array geometry and tracking power

$$RE1 = 0$$

If $M\emptyset = 1$ then

$$TLT' = TL \cdot RPD$$

$$IF = \sin TLT' \cdot CE \cdot CA + \cos TLT' \cdot SE$$

If $M\emptyset = 2$ then

$$IF = \sqrt{1. - (CE \cdot SA)^2}$$

$$TLT' = \min(\cos^{-1}(SE/IF), \pi/2)$$

$$RE1 = 3.75 \cdot E - 4 \cdot AA$$

if $SB > SBT$

CALCULATIONS (contd)

If $M\emptyset = 3$ then

$$IF = \sqrt{1. - (CE*CA)^2}$$

$$TLT' = \text{MIN}(\text{COS}^{-1}(SE/IF), \pi/2)$$

$$RE1 = 3.75 \text{ E-4} * AA$$

if $SB > SBT$

If $M\emptyset = 4$ then

$$TLT' = TL * RPD$$

$$IF = \text{SIN } TLT' * CE + \text{COS } TLT' * SE$$

$$RE1 = 3.75 \text{ E-4} * AA$$

if $SB > SBT$

If $M\emptyset = 5$ then

$$IF = 1$$

$$TLT' = \text{MIN}(\text{COS}^{-1}(SE), \pi/2)$$

$$RE1 = 5. \text{E-4} * AA$$

if $SB > SBT$

4) Insolation components

$$SB1 = SB * IF$$

$$SD1 = SD * .5 * (1 + \text{COS}(TLT'))$$

$$SR1 = ST * .5 * PR * (1 - \text{COS}(TLT'))$$

$$ST1 = SB1 + SD1 + SR1$$

5) Tilt

$$TLT = TLT' / RPD$$

REFERENCES FOR SO

1. J. K. Linn, "Photovoltaic System Analysis Program-SOLCEL," Sandia Laboratories Report SAND77-1268, August 1977.
2. B. Y. Liu and R. C. Jordan, "The Interrelationship and Characteristic Distribution of Direct, Diffuse and Total Solar Radiation," Solar Energy, Vol. IV, July 1960, pp. 1-19.
3. J. A. Duffie and W. A. Beckman, Solar Thermal Processes (Chapter 2), Wiley, 1974.

CSO

SUBROUTINE SO(SE,SA,IF,RE1,SB1,SD1,SR1,ST1,TLT,
1 LA,DY,TD,MO,TL,SB,ST,PR,AA,SBT)

PURPOSE THIS COMPONENT COMPUTES FLAT PLATE COLLECTOR
INSOLATION FOR FIVE MODES OF SOLAR TRACKING
TILTED ORIENTATION, FACING SOUTH
TRACKING ABOUT A HORIZONTAL EW AXIS
TRACKING ABOUT A HORIZONTAL NS AXIS
TILTED, TRACKING ABOUT THE VERTICAL AXIS
TWO AXIS TRACKING

WRITTEN BY Y.K.CHAN, 11-6-78, VERSION 1

METHOD ARRAY INSOLATION IS SUM OF BEAM AND DIFFUSE
COMPONENTS. THE BEAM COMPONENT IS THE PRODUCT OF
NORMAL INCIDENCE INSOLATION AND A GEOMETRY DEPENDENT
INCIDENCE FACTOR. THE DIFFUSE COMPONENT IS
APPROXIMATED AS THE PRODUCT OF HORIZONTAL DIFFUSE
INSOLATION TIMES A GEOMETRY FACTOR PLUS GROUND REFLECTANCE.

CALLING SEQUENCE

OUTPUTS

SE -SINE OF SOLAR ELEVATION ANGLE
SA -SINE OF SOLAR AZIMUTH ANGLE
IF -COSINE OF SOLAR INCIDENCE ANGLE
RE1 -TRACKING POWER REQUIRED,KW
SB1 -COLLECTOR BEAM INSOLATION,W/M2
SD1 -COLLECTOR DIFFUSE INSOLATION,W/M2
SR1 -COLLECTOR REFLECTED INSOLATION,W/M2
ST1 -COLLECTOR TOTAL INSOLATION,W/M2
TLT -COLLECTOR TILE ANGLE,DEGREES

INPUTS

LA -COLLECTOR LATITUDE, DEGREES
DY -DAY OF YEAR(1-365)
TD -TIME OF DAY(0-24),HOUR
MO -TRACKING MODE
1=FIXED ORIENTATION AND TILT (DEFAULT)
2=HORIZONTAL EW AXIS TRACKING
3=HORIZONTAL NS AXIS TRACKING
4=TILTED,VERTICAL AXIS TRACKING
5=TWO AXIS TRACKING
TL -COLLECTOR TILT (MO=1,4 INPUTS),DEGREES
SB -DIRECT NORMAL BEAM INSOLATION,W/M2
ST -GLOBAL INSOLATION ON A HORIZONTAL SURFACE,W/M2
PR -GROUND REFLECTANCE (DEFAULT=0.2)
AA -COLLECTOR ARRAY AREA,M2
SBT -INSOLATION THRESHOLD FOR TRACKING,W/M2
(DEFAULT=100)

COMMON /CIMPL/IMPL
REAL IF,LA,MO
IF(IMPL.NE.0)GO TO 100
IF(MO.EQ..99999)MO=1.
IF(PR.EQ..99999)PR=.2
IF(SBT.EQ..99999)SBT=100
RPD=3.1415926/180.

100 CONTINUE

IF((SB.GT.0.).OR.(MO.LT.2.))GO TO 109

SA=0.

IF=0.

RE1=0.

SB1=0.

SD1=0.

SR1=0.

ST1=0.

RETURN

109 CONTINUE

RE1=0.

C
C
C

SOLAR AZIMUTH AND ELEVATION

W=15.*(12.-TD)*RPD

ADEL=23.45*SIN(.0172142*(284+DY))*RPD

PLA=LA*RPD

CLAP=COS(PLA)

SADEL=SIN(ADEL)

CADEL=COS(ADEL)

SINPLA=SIN(PLA)

COSW=COS(W)

SE=SADEL*SINPLA+CADEL*COSW*CLAP

CE=SQRT(1.-SE*SE)

F=CADEL*COSW*SINPLA-SADEL*CLAP

CA=0.

SA=1.

IF(ABS(F).LE.1.E-5)GO TO 200

TAZ=CADEL*SIN(W)/F

CA=1./SQRT(1.+TAZ*TAZ)

SA=TAZ*CA

200 CONTINUE

C
C
C

HORIZONTAL DIFFUSE INSOLATION

SD=ST-SB*SE

C
C
C

ARRAY GEOMETRY AND TRACKING POWER

IMO=MO+.1

GO TO(301,302,303,304,305)IMO

301 TLTP=TL*RPD

IF=SIN(TLTP)*CE*CA+COS(TLTP)*SE

GO TO 309

302 IF=SQRT(1.-CE*CE*SA*SA)

BIF=AMIN1(1.,SE/IF)

TLTP=1.5708

IF(BIF.GT.0.)TLTP=ACOS(BIF)

IF(SB.GT.SBT)RE1=3.75E-4*AA

GO TO 309

303 IF=SQRT(1.-CE*CE*CA*CA)

BIF=AMIN1(1.,SE/IF)

TLTP=1.5708

IF(BIF.GT.0.)TLTP=ACOS(BIF)

IF(SB.GT.SBT)RE1=3.75E-4*AA

GO TO 309

304 TLTP=TL*RPD

IF=SIN(TLTP)*CE+COS(TLTP)*SE

IF(SB.GT.SBT)RE1=3.75E-4*AA
GO TO 309

305 IF=1.

SE1=AMIN1(SE,1.)

TLTP=1.5708

IF(SE1.GT.0.)TLTP=ACOS(SE1)

IF(SB.GT.SBT)RE1=5.E-4*AA

C

309 CONTINUE

C

C

C

INSULATION COMPONENTS

SB1=SB*IF

SD1=SD*.5*(1.+COS(TLTP))

SR1=ST*.5*PR*(1.-COS(TLTP))

ST1=SB1+SD1+SR1

C

C

C


TILT

TLT=TLTP/RPD

RETURN

END

7.39 SINGLE POLE SWITCH



THE SWITCHING OPERATION MAY BE CONTROLLED BY EITHER TIME OR THE INPUT PARAMETER SW1. THE TIME DEPENDENCE MAY BE ELIMINATED BY SETTING $TC1 = 10^{36}$

Inputs

<u>Parameter/Port</u>	<u>Description</u>
VA1	Input to switch
VB1	Input to switch
SW1	Switch control parameter
TC1	Time for first switching (hours)
TC2	Time for second switching (hours)

Outputs

<u>Variable/Port</u>	
V01	Switch output

Calculation Sequence

$$\begin{aligned}
 &\text{If } SW1 = 0 \text{ then} \\
 &\quad V01 = \begin{pmatrix} VA1 & TC1 < TIME < TC2 \\ VB1 & \text{otherwise} \end{pmatrix} \\
 &\text{If } SW1 = 1 \text{ then} \\
 &\quad V01 = \begin{pmatrix} VB1 & TC1 < TIME < TC2 \\ VA1 & \text{otherwise} \end{pmatrix}
 \end{aligned}$$

CSW

SUBROUTINE SW(V01,VA1,VB1,SW1,TC1,TC2)

PURPOSE - TO PROVIDE SWITCH CONTROL FOR ONE VARIABLE

METHOD - SEE CODING

WRITTEN BY - ADAM LLOYD

LATEST REVISION

NOV 75

LIMITATIONS - NOT MORE THAN TWO SWITCHINGS AT TIMES TC1 AND TC2

INPUT/OUTPUT LIST

V01	OUTPUT VARIABLE NO 1	ANY	OUTPUT	VAR
VA1	INPUT VARIABLE NO A1	ANY	INPUT	VAR
VB1	INPUT VARIABLE NO B1	ANY	INPUT	VAR
SW1	SWITCH CONTROL INITIAL VALUE	---	INPUT	PARAM
	=1. VO=VB			
	=0. VO=VA			
TC1	TIME FOR FIRST SWITCH	SECS	INPUT	PARAM
TC2	TIME FOR SECOND SWITCH	SECS	INPUT	PARAM
	(TC2.GT.TC1)			

COMMON/CTIME/TIME

COMMON/CIO/IREAD,IWRITE,IDIAG

SX=SW1

IF(TIME.GT.TC1.AND.TIME.LT.TC2)SX=ABS(SW1-1.)


V01=VA1

IF(SX.GT.0.5)V01=VB1

RETURN

END

7.40 TWO POLE SWITCH



SEE SW FOR SWITCH CONTROL LOGIC

Inputs

<u>Parameter/Port</u>	<u>Description</u>
VA1	Input to switch 1
VA2	Input to switch 2
VB1	Input to switch 1
VB2	Input to switch 2
SW1	Switch control parameter
TC1	Time for first switching (hours)
TC2	Time for second switching (hours)

Outputs

<u>Variable/Port</u>	
V01	Output from switch 1
V02	Output from switch 2

CSX

SUBROUTINE SX(V01,V02,VA1,VA2,VB1,VB2,SW1,TC1,TC2)

PURPOSE - TO PROVIDE A SWITCH COMPONENT FOR TWO VARIABLES

METHOD - SEE CODING

WRITTEN BY - ADAM LLOYD

LATEST REVISION

NOV 75

LIMITATIONS - NOT MORE THAN TWO SWITCHINGS AT TIMES TC1 AND TC2

INPUT/OUTPUT LIST

V01	OUTPUT VARIABLE NO 1	ANY	OUTPUT	VAR
V02	OUTPUT VARIABLE NO 2	ANY	OUTPUT	VAR
VA1	INPUT VARIABLE NO A1	ANY	INPUT	VAR
VA2	INPUT VARIABLE NO A2	ANY	INPUT	VAR
VB1	INPUT VARIABLE NO B1	ANY	INPUT	VAR
VB2	INPUT VARIABLE NO B2	ANY	INPUT	VAR
SW1	SWITCH CONTROL INITIAL VALUE	---	INPUT	PARAM
	=1. V0=VB			
	=0. V0=VA			
TC1	TIME FOR FIRST SWITCH	SECS	INPUT	PARAM
TC2	TIME FOR SECOND SWITCH	SECS	INPUT	PARAM
	(TC2.GT.TC1)			

COMMON/CTIME/TIME

COMMON/CIO/IREAD,IWRITE,IDIAG

SW=SW1

IF(TIME.GT.TC1.AND.TIME.LT.TC2)SW=ABS(SW1-1.)

V01=VA1

V02=VA2


IF(SW.GT.0.5)V01=VB1

IF(SW.GT.0.5)V02=VB2

RETURN

END

7.41 THREE POLE SWITCH



SEE SW FOR SWITCH CONTROL LOGIC

Inputs

<u>Parameter/Port</u>	<u>Description</u>
VA1	Input to switch 1
VA2	Input to switch 2
VA3	Input to switch 3
VB1	Input to switch 1
VB2	Input to switch 2
VB3	Input to switch 3
SW1	Switch control parameter
TC1	Time for first switching (hours)
TC2	Time for second switching (hours)

Outputs

<u>Variable/Port</u>	
V01	Output from switch 1
V02	Output from switch 2
V03	Output from switch 3

CSY

SUBROUTINE SY(V01,V02,V03,VA1,VA2,VA3,VB1,VB2,VB3,SW1,TC1,TC2)

PURPOSE - TO PROVIDE A SWITCH COMPONENT FOR THREE VARIABLES

METHOD - SEE CODING

WRITTEN BY - ADAM LLOYD

LATEST REVISION

NOV 75

LIMITATIONS - NOT MORE THAN TWO SWITCHINGS AT TIMES TC1 AND TC2

INPUT/OUTPUT LIST

V01	OUTPUT VARIABLE NO 1	ANY	OUTPUT	VAR
V02	OUTPUT VARIABLE NO 2	ANY	OUTPUT	VAR
V03	OUTPUT VARIABLE NO 3	ANY	OUTPUT	VAR
VA1	INPUT VARIABLE NO A1	ANY	INPUT	VAR
VA2	INPUT VARIABLE NO A2	ANY	INPUT	VAR
VA3	INPUT VARIABLE NO A3	ANY	INPUT	VAR
VB1	INPUT VARIABLE NO B1	ANY	INPUT	VAR
VB2	INPUT VARIABLE NO B2	ANY	INPUT	VAR
VB3	INPUT VARIABLE NO B3	ANY	INPUT	VAR
SW1	SWITCH CONTROL INITIAL VALUE	---	INPUT	PARAM
	=1. V0=VB			
	=0. V0=VA			
TC1	TIME FOR FIRST SWITCH	SECS	INPUT	PARAM
TC2	TIME FOR SECOND SWITCH	SECS	INPUT	PARAM
	(TC2.GT.TC1)			

COMMON/CTIME/TIME

COMMON/CIO/IREAD,IWRITE,IDIAG

SW=SW1

V01=VA1

V02=VA2

V03=VA3

IF(TIME.GT.TC1.AND.TIME.LT.TC2)SW=ABS(SW1-1.)

IF(SW.GT.0.5)V01=VB1


IF(SW.GT.0.5)V02=VB2

IF(SW.GT.0.5)V03=VB3

RETURN

END

7.42 FOUR POLE SWITCH



SEE SW FOR SWITCH CONTROL LOGIC

Inputs

<u>Parameter/Port</u>	<u>Description</u>
VA1	Input to switch 1
VA2	Input to switch 2
VA3	Input to switch 3
VA4	Input to switch 4
VB1	Input to switch 1
VB2	Input to switch 2
VB3	Input to switch 3
VB4	Input to switch 4
SW1	Switch control parameter
TC1	Time for first switching (hours)
TC2	Time for second switching (hours)

Outputs

<u>Variable/Port</u>	
V01	Output from switch 1
V02	Output from switch 2
V03	Output from switch 3
V04	Output from switch 4

CS2

SUBROUTINE SZ(V01,V02,V03,V04,VA1,VA2,VA3,VA4,VB1,VB2,VB3,VB4,
1 SW1,TC1,TC2)

PURPOSE - TO PROVIDE A SWITCH COMPONENT FOR FOUR VARIABLES

METHOD - SEE CODING

WRITTEN BY - ADAM LLOYD

LATEST REVISION

NOV 75

LIMITATIONS - NOT MORE THAN TWO SWITCHINGS AT TIMES TC1 AND TC2

INPUT/OUTPUT LIST

V01	OUTPUT VARIABLE NO 1	ANY	OUTPUT	VAR
V02	OUTPUT VARIABLE NO 2	ANY	OUTPUT	VAR
V03	OUTPUT VARIABLE NO 3	ANY	OUTPUT	VAR
V04	OUTPUT VARIABLE NO 4	ANY	OUTPUT	VAR
VA1	INPUT VARIABLE NO A1	ANY	INPUT	VAR
VA2	INPUT VARIABLE NO A2	ANY	INPUT	VAR
VA3	INPUT VARIABLE NO A3	ANY	INPUT	VAR
VA4	INPUT VARIABLE NO A4	ANY	INPUT	VAR
VB1	INPUT VARIABLE NO B1	ANY	INPUT	VAR
VB2	INPUT VARIABLE NO B2	ANY	INPUT	VAR
VB3	INPUT VARIABLE NO B3	ANY	INPUT	VAR
VB4	INPUT VARIABLE NO B4	ANY	INPUT	VAR
SW1	SWITCH CONTROL INITIAL VALUE	---	INPUT	PARAM
	=1. VO=VB			
	=0. VO=VA			
TC1	TIME FOR FIRST SWITCH	SECS	INPUT	PARAM
TC2	TIME FOR SECOND SWITCH	SECS	INPUT	PARAM
	(TC2.GT.TC1)			

COMMON/CTIME/TIME

COMMON/CIO/IREAD,IWRITE,IDIAG

SW=SW1

IF(TIME.GT.TC1.AND.TIME.LT.TC2)SW=ABS(SW1-1.)

V01=VA1

V02=VA2

V03=VA3

V04=VA4

IF(SW.GT.0.5)V01=VB1

IF(SW.GT.0.5)V02=VB2


IF(SW.GT.0.5)V03=VB3

IF(SW.GT.0.5)V04=VB4

RETURN

END

7.43 SECOND ORDER TRANSFER FUNCTION



Inputs

<u>Parameter/Port</u>	<u>Description</u>
F_{IN}	Input quantity
Z_0	Numerator coefficient
Z_1	Numerator coefficient
P_0	Denominator coefficient
P_1	Denominator coefficient

Outputs

<u>Variable/Port</u>	
X_1	Intermediate state
F_0	Output quantity (state)

Calculation Sequence

$$\begin{aligned} X_1 &= Z_0 * F_{IN} - P_0 * F_0 \\ F_0 &= X_1 + Z_1 * F_{IN} - P_1 * F_0 \end{aligned}$$

NOTE: d.c. gain = $\frac{Z_0}{P_0}$; infinite frequency gain = 0.

CTF

SUBROUTINE TF(X1,XIDOT,IX1,FO,FODOT,IFO,FIN,ZO,Z1,PO,P1)

PURPOSE - TO SIMULATE A SECOND ORDER TRANSFER FUNCTION WITH
FIRST ORDER NUMERATOR

$$\frac{FO}{FIN} = \frac{Z1*S + ZO}{S^2 + P1*S + P0}$$

METHOD - SELF EXPLANATORY

LIMITATIONS - NONE

WRITTEN BY ADAM LLOYD

LATEST REVISION NOV 75

INPUT/OUTPUT LIST

X1	INTERMEDIATE STATE VARIABLE	ANY	OUTPUT STATE
XIDOT	STATE VARIABLE DERIVATIVE	ANY	OUTPUT STATE
IX1	INTEGRATOR CONTROL	---	PROGRAM VAR
FO	TRANSFER FUNCTION OUTPUT	ANY	OUTPUT STATE
FODOT	TRANSFER FUNCTION OUTPUT DERIV.	ANY	OUTPUT STATE
IFO	INTEGRATOR CONTROL	---	PROGRAM VAR
FIN	TRANSFER FUNCTION INPUT	ANY	INPUT VAR
ZO	NUMERATOR COEFFICIENT	ANY	INPUT VAR
Z1	NUMERATOR COEFFICIENT	ANY	INPUT VAR
PO	DENOMINATOR COEFFICIENT	1/SEC2	INPUT VAR
P1	DENOMINATOR COEFFICIENT	1/SEC	INPUT VAR

COMMON/CID/IREAD,IWRITE,IDIAG


IF(IX1.NE.0)XIDOT=ZO*FIN-PO*FO

IF(IFO.NE.0)FODOT=X1+Z1*FIN-P1*FO

RETURN

END

7.44 TIME CONVERSION



Converts simulation running time in hours to time referenced to start of day and start of week, and computes number of days and weeks elapsed since start of year.

Inputs

<u>Parameter/Port</u>	<u>Description</u>	<u>Units</u>
TO	Initial time of simulation from start of year	hrs
TIME	Running time (input via common/CTIME)	hrs

Outputs

<u>Variable/Port</u>		
TW	Time since start of week	hrs
TD	Time since start of day	hrs
WY	Number of weeks	-
DY	Number of days	-
MY	Number of months (approx.)	-
T	Running time from start of year	hrs
DW	Day of week	-

Calculation Sequence

$$\begin{aligned}
 T &= \text{AMOD}(TO + \text{TIME}, 8760) & TW &= \text{AMOD}(T, 168) \\
 WY &= T / 168 + 1 & TD &= \text{AMOD}(T, 24) \\
 DY &= T / 24 + 1 & DW &= TW / 24 + 1 \\
 MY &= T / 730 + 1
 \end{aligned}$$

CTI

SUBROUTINE TI(T,TD,TW,DW,DY,WY,AMY,TO)

PURPOSE CONVERT SIMULATION TIME TO DAILY, WEEKLY, MONTHLY UNITS

WRITTEN BY A.W. WARREN

VERSION 1, MARCH 3 197

CALL SEQUENCE

T	- SIMULATION TIME FROM START OF YEAR, HR	OUTPUT V
TD	- TIME OF DAY, HR	OUTPUT V
TW	- TIME SINCE START OF WEEK, HR	OUTPUT V
DW	- DAY OF WEEK	OUTPUT V
DY	- DAY OF YEAR	OUTPUT V
WY	- WEEK OF YEAR	OUTPUT V
AMY	- MONTH OF YEAR (APPROX.)	OUTPUT V
TO	- SIMULATION INITIAL TIME FROM START OF YEAR, HR	INPUT PA

COMMON / CTIME / TIME

DATA EPS/ .000001/

T = AMOD(TO+TIME,8760.+EPS)

TD = AMOD(T+EPS,24.)

TW = AMOD(T+EPS,168.)

ND = TW/24.+1.001

DW = ND

ND = T/24.+1.001

DY = ND

NW = T/168.+1.001

WY = NW


MY = T/730.+1.001

AMY = MY

RETURN

END

7.45 THERMAL LOAD



Thermal load is computed as a user specified function of ambient temperature and time of day. The actual load delivered is either the load requested or the maximum discharge rate of the thermal storage chamber. The value of the thermal energy delivered and % of total load actually delivered are also computed.

Basic Equation

$$RE = TL\emptyset(TA) * TWT(TD) * NC$$

where

$TL\emptyset$ = Thermal load versus temperature table

TWT = Daily profile weighting function

NC = Normalizing constant

Tables

TL0

Thermal load versus ambient temperature

Units

kw

TWT

Daily profile weighting function (tabular with time of day)

Inputs

Parameter/Port

TA

Ambient temperature

°F

LD

Power delivered

kw

TD

Time of day (0-24)

h

VE

Value of thermal energy

\$/kwh

NC

Normalizing constant

Outputs

Variable/Port

RE

Load request

kw

VDE

Total value of energy delivered (state)

\$

Statistics

PC

Cumulative percent of load delivered

-

SLD

Total energy delivered

kwh

SRE

Total energy requested

kwh

Calculation Sequence

1) Compute load request

$$RE = TLQ(TA)*TWT(TD)*NC$$

2) Value of energy dynamics

$$\dot{VDE} = LD*VE$$

3) Statistics

$$SLD = SLD + LD * \Delta / 2$$

$$SRE = SRE + RE * \Delta / 2$$

$$PC = 100. * SLD / SRE$$

where Δ = integration step size

CTL

SUBROUTINE TL(TLO,TWT,VDE,DVD,IVD,RE,PC,SLD,SRE,TA,LD,TD,VE,NC)

PURPOSE COMPUTE ENERGY RESPONSE FROM A THERMAL LOAD REQUEST

METHOD ENERGY DELIVERED IS EQUAL TO THE LOAD REQUESTED OR
THE MAXIMUM DISCHARGE RATE.

WRITTEN BY F. O. MAHONY

VERSION 1, APRIL 1 1977

CALL SEQUENCE

TABLES

TLO - THERMAL LOAD AS FUNCTION OF AMBIENT TEMPERATURE

TWT - DAILY PROFILE WEIGHTING FUNCTION VS TIME OF DAY

OUTPUTS

VDE - VALUE OF ENERGY DELIVERED (STATE), \$

DVD - DERIVATIVE OF VDE

IVD - INDICATOR FOR VDE

RE - LOAD REQUEST, KW

PC - CUMULATIVE PERCENT OF LOAD DELIVERED

SLD - TOTAL ENERGY DELIVERED, KWH

SRE - TOTAL ENERGY REQUESTED, KWH

INPUTS

TA - AMBIENT TEMPERATURE, DEG F

LD - POWER DELIVERED, KW

TD - TIME OF DAY, HR

VE - VALUE OF THERMAL ENERGY, \$/KWH

NC - NORMALIZING CONSTANT FOR LOAD REQUEST

DIMENSION TLO(3),TWT(5)

COMMON/CIMPL/IMPL /CSIMUL/ DUM(6),TINC,TMAX/CTIME/TIME

COMMON/COST /CC,CM,CO,CV,CLO,CRE

REAL LD,NC

ITL=TLO(2)

ITW=TWT(2)

IF(IMPL.GT.0)GO TO 100

TMAX1=TMAX*0.99999

TINC1=TINC*.5

PC =0.0

SLD=0.0

SRE=0.0

COMPUTE LOAD REQUEST

100 TLD=TBLU1(TA,TLO(4),TLO(ITL+4),1,-ITL)

TW=TBLU1(TD,TWT(4),TWT(ITW+4),1,-ITW)

RE =TLD*TW*NC

VALUE OF ENERGY

C IF(IVD.NE.0)DVD=LD*VE

C IF(IMPL.LE.1)RETURN

C
C PERFORMANCE STATISTICS

C SLD=SLD+LD*TINC1

C SRE=SRE+RE*TINC1

C IF(SRE.GT.0.0)PC=100.0*SLD/SRE

C IF(TIME.LT.TMAX1)RETURN

C CV=CV+VDE


C CLD=CLD+SLD-LD*TINC1

C CRE= CRE+ SRE-RE*TINC1

C RETURN

END

7.46 AMBIENT TEMPERATURE



This component is very similar to the wind component. Ambient temperature is output either from user supplied time histories on storage files or by generating a set of random numbers with user specified random variations. If user supplied profiles are available, then the temperatures are generated from the following equation:

$$TA2 = [PD(TD) + CN(t)] * PY(WY) / M0$$

where PD and PY are the user supplied daily and weekly profiles, TD and WY are the time of the day and week of the year, CN is a colored noise term and M0 is the average value of PY:

$$M0 = \frac{1}{J} \sum_{j=1}^J PY(j)$$

<u>Tables</u>	<u>Description</u>	<u>Units</u>
PD	Daily profile versus TD	°F
PY	Yearly profile versus WY	arbitrary

Inputs

Parameter/Port

TA	1	Ambient temperature data file	°F
TD		Time of day	hr
WY		Week of the year	-
CT		Correlation time of colored noise	hr
MN		Mean temperature of colored noise	°F
STD		Standard deviation of colored noise	°F

Outputs

Variable/Port

CN		Colored noise sample	°F
TA	2	Ambient temperature	°F
AV		Mean of daily temperature	°F
MO		Mean of yearly profile	
TIM		Last time a random sample was generated	hr

Calculation Sequence

1) Initialization (first pass only)

Compute AV, MO, and initial CN

$$AV = MN + \frac{1}{N} \sum_{j=1}^N PD(j)$$

2) Check for data file input

If TA1 = .99999 go to 3)

TA2 = TA1

Return

3) Generate colored noise sample CN

If TIME = TIM RETURN

$$A = \begin{cases} \text{EXP}(-TINC/CT) & CT > 0 \\ 0. & CT = 0 \end{cases}$$

where TINC = integration step size

$$CN = CN * A + W$$

Where W is white noise with mean = $MN*(1-A)$ and

$$\text{standard deviation} = \text{STD} * \sqrt{1-A^2}$$

TIM = TIME

4) Compute Temperature

$$TA2 = (PD(TD) + CN) * PY(WY) / MO$$

CTP

SUBROUTINE TP (PD,PY,TAO,AV,XM,TIMO,XN, TAI, TD,WY,CT,XMN,STD)

PURPOSE GENERATE AMBIENT TEMPERATURE FROM DAILY, YEARLY AND RANDOM L

METHOD COLORED NOISE WITH SPECIFIED PARMS IS ADDED TO A MEAN DAILY PROFILE AND MULTIPLIED BY A YEARLY PROFILE.

WRITTEN BY A.W. WARREN

VERSION 1, MARCH 7 197

CALL SEQUENCE

TABLES

PD - MEAN DAILY PROFILE, DEG.F

PY - MEAN YEARLY PROFILE, DEG.F

OUTPUTS

TAO - AMBIENT TEMPERATURE OUTPUT, DEG.F

AV - MEAN DAILY TEMPERATURE, DEG.F

XM - MEAN YEARLY TEMPERATURE, DEG.F

TIMO- LAST TIME COLORED NOISE WAS USED, HR

XN - COLORED NOISE SAMPLE, DEG.F

INPUTS

TAI - TEMPERATURE INPUT FROM DATA FILE, DEG.F

TD - TIME OF DAY, HR

WY - WEEK OF YEAR (1-52)

CT - CORRELATION TIME FOR COLORED NOISE, HR

XMN - MEAN TEMPERATURE OF COLORED NOISE, DEG.F

STD - STANDARD DEVIATION OF COLORED NOISE, DEG.F

DIMENSION PD(1),PY(1)

COMMON/CIMPL/IMPL /CSIMUL/DUM(6),TINC /CTIME/TIME

DATA AX /.99999/

INITIALIZATION

ND=PD(2)

NY=PY(2)

IF(IMPL.GT.0) GO TO 10

TIMO=-1.

CALL RN(XN,AX,STD,XMN)

AV = 0.

DO 20 I=1,ND

L = 3+ND+I

20 AV = AV + PD(L)

AV = AV/ND +XMN

ORIGINAL PAGE IS
OF POOR QUALITY

XM=0.

DO 30 I=1,NY

L=3+NY+I

30 XM=XM+PY(L)

XM=XM/NY

CHECK FOR DATA FILE INPUT

10 IF(TAI.EQ. .99999) GO TO 100

TAO = TAI

GO TO 150

GENERATE COLORED NOISE SAMPLE XN

```

100 IF( TIMC.EQ.TIME) GO TO 150
    A=0.
    IF(CT.GT.0.) A=EXP(-TINC/CT)
    WMN = XMN*(1.-A)
    WSD = STD*SQRT(1.-A*A)
    CALL RN(W,AX,WSD,WMN)
    XN = A*XN+W

```

C
C

COMPUTE AMBIENT TEMPERATURE

```

DTP = TBLU1(TD,PD(4),PD(4+ND),1,-ND)
YTP = TBLU1(WY,PY(4),PY(4+NY),1,-NY)
TAO = (DTP + XN)*YTP/ XM
TIMO=TIME

```


C

```

150 RETURN
    END

```

7.47 VARIABLE RATIO TRANSMISSION



This component models a transmission which couples a fixed speed rotor input (or output) to a variable speed rotor output (or input) component. Power losses are modeled as a table lookup depending on gear ratio and input power.




FIGURE 7.47 TRANSMISSION MODEL - LOOKUP TABLE

Tables

PLØ

Description

Power loss versus input power and gear ratio (TABLE DIMENSION = 66)

Units

kw

Inputs

Parameter/Port

RS	1	Input rotor speed	
RS	2	Output rotor speed	rpm
P	1	Input power	rpm
EF	1	Input product efficiency	kw
MP	1	Maximum input power	-
CC		Capital cost/year	kw
CM		Maintenance cost/year	\$
			\$

Outputs

Variable/Port

P	2	Output power	
TØ		Output torque	kw
PL		Power loss	ft-lb
EF	2	Output product efficiency	kw
MP	2	Maximum power output	-
			kw

Calculation Sequence

If $P1 \leq 0$ or $RS1 \leq 0$ set $P2 = T0 = PL = 0$ and go to 4)

1) Determine gear ratio and power terms

$$GR = RS2/RS1$$

$$PL = PL0(P1, GR)$$

$$P2 = P1 - PL$$

2) Determine output torque

$$T0 = P2 * 737.6 / (RS2 * (2 \pi / 60))$$

3) Efficiency and maximum power

$$EF2 = EF1 * (P2 / P1)$$

If $P2 \leq 0$, set $EF2 = EF1$ and write Diagnostic

$$MP2 = MP1 - PL0(MP1, GR)$$

$$MP2 \leq 0 \Rightarrow \text{DIAGNOSTIC}$$

4) Compute Costs

CTR

SUBROUTINE TR(PLU,P2,TO,PL,EF2,MP2,RS1,RS2,P1,EF1,MP1,CC,CM)

PURPOSE TRANSMISSION MODEL

METHOD OUTPUT POWER AND TORQUE COMPUTED FROM
INPUT AND OUTPUT ROTOR SPEEDS. POWER
LOSS MODELED BY TABLE LOOKUP DEPENDING
ON GEAR RATIO AND INPUT POWER

WRITTEN BY Y.K.CHAN

VERSION 1, JUNE 17, 1977

CALL SEQUENCE

TABLES

PLO -POWER LOSS VERSUS INPUT POWER AND GEAR RATIO ,KW

OUTPUTS

P2 -OUTPUT POWER,KW

TO -OUTPUT TORQUE,FT-LB

PL -POWER LOSS,KW

EF2 -OUTPUT PRODUCT EFFICIENCY

MP2 -MAXIMUM POWER OUTPUT,KW

INPUTS

RS1 -INPUT ROTOR SPEED,RPM

RS2 -OUTPUT ROTOR SPEED,RPM

P1 -INPUT POWER,KW

EF1 -INPUT PRODUCT EFFICIENCY

MP1 -MAXIMUM INPUT POWER,KW

CC -CAPITOL COST/YEAR,\$

CM -MAINTENANCE COST/YEAR,\$

COMMON/CIMPL/IMPL,ICNT/CTIME/TIME/CSIMUL/DUM(7),TMAX
X /COST/CCI,CMI

REAL MP2,MP1

DIMENSION PLO(1)

IF(IMPL.GT.0)GO TO 10

TMAX1=TMAX*.99999

RS2=RS1

10 CONTINUE

NNGR=PLO(3)

NNP1=PLO(2)

M4=NNGR+4

MN4=NNP1+M4

COMPUTE GEAR RATIO AND POWER TERMS

P2=0.

TO=0.

PL=0.

EF2=EF1

MP2=MP1

100 IF((RS1.LE.0.).OR.(P1.LE.0.))GO TO 400

P2=P1


200 IF(RS2.LE.0)GO TO 400

300 GR=RS2/RS1

PL=TBLU2(P1,GR,PLO(M4),PLO(4),PLO(MN4),1,1,-NNP1,-NNGR,NNP1,NNGR)

P2=P1-PL

7.48 THERMAL STORAGE CHAMBER



The thermal storage chamber is modeled by a "lumped" parameter approach. The entire storage media mass is characterized by a single temperature (no temperature gradient). The storage media is either a sensible heat or a phase change media. Energy is input via electrical resistance heaters and withdrawn by a heat exchanger. Energy is deposited in the media at a rate equal to the available electrical power up to a maximum charging power. The discharge heat exchanger fluid mass flow rate is adjusted to provide the desired heat load demand. The maximum mass flow rate condition determines the maximum thermal load. The maximum energy limit represents the point where the maximum media temperature is reached.

The model initially calculates the required storage media mass to provide the rated thermal energy storage (design point). Cost calculations are also made on the design point conditions. Initial checks on charge and discharge power and initial stored energy level are made. The storage temperature is determined based on the energy level.

Note: An example case discussing parameter specification for TS is provided on page 54, Reference [1].

Basic Equation

$$\dot{E} = P - LD - NU \cdot E$$

<u>Tables</u>		<u>Description</u>	<u>Units</u>
HT		Media temperature versus enthalpy in KWH/LB ¹	°F
<u>Inputs</u>			
<u>Parameter/Port</u>			
P		Input power	kw
RE	1	Demand thermal load	kw
NU		Stored energy loss coefficient (D = 0.02)	(h) ⁻¹
TS		Rated storage time ²	h
VØ		Rated input voltage ²	V
TM1		Maximum allowable storage temperature (D = 212)	°F
TØ1		Minimum allowable storage temperature (D = 60)	°F
DH		Design point enthalpy	kwh/lb
PD		Rated storage thermal power ²	kw
PM		Maximum charge rate (D = 2*PD)	kw
MFM		Maximum working fluid mass flow rate (D = 9000)	lb/h
TDE		Temperature deadband for priority resequence (D = 4)	°F
EF	1	Input product efficiency	-
MP	1	Maximum input charging rate (D = 1.X10 ⁸)	kw
CP2		Working fluid heat capacity (D = 2.93X10 ⁻⁴)	kwh/lb-°F
TØ2		Working fluid return temperature (D = 40)	°F
TM2		Maximum allowable working fluid temperature (D = 212)	°F
R		Effective heat exchanger thermal resistance (D = 3.08X10 ⁻⁴)	°F/kw
CM		Storage device yearly maintenance cost (D = 0.6)	\$/kw
CSA		Storage device capacity cost (D = 50)	\$/kw
CSB		Storage device energy cost (D = 15.2)	\$/kwh
LE		Unit life expectancy	years

D - Default values specified

1 - See Figure 7.48

2 - Design point conditions

Outputs

Variable/Port	Description	Units
E	Stored energy (state)	kwh
I	Input current	amps
MP 2	Maximum discharge rate allowable	kw
INT	Priority interrupt flag	-
T	Storage temperature	°F
M	Required storage media mass	lb
CC0	Storage device capital cost/year	\$
RE 2	Maximum charging rate request	kw
MF	Working fluid mass flow rate	lb/h
LD	Power Delivered	kw

Statistics

TSU	Maximum storage temperature	°F
TSL	Minimum storage temperature	°F
ME	Maximum stored energy	kwh
MFU	Maximum working fluid mass flow rate	lb/h




FIGURE 7.48: TEMPERATURE - ENTHALPY DIAGRAM

The calculation sequence and default values assume a thermal storage device sized to provide 10kw for 24 hours. A paraffin wax phase change storage medium is assumed. Water is assumed as the thermal transport fluid. Costs are assumed to be given by data for the phase change storage device given in Reference 1. The thermal resistance value, R, is assumed equal to that determined for the device of Reference 1. The value for the maximum charging rate, PM, reflects the acceptance of twice the design charge rate. The actual numbers which should be used will depend on specific design and performance requirements obtained from a desired application.

Calculation Sequence

- 1) Media mass, capital cost, maintenance cost (first pass)

$$M = \frac{PD \cdot TS}{DH}$$

$$CC = (CSA + CSB \cdot TS) \cdot PD / LE$$

$$CM = CM \cdot PD$$

- 2) Storage Temperature and Working Fluid Temperature

$$T = HT(E/M)$$

$$TF = \min\{TM2, \max[T02, T - RE1 \cdot R]\}$$

$$E2 = M \cdot HT^{-1}(TM1)$$

-
1. "Advanced Thermal Energy Storage," BEC/EPRI RP 788-1, July 1976.

Calculation Sequence Cont.

3) Discharge Rate and Thermal Load

$$E1 = M*HT^{-1}(T01)$$

$$MP2 = MFM*CP2*(TF-T02)$$

$$LD = \min(RE1, MP2, (E-E1)/TINC)$$

$$MF = LD/(CP2*(TF-T02))$$

4) Diagnostic Checks

$$MF \leq MFM$$

$$P \leq PM$$

$$T01 \leq T \leq TM1$$

5) Current calculations

$$I = \frac{P*1000}{V0}$$

6) Energy dynamics

$$\dot{E} = P - LD - NU*E$$

7) Maximum Charging Rates

$$RE2 = \min(PM, MP1, (E2-E)/TINC)/EF1$$

where TINC = integration step size

Calculation Sequence Cont.

8) Priority resequencing

```

if  $T \leq T01$ ,  $INT = 1$ 
if  $T \geq T01 + TDE$  and  $INT=1$ ,  $INT=0$ 
if  $T \geq TM1$ ,  $INT=-1$ 
if  $T < TM1 - TDE$  and  $INT=-1$ ,  $INT=0$ 

```

9) Compute Statistics and Costs

CTS

```

SUBROUTINE TS(HT,E,DE,IE,I,MP2,INT,T,M,CCO,RE,MF,LD
1      ,TSU,TSL,ME,MFU,P,RE1,NU,TSO,VO,TM1,TO1,DH,PD,PM,
2      MFM,TDE,EF1,MP1,CP2,TO2,TM2,R,CM,CSA,CSB
3      ,LE)

```

PURPOSE COMPUTE ENERGY CONTAINED IN A THERMAL STORAGE MEDIA

METHOD A PHASE CHANGE OR SENSIBLE HEAT MEDIA IS MODELED AS
A SINGLE TEMPERATURE MASS WITH NO GRADIENTS.

WRITTEN BY F. O. MAHONY

VERSION 2, JULY, 1977

CALL SEQUENCE

TABLE

HT - MEDIA TEMPERATURE VERSUS ENTHALPY IN KWH/LB, DEG F

OUTPUTS

E - STORED ENERGY (STATE VARIABLE), KWH
DE - POWER INTO STORAGE, KW
IE - STATUS INDICATOR
I - INPUT ELECTRIC CURRENT, KW
MP2 - MAXIMUM DISCHARGE RATE ALLOWABLE, KW
INT - PRIORITY FLAG INTERRUPT
T - STORAGE TEMPERATURE, DEG F
M - REQUIRED STORAGE MEDIA MASS, LB
CCO - STORAGE DEVICE CAPITAL COST/YEAR, \$
RE - MAXIMUM CHARGING RATE REQUEST, KW
MF - WORKING FLUID MASS FLOW RATE, LB/HR
LD - THERMAL LOAD DELIVERED, KW
TSU - MAXIMUM STORAGE TEMPERATURE, DEG F
TSL - MINIMUM STORAGE TEMPERATURE, DEG F
ME - MAXIMUM STORED ENERGY, KWH
MFU - MAXIMUM WORKING FLUID MASS FLOW RATE, LB/HR

INPUTS

P - INPUT POWER, KW
RE1 - THERMAL DISCHARGE REQUEST, KW
NU - STORAGE ENERGY LOSS COEFFICIENT, 1/HR
TSO - RATED STORAGE TIME, HR
VO - RATED INPUT VOLTAGE, VOLTS
TM1 - MAXIMUM ALLOWABLE STORAGE TEMPERATURE, DEG F
TO1 - MINIMUM ALLOWABLE STORAGE TEMPERATURE, DEG F
PD - RATED STORAGE THERMAL POWER, KW
DH - DESIGN POINT ENTHALPY, KWH/LB
PM - MAXIMUM CHARGE RATE, KW
MFM - MAXIMUM WORKING FLUID MASS FLOW RATE, LB/HR
TDE - TEMPERATURE DEADBAND FOR PRIORITY RESEQUENCE, DEG F
EF1 - INPUT PRODUCT EFFICIENCY
MP1 - MAXIMUM INPUT CHARGING RATE, KW
CP2 - WORKING FLUID HEAT CAPACITY, KWH/LB-F
TO2 - WORKING FLUID RETURN TEMPERATURE, DEG F
TM2 - MAXIMUM ALLOWABLE WORKING FLUID TEMPERATURE, DEG F
R - EFFECTIVE HEAT EXCHANGER THERMAL RESISTANCE, F/KW
CM - STORAGE DEVICE YEARLY MAINTENANCE COST, \$/KW
CSA - STORAGE DEVICE CAPACITY COST, \$/KW
CSB - STORAGE DEVICE ENERGY COST, \$/KWH
LE - UNIT/LIFE FILE EXPECTANCY, YEARS

COMMON/CIMPL/IMPL,ICN/CTIME/TIME /CSIMUL/DUM(7),TMAX /COST/CCI,CMI
 REAL NU,I,MP2,INT,MF,LD,ME,MFU,MFM,MP1,LE,M
 DIMENSION HT(1)

IF(IMPL.GT.0)GO TO 100
 TMAX1=TMAX*.99999
 TINC=DUM(7)

IF(NU.EQ. .99999)NU=0.02
 IF(TM1.EQ. .99999)TM1=212.0
 IF(TU1.EQ. .99999)TU1=60.0
 IF(PM.EQ. .99999) PM=2.0*PD
 IF(MFM.EQ. .99999)MFM=9000.0
 IF(TDE.EQ. .99999)TDE=4.0
 IF(CP2.EQ. .99999)CP2=2.93E-4
 IF(TO2.EQ. .99999)TO2=40.0
 IF(TM2.EQ. .99999)TM2=212.0
 IF(R.EQ. .99999)R =3.08E-4
 IF(CM.EQ. .99999)CM =0.6
 IF(CSA.EQ. .99999)CSA=50.0
 IF(CSB.EQ. .99999)CSB=15.2
 IF(MP1.EQ. .99999) MP1= 1.0E6

INT=0.0
 RE1=0.0

TSU=0.0
 ME =0.0
 MFU=0.0
 TSL=1.0E6
 CM= CM*PD

M =PD*TSU/DH
 CCO=(CSA+CSB*TSU)*PD/LE

COMPUTE STORAGE TEMPERATURE

100 NH=HT(2)
 T=TB LUI(E/M,HT(4),HT(4+NH),1,NH)
 E1=M*TB LUI(TM1,HT(4+NH),HT(4),1,NH)

WORKING FLUID TEMPERATURE

TF =AMIN1(TM2,AMAX1(TO2,T-RE1*R))

MAXIMUM DISCHARGE RATE AND THERMAL LOAD

MP2=MFM*CP2*(TF-TO2)
 IF(INT.EQ.1.)MP2=0.
 LD =AMIN1(RE1,MP2)

WORKING FLUID MASS FLOW RATE

IF(LD.GT.0.0) MF =LD/CP2/(TF-TO2)

IF(IMPL.LE.1)GO TO 200

ORIGINAL PAGE IS
 OF POOR QUALITY

```
IF(IMPL.GT.2) GO TO 200
PM1= PM/.9999
```

```
IF(MF .GT.MFM)WRITE(6,1010)MF,MFM
IF(P .GT.PM1 )WRITE(6,1020)P ,PM
IF(MF.GT.MFM .OR. P.GT.PM1)ICN=ICN+1
IF(T .LT.T01.OR.
1 T .GT.TM1)WRITE(6,1030)T,T01,TM1
IF(T.LT.T01 .OR. T.GT.TM1) ICN=ICN+1
```

CURRENT CALCULATION

```
200 I =P*1000.0/V0
```

ENERGY STATE

```
IF(IE.NE.0)DE=P-LD-NU*E
```

MAXIMUM CHARGING RATE REQUEST

```
A=AMAX1(E1-E,0.)/TINC
RE =AMIN1(PM,MP1,A)/EF1
```

PRIORITY RESEQUENCING

```
IF(T.LE.T01)INT=1.0
```

```
IF(T.GE.(T01+TDE).AND.
1 INT.EQ.1.)INT=0.0
```

```
IF(T.GE.TM1)INT=-1.0
```

```
IF(T.LT.(TM1-TDE).AND.
1 INT.EQ.-1.)INT=0.0
```

```
IF(IMPL.LE.1)RETURN
```

```
TSU=AMAX1(TSU,T)
TSL=AMIN1(TSL,T )
ME =AMAX1(ME ,E )
MFU=AMAX1(MFU,MF)
IF(TIME.LT.TMAX1)RETURN
```

COST

```
CMI=CMI+CM
CCI=CCI+CCD
CM = CM/PD
```

```
RETURN
```

```
1010 FORMAT(1H0,26HTS WORKING FLUID FLOW RATE,F12.3
```

```
1 ,32H GREATER THAN MAXIMUM ALLOWED,F12.3)
```

```
1020 FORMAT(1H0,14HTS INPUT POWER,F12.3
```

```
1 ,44H GREATER THAN MAXIMUM ALLOWED CHARGE RATE,F12.3)
```


```
1030 FORMAT(1H0, 23HTS STORAGE TEMPERATURE ,F12.3
```

```
1 ,20H OUTSIDE MINIMUM ,F12.3
```

TS

C 2 ,15H AND MAXIMUM,F12.3)
END

7.49 TURBINE (PNEUMATIC)



The turbine model is based on a high pressure ratio, constant angular velocity design. The turbine is assumed to be designed to a set of operating conditions defined in terms of user specified parameters. The polytropic efficiency is only weakly related to angular velocity. Initial calculations are made with the design polytropic efficiency, and refinements are then computed after off-design parameters are calculated.

Basic Equation

The equation for output power P2 is

$$P2 = M * CP * (T1 - TA)$$

Inputs

<u>Parameter/Port</u>	<u>Description</u>	<u>Units</u>
M	Inlet mass flow rate	lb/h
CP	Air heat capacity ($D = 7.2 \times 10^{-5}$)	kwh/lb/°F
T	1 Input air temperature	°F
TA	Ambient air temperature	°F
MD	Design mass flow rate ($D = 4800$)	lb/h
TID	Design inlet air temperature ($D = 600$)	°F
PID	Design inlet pressure ($D = 117.6$)	psi
P2D	Design exit pressure (ambient) ($D = 14.7$)	psi
T2D	Design exit temperature (ambient) ($D = 70$)	°F
PS	Storage vessel pressure	psi
RS	Angular velocity	rpm
EF	1 Input product efficiency	-
MP	1 Maximum input power	kw
P	1 Input power	kw
CK	Capacity cost coefficient ¹ ($D = 0.015$)	
F0	Turbine mass flow exponent for capital cost ($D = 0.75$)	-
G	Turbine temperature exponent for capital cost ($D = 0.5$)	-
NPD	Design Polytropic Efficiency ($D = 0.88$)	

Outputs

<u>Variable/Port</u>			
P	2	Output power	kw
CC0		Turbine cost/year	\$
PR		Back pressure	psi
T0		Torque	ft-lb

D - Default values supplied

¹ CK = Capital cost (known unit)/[(design point mass flow rate)^{F0} *
(design point temperature + 460)^G * LN (inlet/outlet pressure ratio)*LE],
where LE = life expectancy in years.

Outputs Cont.

<u>Variable/Port</u>		<u>Description</u>	<u>Units</u>
EF	2	Output product efficiency	-
MP	2	Maximum discharge power	kw

Statistics

MOP	Maximum power observed	kw
-----	------------------------	----

The calculation sequence and the default values are based on the assumption of a high pressure ratio, constant angular velocity turbine, rated at 150 kw and a pressure ratio of 8. The equations used relate first order effects among the various physical quantities and were derived from first principles originally in support of the research work of Reference 1. Cost scaling was also developed in that reference based on cost estimates from turbomachinery manufacturers.

-
1. "Closed Cycle High Temperature Control Receiver Concept for Solar Electric Power," BEC/EPRI RP377-1, June 1976.

Calculation Sequence

1) Costs

$$CC = CK*(MD)**F0*(TID+460)**G*LN(PID/P2D)$$

2) Back Pressure PR determined by

$$PR = (M/MD)*PID* \sqrt{(T1+460)/(TID+460)}$$

If $PR > PS$ write DIAGNOSTIC

3) Efficiency

$$RAT = (PID/P2D)**(2/7)$$

$$EFF = (RAT-1.)/(RAT**(1/NPD)-1)$$

4) Power Out

$$P2 = M*CP*(T1-TA)*EFF$$

5) Torque

If $RS = 0$, set $T0 = 0$ and go to 6)

$$T0 = P2*(737.6)/(RS*2\pi/60)$$

6) Efficiency and maximum power

$$EF2 = EF1*EFF$$

$$MP2 = \min(MP1*EFF, MD*CP*(T1-TA))$$

7) Compute Statistics and Costs

CTU

SUBROUTINE TU(P2,CC,PR,TO,EF2,MP2,MOP,M,CP,T1,TA,MD,TID,PID,P2D,
1 T2D,PS,RS,EF1,MP1,P1,CK,F,G,NPD)

PURPOSE TURBINE PERFORMANCE MODEL

METHOD COMPUTE TURBINE POWER OUTPUT FROM INPUT DESIGN
CONDITIONS AS A FUNCTION OF INLET TEMPERATURE
AND MASS FLOW RATE

WRITTEN BY F.O. MAHONY

VERSION 1, MARCH 22 1977

CALL SEQUENCE

OUTPUTS

P2 - OUTPUT POWER, KW
CC - TURBINE COST PER YEAR, \$
PR - BACK PRESSURE, PSI
TO - TORQUE, FT-LB
EF2 - OUTPUT PRODUCT EFFICIENCY
MP2 - MAXIMUM DISCHARGE POWER, KW
MOP - MAXIMUM POWER OBSERVED, KW

INPUTS

M - INLET MASS FLOW RATE, LB/HR
CP - AIR HEAT CAPACITY, KWH/LB/DEG F
T1 - INPUT AIR TEMPERATURE, DEG F
TA - AMBIENT AIR TEMPERATURE, DEG F
MD - DESIGN MASS FLOW RATE, LB/HR
TID - DESIGN INLET AIR TEMPERATURE, DEG F
PID - DESIGN INLET PRESSURE, PSI
P2D - DESIGN EXIT PRESSURE (AMBIENT), PSI
T2D - DESIGN EXIT TEMPERATURE (AMBIENT), PSI
PS - STORAGE VESSEL PRESSURE, PSI
RS - ANGULAR VELOCITY, RPM
EF1 - INPUT PRODUCT EFFICIENCY
MP1 - MAXIMUM INPUT POWER, KW
P1 - INPUT POWER, KW
CK - CAPACITY COST COEFFICIENT
F - TURBINE MASS FLOW EXPONENT FOR CAPITAL COST
G - TURBINE TEMPERATURE EXPONENT FOR CAPITAL COST
NPD - DESIGN POLYTROPIC EFFICIENCY

COMMON /CIMPL/IMPL,ICNT/CTIME/ TIME /CSIMUL/DUM(7),TMAX /COST/CCI
REAL MP2,MOP, M,MD, MP1,NPD
DATA PI /3.14159/

IF(IMPL.GT.0) GO TO 100
IF(CP .EQ. .99999) CP = 72.0E-6
IF(TA .EQ. .99999) TA = 70.0
IF(MD .EQ. .99999) MD = 4800.
IF(TID.EQ. .99999) TID=600.0
IF(PID.EQ. .99999) PID=117.6
IF(P2D.EQ. .99999) P2D=14.7
IF(T2D.EQ. .99999) T2D=70.0
IF(CK .EQ. .99999) CK =0.015
IF(F .EQ. .99999) F =0.75
IF(G .EQ. .99999) G =0.5

```

IF(NPD.EQ..99999)NPD=.88
MOP = 0.
RS = AMAX1(0.0,AMIN1(RS, 4000.))
TMAX1=.99999*TMAX
CC = CK*MD**F*(TID+460.)**G*ALOG(PID/P2D)
      DETERMINE BACK PRESSURE

```

```

100 RAT= (PID/P2D)**.2857
EFF= (RAT-1.0)/(RAT**(1./NPD) - 1.0)
PR = M/MD*PID*SQRT((T1 + 460.0)/(TID+460.))

```

```

IF(PR.GT.PS) GO TO 1000

```

```

      POWER OUTPUT

```

```

200 P2= M*CP*(T1-TA)*EFF
TO = 0.
IF(RS.EQ.0. .OR. P1.EQ. 0.) GO TO 300
      TORQUE
TO = P2*737.6/(RS*2.0*P1/60.0)

```

```

      EFFICIENCY AND MAXIMUM POWER

```

```

300 EF2 = EF1*EFF
MP2 = AMIN1(MP1*EFF ,MD*CP*(T1-TA))
IF(IMPL.LE. 1) RETURN
MOP = AMAX1(MOP,P2)
IF(TIME.LT.TMAX1) RETURN
CCI = CCI + CC

```

```

      RETURN

```

```

1000 IF(IMPL.EQ.2)WRITE(6,1010) PR,PS
1010 FORMAT (1H0,2HTURBINE BACK PRESSURE,F12.3,
1      39H GREATER THAN STORAGE VESSEL PRESSURE ,F12.3)
IF(IMPL.EQ.2)ICNT=ICNT+1

```

```

      GO TO 200

```


```

      END

```

ORIGINAL PAGE IS
OF POOR QUALITY

7.50 UTILITY



The utility model has two power outputs corresponding to baseload and peak generation, with corresponding generation cost inputs. A surplus power input is also provided with cost credit depending on whether baseload or peak power is reduced. Total energy cost, total output power and total peak load requests are monitored.

Minimum input parameters to specify the utility are:

CB = cost of baseload generation (\$/kwh),
 CP = cost of peak load generation (\$/kwh).

Note: Even if no baseload generation is assumed, CB may be needed to compute surplus power cost credits.

Inputs

<u>Parameter/Port</u>	<u>Description</u>	<u>Units</u>
BS	Baseload generation (default = 0.)	kw
CE	Cost of baseload generation/kwh	\$
MP 1	Maximum power capacity (default = 1×10^8)	kw
P 0	Surplus power returned to utility	kw
RE	Peak generation request	kw
CP	Cost of peak load generation/kwh	\$
CC	Capital cost/year	\$
CM	Maintenance cost/year	\$

Outputs

<u>Variable/Port</u>			
P 1	Baseload generation (= BS)		kw
MP 2	Maximum power capacity (= MP1)		kw
P 2	Peak load generation		kw
CØ	Cost of energy used (state)		\$

Statistics

SR	Sum of requested peak generation	kwh
SPØ	Sum of output energy	kwh
SP	Sum of surplus energy	kwh
VSP	Value of surplus energy	\$

Calculation Sequence

1) Power outputs

If $BS > MP1$, write diagnostic

$$P1 = BS, MP2 = MP1$$

$$P2 = \text{MIN} (MP1 - BS, RE)$$

2) Energy cost dynamics

$$C0 = BS * CB + (P2 - P0) * CX$$

$$CX = \begin{cases} CP & \text{if } P2 - P0 > 0 \\ 0 & \text{if } P2 - P0 < 0 \end{cases}$$

3) Statistics

$$SR = SR + RE * TINC$$

$$DEL = \begin{cases} 0 & \text{if } P2 > P0 \\ (P0 - P2) * TINC & \text{if } P0 > P2 \end{cases}$$

$$SP0 = SP0 + (P1 + P2 - P0) * TINC + DEL$$

$$SP = SP + DEL$$

$$VSP = VSP + DEL * CB$$

Where $TINC = \text{integration step size}/2$

4) Compute Costs

CUT

SUBROUTINE UT(P1,MP2,P2,CO,COD,ICO,SR,SPO,SP,VSP
1 ,BS,CB,MP1,PO,RE,CP,CC,CM)

PURPOSE MODEL OF UTILITY CAPABLE OF PRODUCING
BASELOAD AND PEAKLOAD POWER, AND OF
ABSORBING SURPLUS POWER

METHOD COMPUTE PEAKLOAD GENERATION AND ENERGY COST

WRITTEN BY Y.K.CHAN

VERSION 1, JUNE 8, 1977

CALL SEQUENCE

OUTPUT

P1 -BASELOAD GENERATION,KW
MP2 -MAXIMUM POWER CAPACITY,KW
P2 -PEAKLOAD GENERATION,KW
CO -COST OF ENERGY USED (STATE), \$
COD -ENERGY COST RATE, \$/HR
ICO -INTEGRATOR CONTROL FOR CO

STATISTICS

SR -SUM OF REQUESTED PEAK GENERATION,KW
SPD -SUM OF OUTPUT ENERGY, KWH
SP -SUM OF SURPLUS ENERGY, KWH
VSP -VALUE OF SURPLUS ENERGY, \$

INPUTS

BS -BASELOAD GENERATION (DEFAULT=0.),KW
CB -COST OF BASELOAD GENERATION/KWH, \$
MP1 -MAXIMUM POWER CAPACITY,KW
PO -SURPLUS POWER RETURNED TO UTILITY,KW
RE -PEAK GENERATION REQUEST, KW
CP -COST OF PEAKLOAD GENERATION/KWH, \$
CC -CAPITAL COST/YEAR, \$
CM -MAINTENANCE COST/YEAR, \$

COMMON /CIMPL/IMPL,ICNT/CTIME/TIME/CSIMUL/DUM(7),TMAX
X /COST/CCI,CM1,COP,VDE,TDE,TLD,UTV,UTD,SPD
REAL MP2,MP1

IF(IMPL.GT.0)GO TO 100
IF(BS.EQ..99999)BS=0.
IF(MP1.EQ..99999)MP1=1.E6
TMAX1=TMAX*.99999
SR=0.
SP=0.
SPD=0.
VSP=0.
RE=0.
PO=0.

COMPUTE POWER OUTPUTS


TINC1=DUM(7)*.5
IF(BS.LE.MP1)GO TO 100
IF(IMPL.EQ.2) WRITE(6,208)BS,MP1
208 FORMAT(1H0,10H BASELOAD ,F12.3,32H EXCEEDS MAXIMUM POWER CAPACITY,
1 F12.3)
IF(IMPL.EQ.2)ICNT=ICNT+1

```

      BS=MP1
C
100 P1=BS
      MP2=MP1
      P2=AMIN1(MP1-BS,RE)
C
      COMPUTE ENERGY COST
C
      CX=0.
      IF(P2.GT.P0)CX=CP
      IF(ICO.NE.0)COD=BS*CB+(P2-P0)*CX
      IF(IMPL.LE.1)RETURN
C
      STATISTICS
C
      SR=SR+RE*TINC1
      SPO=SPO+ (P1+P2-P0)*TINC1
      IF(P2.GT.P0) GO TO 200
      TERM=(P0-P2)*TINC1
      SPO= SPO+TERM
      SP= SP+ TERM
      VSP= VSP+ CB*TERM
C
200 IF(TIME.LT.TMAX1)RETURN
      CCI=CCI+CC
      CMI=CMI+CM
      VDE=VDE-CO+VSP
      TDE=TDE-SPO+SP
      UTV=UTV+CO
      UTD=UTD+SPO
      SPD= SPD+SP
      RETURN
      END

```


7.51 WIND



This model computes wind speed either from user supplied time histories (data tape) or by generating a set of random numbers with user supplied daily and yearly average profiles and user specified random variation. If user supplied profiles are available then the wind speeds are generated from the following equation:

Basic Equation

$$WV = [PD(TD) + N(T)] * PY(WY) / M$$

where PD is the user supplied daily mean profile
 TD is the time of the day
 PY is the user supplied yearly profile
 WY is the week of the year
 N is white noise with user specified probability distribution

$$M = \frac{1}{J} \sum_{i=1}^J PY(i)$$

Tables

PD

PY

DF

Description

Daily profile versus TD (default = 0)

Yearly profile versus WY

Density function for white noise terms
(tabular with speed WV)Units

miles/hr

arbitrary

arbitrary

InputsParameter/Port

WV

1

Wind speed data file input

TD

Time of day

WY

Week of the year

miles/hr

hr

-

OutputsVariable/Port

WV

2

Wind speed

M

Mean of yearly profile

TIM

Last time a random sample was generated

miles/hr

hr

Statistics

MV

Maximum speed

AV

Average speed (expected daily wind)

miles/hr

miles/hr

C-5

Calculation Sequence

- 1) Compute distribution function and mean M (first pass only)

$$F(W) = \frac{(\sum DF(V_i) : V_i \leq W)}{\sum DF(V_i)}$$

- 2) Check for data file input

If WW1 = .99999 go to 3)

WW2 = WW1

Go to 5)

- 3) Generate white noise input N

If TIME = TIM go to 5)

U = random noise sample, uniformly distributed [0,1]

Interpolate to find $N = F^{-1}(U)$

TIM = TIME

- 4) Compute wind speed

$$W2 = [PD(TD) + N] * PY(WY)/M$$

- 5) Compute Statistics

CWD

SUBROUTINE WD (PD,PY,WF,WVO,AMV,AV,XM,TIMO ,WVI,TD,WY)

C
C PURPOSE GENERATE WIND SPEED FROM DAILY, YEARLY, AND RANDOM PROFILE DATAC
C METHOD RANDOM NOISE WITH SPECIFIED DIST. IS ADDED TO MEAN DAILY PROFILE
C AND MULTIPLIED BY A YEARLY PROFILE. INITIALLY THE DENSITY TABLE
C WF IS CONVERTED TO A DIST. FUNCTION.C
C WRITTEN BY A.W. WARREN

VERSION 1, MARCH 4 1977

C
C CALL SEQUENCEC
C TABLES

C PD - MEAN DAILY WIND PROFILE, MPH

C PY - MEAN YEARLY WIND PROFILE

C WF - WIND FREQUENCY FUNCTION (NON-GUST, RANDOM COMPONENT), HRS

C
C OUTPUTS

C WVO - WIND VELOCITY OUTPUT, MPH

C AMV - MAX. OBSERVED WIND SPEED, MPH

C AV - MEAN DAILY WIND SPEED, MPH

C XM - MEAN YEARLY WIND, -

C TIMO- LAST TIME A RANDOM SAMPLE WAS USED, HRS

C
C INPUTS

C WVI - WIND VELOCITY INPUT FROM DATA FILE, MPH

C TD - TIME OF DAY, HRS

C WY - WEEK OF YEAR (1-52)

C
C DIMENSION PD(1),PY(1),WF(1)

COMMON/CIMPL/IMPL /CTIME/TIME

DATA IX/1/

C
C INITIALIZATION

C COMPUTE MEAN DAILY WIND SPEED AND DIST. FCN

C
C NP=WF(2)

C ND=PD(2)

C NY=PY(2)

C IF(IMPL.GT.0) GO TO 10

C SUM=0.0

C AMN=0.0

C TIMO=-1.

C IF(WF(4+2*NP).EQ. 1.) GO TO 40

C DO 20 I=1,NP

C WF(I+2) = WF(I+3)

C L = 3+NP+I

C A=WF(L)

C WF(L)=SUM

C SUM=SUM+ A

C 20 AMN = AMN + A*WF(2+I)

C AMN = AMN/SUM

C WF(3+NP)= WF(NP+2)*2. - WF(NP+1)

C WF(L+1)= 1.

C
C DO 30 I=1,NP

C L=3+NP+I

C 30 WF(L) = WF(L)/SUM

40 CONTINUE

DEFAULT TABLE FOR PD

IF(PD(2).EQ. 1.99999) PD(4)=0.
IF(PD(2).EQ. 1.99999) PD(5)=0.
IF(PD(2).EQ. 1.99999) PD(2)=1.

AV = 0.
DO 25 I=1,ND
L = 3+ND+I

25 AV = AV+PD(L)
AV = AV/ND + AMN

XM=0.
DO 15 I=1,NY
L=3+NY+I

15 XM=XM+PY(L)
XM=XM/NY
AMV =0.

CHECK FOR DATA FILE INPUT

10 IF(WVI.EQ. .99999) GO TO 100
WVO = WVI
GO TO 150

GENERATE WHITE NOISE WITH DIST. WF

100 IF(TIME.EQ.TIME) GO TO 150
CALL UNIF(U,IX)
NP1=NP+1
WN = TBLU1(U,WF(4+NP),WF(3),1,-NP1)


GENERATE WIND SPEED USING DAILY AND YEARLY PROFILES

DWV = TBLU1(TD,PD(4),PD(4+ND),1,-ND)
YWV = TBLU1(WY,PY(4),PY(4+NY),1,-NY)
WVO = (DWV + WN)* YWV / XM
TIME=TIME

MAX. OBSERVED WIND SPEED

150 IF(IMPL.LE.1) RETURN
AMV = AMAX1(AMV,WVO)
RETURN
END

7.52 TURBINE/GENERATOR



This component uses a power curve relationship with wind velocity to model the wind turbine and generator. It may be used in place of the more detailed wind turbine-transmission-generator components where a simplified analysis is desirable, or where a nonstandard wind generator model is desired. The model may be used for either A.C. or D.C. power generation.

Basic Equations

$$P_2 = I = 0 \quad \left(\begin{array}{l} WV < WV_0 \\ WV > WV_1 \end{array} \right)$$

$$P_2 = V * I / 1000 \quad WV_0 \leq WV \leq WV_1$$




FIGURE 7.52: OUTPUT POWER VERSUS WIND VELOCITY

Tables

PW

Description

Wind generation power versus wind velocity ¹

Units

kw

Inputs

Parameter/Port

V	Bus voltage (Rated)	volts
WO	Power cutin velocity	mph
WV	Power cutout velocity	mph
WV	Wind velocity	mph
CC	Capital cost/year	\$
CM	Maintenance cost/year	\$
EC	Control Energy Rate	\$/hr

Outputs

Variable/Port

I	Bus current	amps
P	2 Real power output	kw

Statistics

MI	Maximum current	amps
MP0	Maximum power	kw
SP	Total output energy	kwh
C0	Total operating costs	\$

¹ Output power including mechanical and electrical efficiencies

Calculation Sequence

1) Initialize statistics

2) Compute P2 and I

$$P2 = \begin{pmatrix} PW(W) & W0 \leq W \leq W1 \\ 0 & \text{otherwise} \end{pmatrix}$$

$$I = P2 * 1000 / V$$

3) Compute Statistics and Costs

CWP

00000000000000000000000000000000

C
C
C

CC

C

390

BCS 40262-1

DIMENSION PW(1)

COMMON / CIMPL / IMPL

COMMON/CGST/ CC,CM,COP /CTIME/ TIME /CSIMUL/ DUM(6),TINC,TMAX

POWER OUTPUT CALCULATIONS

PO = 0.

N = PW(2)

$$10 \text{ BI} = \text{PO} * 1000 / \text{VO}$$

```
IF(IMPL.GT.0) GO TO 20
```

$$C_0 = 0.$$

AMI = 0.

AMP = 0.

$$SP = 0.$$
$$TMAX1=TMAX*.99999$$

```
20 IF(IMPL.LE.1) RETURN
```

```
AMI = AMAX1(AMI,BI)
```

AMP = AMAX1(AMP,PO)

$$SP = SP + PO * .5 * TINC$$

```
CO= CO + EC*.5*TING
```

COST SUMMATION


```
IF( TIME.LT.TMAX1) RETURN
```

$$CC = CC + CCI$$
$$CM = CM + CMI$$
$$COP = COP + CO$$

RETURN

END

7.53 WIND TURBINE



This component models the wind turbine in terms of physical properties such as blade radius, power coefficient, and design tip speed ratio.¹ The step-up gear ratio is computed based on design rotor speed.

Basic Equations

Output power is given by

$$P2 = CP * 1/2 * AD * A * (WV * C)^3 * k$$

where:

CP = effective power coefficient (tabular with WV)

$$A = \pi * (BR)^2$$

C = 1.4667 (mph to ft/sec. conversion)

k = 1.3558×10^{-3} (ft-lb to kw-sec. conversion)

Minimum input parameters to specify the wind turbine are:

VO = mean wind speed,

BR = blade radius,

CPM = maximum power coefficient at design speed VO.

¹ NASA CR 134937 "Design Study of Wind Turbines - 50kw to 3000 kw - For Electric Utility Applications", Kaman Aerospace Corporation, February 1976.

Inputs

<u>Parameter/Port</u>	<u>Description</u>	<u>Units</u>
WV	Wind speed	mph
V0	Mean wind speed (yearly)	mph
VR	Rated wind speed (default = $1.35 \times V0$)	mph
RS	Rotor speed	rpm
RSG	Generator shaft speed (design)(default = 1800)	rpm
BR	Blade radius	ft
EC	Cost to operate controls	\$/h
AD	Air density (default = 0.0023)	slugs/ft ³
LAM ¹	Design tip speed ratio (default = 9.4)	-
CPM ²	Maximum power coefficient at V0 (default = 0.4)	-
CP	Effective power coefficient (default table versus V0/WV)	-
CC	Capital cost/year	\$
CM	Maintenance cost/year	\$

Outputs

<u>Variable/Port</u>			
P	2	Output mechanical power	kw
T0		Mechanical torque	ft-lb
C0		Total operating cost	\$
GR		Step-up gear ratio	-
RAP		Rated output power	kw

Statistics

MT	Maximum torque	ft-lb
MP0	Maximum power	kw
SP	Total energy delivered	kwh

¹ LAM may be computed using the design equation:

$$LAM = \sqrt{8 / (3 * \text{solidity constant} * \text{design lift coefficient})}$$

² If default CP table not used then set CPM = CP(rated wind speed)

Calculation Sequence

- 1) First pass - Compute Gear Ratio and Rated Power

$$RS = (LAM * V_0 * C / BR) * (60 / 2\pi)$$

$$GR = RSG / RS$$

$$RAP = .5 * CP1 * AD * A * (VR * C)^3$$

where

$$CP1 = \begin{cases} CPM * F(V_0 / VR) & \text{if CP default used} \\ CPM & \text{otherwise} \end{cases}$$

- 2) Compute power coefficient CP

If $W = 0$ set $P2 = T0 = 0$ and go to 4)

If CP default used, then

$$CP = CPM * F(V_0 / W)$$

where F is shown in Figure 7.53

- 3) Power and torque

$$A = \pi * BR^2$$

$$P = .5 * CP * AD * A * (WV * C)^3$$

$$(C = 1.4667)$$

$$T0 = P / (RS * 2\pi / 60)$$

$$P2 = P * k$$

$$(k = 1.3558 \times 10^{-3})$$

- 4) Compute Statistics and Costs




FIGURE 7.53 GENERALIZED MACHINE POWER OUTPUT PERFORMANCE

WT

CWT

SUBROUTINE WT (P2,TO,CO,GR,RAP,MT,MPO,SP,WV,VO,VR,RS, RSG,BR,EC,
1 AD,LAM,CPM, CP,CC,CM)

PURPOSE MODEL WIND TURBINE POWER OUTPUT

METHOD COMPUTE POWER COEFFICIENT AND ROTOR SPEED FROM PHYSICAL
DESIGN PARAMETERS. RATED POWER COEFF. IS 3/4 OF CPM.

WRITTEN BY A. W. WARREN

VERSION 2, APRIL 6 1977

CALL SEQUENCE

OUTPUTS

P2 - OUTPUT MECHANICAL POWER, KW
TO - OUTPUT MECHANICAL TORQUE, FT-LB
CO - OPERATING COST SUM, \$
GR - TURBINE/GENERATOR GEAR RATIO
RAP - RATED OUTPUT POWER, KW
MT - MAXIMUM TORQUE STATISTIC, FT-LB
MPO - MAXIMUM POWER STATISTIC, KW
SP - TOTAL OUTPUT ENERGY DELIVERED, KWH

INPUTS

WV - WIND SPEED, MPH
VO - MEAN WIND SPEED (YEARLY), MPH
VR - RATED WIND SPEED, MPH
RS - ROTOR SPEED, RPM
RSG - GENERATOR SHAFT SPEED, RPM
BR - BLADE RADIUS, FT
EC - CONTROL ENERGY RATE, \$/HR
AD - AIR DENSITY, SLUGS/FT**3
LAM - DESIGN TIP SPEED RATIO
CPM - MAXIMUM POWER COEFFICIENT AT VO
CP - EFFECTIVE POWER COEFFICIENT AT WV
CC - CAPITAL COST PER YEAR
CM - MAINTENANCE COST PER YEAR

COMMON /CIMPL/IMPL /CTIME/ TIME /CSIMUL/ DUM(6),TINC,TMAX
COMMON /COST/ CCI,CMI,COI

REAL MT,MPO,LAM

DIMENSION F(22)

DATA F/.24,.4,.6,.68,.8,1.,1.2,1.31,1.4,1.6,1.74,0.,.31,.68,.8,
1 .92,1.,.92,.8,.68,.3,0. /,C1,C2,PI/1.4667,.0013558,3.14159 /

INITIALIZATION

IF(IMPL.GT.0) GO TO 100

TMAX1 = TMAX* .99999

TINC2 = .5* TINC

IF(VR .EQ. .99999) VR = 1.35* VO

IF(RSG .EQ. .99999) RSG= 1800.

IF(AD .EQ. .99999) AD = .0023

IF(LAM .EQ. .99999) LAM= 9.4

IF(CPM .EQ. .99999) CPM= 0.4

RS = C1*LAM*VO/BR*(30./PI)

GR = RSG /RS

```

CP1=CPM
IF(CP.EQ..99999)CP1= CPM*TBLU1(VO/VR,F(1),F(12),1,-11)
RAP= .5*CP1*AD*PI*BR*BR*(VR*C1)**3*C2
CO = 0.0
SP = 0.0
MPO= 0.0
MT = 0.0

```

POWER COEFFICIENT CALCULATION

```

100 P2 = 0.0
TO = 0.0
IF( WV.EQ. 0.) GO TO 200
CP1 = CP
IF( CP1.EQ. .99999) CP1 = CPM*TBLU1(VO/WV,F(1),F(12),1,-11)
IF(CP1.EQ. 0.) GO TO 200

```

OUTPUT POWER AND TORQUE

```

A = PI*BR**2
P = .5*CP1*AD*A*(WV*C1)**3
IF(WV.GT.VR)P= RAP/C2
TO=P/(RS*PI/30.)
P2 = P*C2

```

STATISTICS AND COSTS

```

200 IF(IMPL.LE.1) RETURN

```

```

CO = CO + EC*TINC2
MT = AMAX1( MT,TO)
MPO= AMAX1(MPO,P2)
SP = SP + P2*TINC2

```

```

IF(TIME.LT.TMAX1)RETURN
CCI = CCI + CC
CMI = CMI + CM
COI = COI + CO

```

```

RETURN
END

```

ORIGINAL PAGE IS
OF POOR QUALITY

8.0 WIND GENERATION AND STORAGE EXAMPLES

This section gives four simple example simulations using the SIMWEST program. These examples exercise all storage components of the SIMWEST library and many of the model features. Each example contains the input data for model generation and analysis, selected printer output generated by the programs and a discussion of the results obtained. It is recommended that a user work through and understand the model connections for these examples before attempting to build more complex models.

8.1 BATTERY STORAGE MODEL

A simplified schematic of the battery storage model is shown in Figure 8.1-1. In this model, wind power supplemented by utility generation is supplied to a power divider, which delivers power to the load as a first priority, and battery storage as second priority. Similarly, if the load cannot be met from the wind or storage, then the utility is requested to supply peaking power to meet the load. This model exercises the logic components including the priority interrupt.

Figure 8.1-2 shows the model generation input data for the model. The components are generally defined in the order of power flow shown in Figure 8.1-1. Ordering the component definition in this way is recommended to avoid convergence problems in the iteration loop. Thus, it would be somewhat better for consistency to define UT after WP rather than after LO in the model. All three types of model connections are illustrated in this example. For example, WP has the general input connection WD, MAB has the specific input connection WP(P,2 = FIN), and PD has the port to port connection PA(1,1). The port connections are especially useful for connecting up the multiport logic components PA and PD. The connection PA(1,1), for example, connects an input request of PD to PA and a power and maximum power input of PA to PD. It may be observed that the utility is connected up to the surplus port of PD. Thus the baseload power sent to MAB in effect is reduced whenever the load and battery




FIGURE 8.1-1: BATTERY STORAGE EXAMPLE

cannot absorb all the power generated. The last component defined is the cost monitor CM, which receives cost input data from other components through a common block rather than by model connections. Figure 8.1-3 shows the model schematic generated by the program. Most of the connection inputs are shown but occasionally a model connection will be overprinted. For example, the input RE1PA to PD is not shown in 8.1-3. In cases like this it is necessary to check the Fortran model (EQMO) in order to verify the model connections.

MODEL DESCRIPTION		BATTERY TEST CASE
LOCATION=74	TI	
LOCATION=61	WD	INPUTS=TI
LOCATION=21	WP	INPUTS=WD
LOCATION=42	MAB	INPUTS=WP(P,2=FIN),UT(P,1=C2)
LOCATION=33	PD	INPUTS=MAB(FO=P),MAB(FO=MP),PA(1,1),PIB(2,2), BA(RE=RE,2)
LOCATION=15	RE	INPUTS=PD(2,1)
LOCATION=17	BA	INPUTS=RE,PA(RE,2=RE)
LOCATION=45	PIB	INPUTS=BA
LOCATION=19	IV	INPUTS=BA
LOCATION=69	PA	INPUTS=IV(2,2),LO(1,0),PIB(4,2),UT(2,3)
LOCATION=76	LO	INPUTS=TI
LOCATION=62	UT	INPUTS=PD(SP=P,0)
LOCATION=1	CM	
END OF MODEL		
LIST OF STANDARD COMPONENTS		
PRINT		

FIGURE 8.1-2 BATTERY MODEL INPUT DATA

The input data for two simulations is shown in Figure 8.1-4. In the first simulation the battery is nearly full at time = 0 and the load is chosen larger on the average than the wind and utility power generated. In the second simulation the reverse is true, i.e. the load is less than that supplied by the



```

TITLE= BATTERY MODEL TEST
PARAMETER VALUES
CR CM=15.,LE CM=30.
BS UT=20.,CB UT=.016,CP UT=.03,CC UT=1000.,CM UT=1000.
C1 MAB=1.
CYCLES=4.01,TO T1=0,V WP=400,WVOWP=8,WV1WP=60,DLINES=100.
CC WP=16000,CM WP=1200,PS1PTB=2.
EC WP=.2
NC LO=.005,CT LO=4,MN LO=0,STDLO=6,VE LO=.023
RAPBA=200.,E1 BA=2000.,EDEBA=100.
VD BA=100
DT BA=10.,CC BA=2000.,CM BA=100.
RAPRE=200.,CC RE=200.,RAPIV=200.,CC IV=0.
TABLE,PW WP=10
8,10,12,14,16,18,20,21.53,25,30
25.6,50.1,86.5,137.4,205.1,292.,400.6,500,782.8,800
TABLE,PY WD=13
0.,4.33,8.67,13.,17.33,21.67,26.,30.33,34.67,39.,43.33,47.67,52.
65,67,68,65,61,56,51,49,49,52,56,61,65
TABLE,PD WD=7
0,4,8,12,16,20,24
10,12,14,16,14,12,10
TABLE,DF WD=16
0,1,2,3,4,5,6,7,8,9,10,11,12,13,14,15
5,44,160,380,480,512,440,376,307,270,148,76,40,22,9,3
TABLE,PD LO=17
0,1,5,3,4,5,6,7,5,9,10,5,12
13,5,15,16,5,18,19,5,21,22,5,24
450,360,372,330,450,660,810,798,804
690,708,699,702,750,708,570,450
TABLE,PW LO=7
1,2,3,4,5,6,7
1,1,.9,.9,.9,.6,.5
TABLE,PY LO=6
0,10,20,30,40,52
226,194,180,174,194,226
INITIAL CONDITIONS, PE BA =1990.
PRINTER PLOTS,DISPLAY1
WV2WD,VS,TIME
P1 PD,VS,TIME
P2 PD,VS,TIME
PE BA,VS,TIME
DISPLAY2
P2 IV,VS,TIME
RE2BA,VS,TIME
RE1LO,VS,TIME
TINC=.25,TMAX=336.,PRATE=8,PRINT CONTROL=3,INT MODE=3,OUTRATE=8
SIMULATE
PARAMETER VALUES,BS UT=0.,NC LO=.005
E1 BA=1000.,EDEBA=200.
CC IV=1000.
INITIAL CONDITIONS,PE BA=250.
SIMULATE

```

FIGURE 8.1-4 INPUT DATA FOR BATTERY SIMULATION

wind system, and the battery storage is fairly low. Figures 8.1-5 to 8.1-8 show results from the first simulation. The cost monitor output is shown in Figure 8.1-5. The energy cost of the wind system is low because the wind profile delivers high energy winds during most of the simulation. The wind velocity shown in Figure 8.1-6 averages about 22 mph. Figure 8.1-7 shows the wind power output supplied directly to the load. The median power output is seen to exceed 450 kw and occasionally output reaches 800 kw = rated power. Figure 8.1-8 shows the usage of battery energy to meet the load during the week, and the increase in storage capacity during the weekends. Since the battery subsystem was limited to 180 kw maximum discharge, the utility was frequently called to meet peak loads. Thus about 10% of the load was satisfied by the utility backup.

WIND ENERGY STORAGE COST SUMMARY

30 YEAR LIFE CYCLE

• YEARLY SYSTEM COSTS

CAPITAL COST (INCLUDING FIXED CHARGES)	86400. \$
FIXED O + M COST	2300. \$
OPERATING + FUEL COST	1753. \$
TOTAL	90453. \$

• ENERGY DELIVERED

ENERGY DELIVERED	4682165. KWH
------------------	--------------

 *
 * ENERGY COST PER KWH 19.3 MILLS *
 *

VALUE OF ENERGY DELIVERED (VALUE OF FUEL SAVED)	105440. \$
--	------------

ENERGY VALUE PER KWH	22.5 MILLS
----------------------	------------

COST PER VALUE DELIVERED	.86
--------------------------	-----

• LOAD FACTOR

PERCENT OF LOAD SUPPLIED BY TOTAL WIND SYSTEM	90.4
--	------

PERCENT OF LOAD SUPPLIED BY UTILITY	9.6
--	-----

PERCENT OF WIND ENERGY SURPLUSSED	4.0
--------------------------------------	-----

COST TO MEET LOAD (WIND + UTILITY)	19.8 MILLS
---------------------------------------	------------

FIGURE 8.1-5 COST MONITOR OUTPUT FOR BATTERY MODEL




FIGURE 8.1-6 WIND PROFILE FOR BATTERY SIMULATION




FIGURE 8.1-7 WIND POWER SUPPLIED TO LOAD




FIGURE 8.1-8 BATTERY POTENTIAL ENERGY STORAGE

8.2 FLYWHEEL STORAGE MODEL

Figure 8.2-1 shows a simplified schematic of the flywheel storage model. This model is very similar to that of 8.1 except that flywheel storage replaces battery storage, and a power line loss is included in the model. The input data for this model is shown in Figure 8.2-2. Observe that the components are defined in the order of information flow shown in 8.2-1. The admittance component AD is used to model transmission line power losses. The model schematic is shown in Figure 8.2-3.

MODEL DESCRIPTION	FLYWHEEL TEST CASE
LOCATION=74 TI	
LOCATION=61 WD	INPUTS=TI
LOCATION=21 WP	INPUTS=WD
LOCATION=42 MAB	INPUTS=WP(P,2=FIN),UT(P,1=C2)
LOCATION=33 PD	INPUTS=MAB(FO=PP),PA(1,1),PIB(2,2),FL(RE=RE,2)
LOCATION=13 MO	INPUTS=PD(2,1)
LOCATION=4 TRI	INPUTS=MO(2,1),FL(RS=RS,2)
LOCATION=6 FL	INPUTS=TRI,PA(2,1)
LOCATION=8 TRO	INPUTS=FL,GE(RS=RS,2)
LOCATION=19 GE	INPUTS=TRO
LOCATION=69 PA	INPUTS=GE(2,2),LO(RE,1=RE,0),PIB(4,2),UT(2,3)
LOCATION=78 AD	INPUTS=PA
LOCATION=76 LO	INPUTS=TI,AD
LOCATION=62 UT	INPUTS=PD(SP=P,0)
LOCATION=1 CM	
END OF MODEL	
LIST STANDARD COMPONENTS	
PRINT	

FIGURE 8.2-2 FLYWHEEL MODEL INPUT DATA




FIGURE 8.2-1: FLYWHEEL STORAGE EXAMPLE



The simulation input data shown in Figure 8.2-4 uses the same wind and load data as Example 8.1. However, the storage component is rated at 400 kw with one hour storage, simulating a system used for temporary storage and discharge during peak power generation and load demand periods. It may be noted that the transmission power loss table is input for both TRI and TR0. Figures 8.2-5 to 8.2-7 show results from the simulation. Charging power to the flywheel in excess of that needed for the load is shown in Figure 8.2-5. Even with average load demand exceeding wind generation, the flywheel is charged at rated power fairly often. The kinetic energy stored by the flywheel over a two week period is shown in Figure 8.2-6. During the week, energy is frequently withdrawn and storage is generally not much above the deadband (80 kwh), whereas during the weekend the reverse is true. Output from the cost monitor is shown in Figure 8.2-7. The capital costs may be low since nominal values were used for component costs. The utility supplied nearly 20% of the load in this case, since flywheel storage capacity is quite low.

TITLE= FLYWHEEL MODEL TEST
 PARAMETER VALUES
 VD AD=100,G1 AD=8.,G2 AD=8.,GH AD=8.,HM AD=200
 SR GE=.008,C2 FL=3,E=8
 PR FL=.02,MN FL=3372,RF FL=3.5,SR FL=.4,WT FL=24000,KF FL=1.3E=5
 ZE FL=.1,RAPFL=400,EO FL=40,E1 FL=400,EDFL=20,CM FL=800,CC FL=300
 RS MD=1750,RAPMD=1000,MP1MD=1.8,CC MD=500,CM MD=0.
 RS1TRI=1750,CC TRI=500,CM TRI=0,CC TRQ=500,CM TRQ=0.
 RAPGE=1000,CC GE=1000,CM GE=100.
 CR CM=15.,LE CM=30.
 H3 UT=20.,CH UT=.016,CP UT=.03,CC UT=1000.,CM UT=1000.
 C1 MAB=1.
 CYCLES=4.01,T0 TI=0,V WP=400,WVOWP=8,WV1WP=60,DLINES=100.
 CC WP=16000,CM WP=1200,PS1PI8=2.
 EC WP=.2
 NC LO=.005,CT LO=4,MN LO=0,STDLO=6,VE LO=.023
 TABLE,PLDTRI=5,4
 0.5,1,1.5,1.72
 0.400,900,1100,1300
 0.16,18,18.5,20
 0.10,11,11.5,12
 0.10,10,10.5,11
 0.6,6.5,7,10
 TABLE,PLOTRO=5,4
 .5,1,1.5,1.72
 0.400,900,1100,1300
 0.16,18,18.5,20
 0.10,11,11.5,12
 0.10,10,10.5,11
 0.6,6.5,7,10
 TABLE,CLOFL=3,3
 -1000, 0, 1000
 2000,4000,7000
 2.8, 7.4, 15
 .9, 2.5, 5
 2.6, 7.2, 15
 TABLE,CL1FL=3
 2000,4000,7000
 .8, 2.4, 4
 TABLE,PW WP=10
 8,10,12,14,16,18,20,21.53,25,30
 25.5,50,1,86.5,137.4,205.1,292.,400,6,500,782,8,800
 TABLE,PY WD=13
 0.,4.33,8.67,13.,17.33,21.67,26.,30.33,34.67,39.,43.33,47.67,52.
 65.67,68.65,61.56,51.49,49.52,56.61,65
 TABLE,PD WD=7
 0.4,8,12,16,20,24
 10,12,14,16,18,12,10
 TABLE,DF WD=16
 0.1,2,3,4,5,6,7,8,9,10,11,12,13,14,15
 5,44,160,380,480,512,440,376,307,270,148,76,40,22,9,3
 TABLE,PD LO=17
 0.1,5,3,4,5,6,7,5,9,10,5,12
 13.5,15,16.5,18,19.5,21,22.5,24
 450,360,372,330,450,660,810,798,804
 690,708,699,702,750,708,570,450
 TABLE,PW LO=7
 1,2,3,4,5,6,7
 1.1,.9,.9,.9,.6,.5
 TABLE,PY LO=6
 0.10,20,30,40,52
 226,194,180,174,194,226
 INITIAL CONDITIONS, KE FL=300.
 PRINTER PLOTS,DISPLAY1
 WV2ND,V,S,TIME
 P1 PD,V,S,TIME
 P2 PD,V,S,TIME
 KE FL,V,S,TIME
 DISPLAY2
 P2 GE,V,S,TIME
 RE2FL,V,S,TIME
 RE1LO,V,S,TIME
 TINC=.25,THAX=336.,PRATE=8,PRINT CONTROL=3,INT MODE=3,OUTRATE=8
 SIMULATE

ORIGINAL PAGE IS
 OF POOR QUALITY

FIGURE 8.2-4 FLYWHEEL SIMULATION DATA




FIGURE 8.2-5 WIND POWER SUPPLIED TO FLYWHEEL STORAGE




FIGURE 8.2-6 FLYWHEEL KINETIC ENERGY STORAGE

WIND ENERGY STORAGE COST SUMMARY	
30 YEAR LIFE CYCLE	
* YEARLY SYSTEM COSTS	
CAPITAL COST (INCLUDING FIXED CHARGES)	89104. \$
FIXED O + M COST	3100. \$
OPERATING + FUEL COST	1753. \$
TOTAL	93957. \$
* ENERGY DELIVERED	
ENERGY DELIVERED	4440974. KWH

ENERGY COST PER KWH	21.2 MILLS

VALUE OF ENERGY DELIVERED (VALUE OF FUEL SAVED)	95217. \$
ENERGY VALUE PER KWH	21.4 MILLS
COST PER VALUE DELIVERED	.99
* LOAD FACTOR	
PERCENT OF LOAD SUPPLIED BY TOTAL WIND SYSTEM	61.3
PERCENT OF LOAD SUPPLIED BY UTILITY	18.7
PERCENT OF WIND ENERGY SURPLUS	8.3
COST TO MEET LOAD (WIND + UTILITY)	22.3 MILLS

FIGURE 8.2-7 FLYWHEEL MODEL COST MONITOR OUTPUT

8.3 HYDRO AND THERMAL STORAGE MODEL

Figure 8.3-1 shows the basic model schematic for a model with both thermal and electrical loads. Wind power is supplied first to meet the electrical load, with excess power going into hydro and thermal storage. The thermal load is driven by an ambient temperature component. The electrical load energy value is supplied by a time dependent look-up table. Figure 8.3-2 shows the model components are ordered according to the flow of information in 8.3-1. Observe that the maximum power input of the power divider is connected up to the wind power output P. The model schematic is shown in Figure 8.3-3.

MODEL DESCRIPTION		HYDRO AND THERMAL TEST CASE
LOCATION=77	TI	
LOCATION=51	WD	INPUTS=TI
LOCATION=21	WP	INPUTS=WD
LOCATION=33	PD	INPUTS=WP,WP(P=MP),PA(1,1),PIH(2,2),HS(RE=RE,2) INPUTS=TS(2,3),PIT(2,3)
LOCATION=13	MO	INPUTS=PD(2,1)
LOCATION=15	PU	INPUTS=MO
LOCATION=17	HS	INPUTS=PU,PA(RE,2=RE)
LOCATION=45	PIH	INPUTS=HS
LOCATION=19	HT	INPUTS=HS
LOCATION=40	GE	INPUTS=HT
LOCATION=59	PA	INPUTS=GE(2,2),LO(1,0),PIH(4,2)
LOCATION=78	FU	INPUTS=TI(TD=FIN)
LOCATION=80	LO	INPUTS=TI,FU(FO=VE)
LOCATION=63	TS	INPUTS=TL
LOCATION=52	PIT	INPUTS=TS
LOCATION=67	TP	INPUTS=TI
LOCATION=65	TL	INPUTS=TI,TP
LOCATION=1	CM	
END OF MODEL		
PRINT		

FIGURE 8.3-2 HYDRO AND THERMAL MODEL INPUT DATA




FIGURE 8.3-1: HYDRO AND THERMAL STORAGE EXAMPLE

PAGE 8




FIGURE 8.3-3 HYDRO AND THERMAL MODEL SCHEMATIC

The input data for a two week simulation with this model is shown in Figure 8.3-4. CYCLES is set to 6 in this model for sufficient iterations to attain steady state in the hydro storage subsystem. The hydro system has much larger capacity and supplies a bigger load than the thermal system in this run. Figures 8.3-5 to 8.3-9 show results of the simulation. Hydro energy storage is shown in 8.3-5. During the week most of the wind energy goes directly to the load except at night. The reservoir builds up to capacity during the weekends. The cumulative percent load delivered by wind and hydro storage is shown in 8.3-6, and averages about 91%. Similarly, thermal energy stored and percent thermal load delivered are shown in 8.3-7 and 8.3-8. The ambient temperature profile for a similar, one week simulation is shown in 8.3-9.

PARAMETER VALUES

CYLES=5.01,TD=TI=0,V WP=400,WVOWP=8,WVTWP=50,DLINES=100.
 CC WP=15000,CM WP=1200,PS1PIH=2.,EC WP=.2,CR CM=15,LE CM=30
 41 PU=200,AS HS=3500,MDRHS=80,MO HS=80000,CM HS=1000
 41 HS=200,MOE HS=400000,LE HS=30,F2 PD=.5,F3 PD=.5
 RA GE=200,RSYGE=3600,SR GE=.0533,CC GE=1000,CM GE=120
 VC LO=.004,CT LO=4,MN LO=0,STLO=5,AN FU=-1.
 31 PFI=2.,FS TS=10,VO TS=110,PD TS=100,LE TS=30,MFTS=10000.
 31 TS=.01465,TDTS=2,RS MO=1750,RAPMO=200,CC MO=500,CM MO=100
 VE TL=.023,VC TL=40.,CT TP=12,MN TP=0,STOTP=5.

TA3LE,PW WP=10

3,10,12,14,15,18,20,21.53,25,30

25,6.50,1.85,5,137.4,205.1,292.,400.6,500,782.8,800

TA3LE,PY WD=13

3.,4.33,8.57,13.,17.33,21.67,26.,30.33,34.67,39.,43.33,47.67,52.

55,57,63,55,51,55,51,49,43,52,55,61,65

TA3LE,PD WD=7

3.,4,8,12,15,20,24

10,12,14,15,14,12,10

TA3LE,DF WD=15

0,1,2,3,4,5,6,7,8,9,10,11,12,13,14,15

5.,4,150,380,480,512,440,376,307,270,148,76,40,22,9,3

TA3LE,MT TS=4

.00879,.025431,.0047371,.0064072

30,147,147,204

TA3LE,PD LO=17

0,1.5,3,4.5,5,6,7.5,9,10.5,12

13.5,15,16.5,18,19.5,21,22.5,24

450,360,372,330,450,560,810,798,804

590,708,699,702,750,708,570,450

TA3LE,PW LO=7

1,2,3,4,5,6,7

1,1.,9.,9.,9.,6.,5

TA3LE,PY LO=6

3,10,20,30,40,52

225,194,180,174,194,226

TA3LE,FTAFU = 5

0,5,10,18,22,24

.019,.019,.028,.028,.019,.019

TA3LE,TLDTL=4

3,52,60,100

4.,2.,1.5,1.

TA3LE,TWTL=4

0,5,18,24

.4,1.,1.,.4

TA3LE,PD TP=9

3,5,6,9,12,15,18,21,24

45,45,48,55,62,64,56,48,46

TA3LE,PY TP=5

0,13,25,39,52

40,50,75,65,40

INITIAL CONDITIONS, MA HS=1600000,E TS=600

ENTER PLOTS,DISPLAY1

4V2WD,VS,TIME

31 PD,VS,TIME

4 PU,VS,TIME

DISPLAY2

E HS,VS,TIME

42 HS,VS,TIME

RE2HS,VS,TIME

DISPLAY3

3C LO,VS,TIME

33 PD,VS,TIME

E TS,VS,TIME

RE1LO,VS,TIME

DISPLAY4

LO TS,VS,TIME

3C TL,VS,TIME

TA2TP,VS,TIME

30 FU,VS,TD TI

TINC=.50,TMAX=335.,PRATE=6,PRINT CONTROL=3,INT MODE=3,OUTRATE=4

TITLE = HYDRO AND THERMAL TEST

SIMULATE

ORIGINAL PAGE IS
OF POOR QUALITY

FIGURE 8.3-4 HYDRO AND THERMAL SIMULATION DATA




FIGURE 8.3-5 HYDRO RESERVOIR ENERGY STORAGE




FIGURE 8.3-6 PERCENT CUMULATIVE LOAD DELIVERED




FIGURE 8.3-7 THERMAL ENERGY STORAGE




FIGURE 8.3-8 PERCENT CUMULATIVE THERMAL LOAD DELIVERED




FIGURE 8.3-9 AMBIENT TEMPERATURE SIMULATION OVER ONE WEEK

8.4 PNEUMATIC STORAGE MODEL

Figure 8.4-1 shows the simplified schematic for the pneumatic storage model. For simplicity the motor and generator have been omitted from the pneumatic storage subsystem. A burner is used if needed to heat the exiting air to the turbine. The heat exchanger is a phase change medium. Figure 8.4-2 shows the input data for this model.

MODEL DESCRIPTION	PNEUMATIC STORAGE TEST CASE
LOCATION=1 TI	
LOCATION=21 WD	INPUTS=TI
LOCATION=51 WP	INPUTS=WD
LOCATION=5 TP	INPUTS=TI
LOCATION=43 PD	INPUTS=WP,WP(P=MP),PA(1,1),PI(2,2),CS(RE=RE,2)
LOCATION=64 UT	INPUTS=PD(SP=P)
LOCATION=15 CO	INPUTS=PD(2,1),TP
LOCATION=17 HX	INPUTS=CO,TP,CS
LOCATION=47 CS	INPUTS=HX,PA(RE,2=RE)
LOCATION=36 PI	INPUTS=CS
LOCATION=49 HY	INPUTS=CS,HX
LOCATION=59 BN	INPUTS=HY
LOCATION=80 TU	INPUTS=BN,TP,CS(PR=PS)
LOCATION=76 PA	INPUTS=TU(2,2),LO(1,0),PI(4,2),UT(2,3)
LOCATION=72 LO	INPUTS=TI
LOCATION=71 CM	
END OF MODEL	
LIST STANDARD COMPONENTS	
PRINT	

FIGURE 8.4-2 PNEUMATIC STORAGE MODEL INPUT DATA




FIGURE 8.4-1: PNEUMATIC STORAGE EXAMPLE

The input data for a two week simulation is shown in 8.4-3. In order to keep the air entering the storage cavern from overheating, a fairly large leakage coefficient ($NU = 0.01$) is assumed. Hence the storage cavern loses about $2/3$ of its heat energy every four days. The load constant NC LO can be adjusted to balance wind energy to the load so that weekly air mass flow in and out of the cavern is balanced. The initial values for the CS and HX states were chosen on the basis of an earlier one week simulation. Figures 8.4-4 to 8.4-8 show results of this simulation. Figure 8.4-4 shows the average temperature of the heat exchanger storage medium for the 'cool' cell. The initial temperature at the beginning of the simulation is a little too cool since the temperature rises to about 400° during the weekends. Phase change in this medium is indicated by the constant temperature intervals at 250° . Figure 8.4-5 shows the air temperature exiting from the heat exchanger into the cavern. During the week this temperature is generally held below 200° but may exceed 350° during the weekend. Figure 8.4-6 shows the air mass stored in the cavern. In this simulation wind power generation exceeded that for the load and thus there is a gradual buildup of air mass in the cavern. The temperature of the stored air mass is shown in Figure 8.4-7. There is about a 10° fluctuation in temperature each week in this case. The last figure, 8.4-8 shows the air temperature exiting from the heat exchanger to the burner. Neglecting the influence of the initial conditions, the average temperature is about 550° and thus a burner is probably not required for this system.

TITLE= PNEUMATIC STORAGE TEST CASE2
 PARAMETER VALUES
 CYCLES=4.01, T0 TI=0, CT TP=12, MN TP=0, STDTP=5, DLINE=100
 V WP=400, WVOWP=8, WV1WP=60, CC WP=16000, CM WP=1200, PS1PI=2, EC WP=.2
 LE CS=30, MDECS=10000, TEMCS=350, NU CS=.010, TM CS=125, BE HX=.001
 MD CM=1500, T3 BN=600, LE BN=30, MDMBN=3000
 ST HX=24, LE HX=30, PD HX=150, TMTHX=250, TEMHX=350, L HX=8
 MD CS=1500, TIDTU=600, RS TU=3600, CR CM=15, LE CM=30, CM CS=400
 NC LO=.0043, CT LO=4, MN LO=0, STDLO=6, VE LO=.023
 CB UT=.019, MP1UT=1.58, CP UT=.023, CC UT=0, CM UT=0
 TABLE, PW WP=10
 8.10.12.14.16.18.20.21.23.26.30
 25.6, 50.1, 86.5, 137.4, 205.1, 292., 400.6, 500., 880., 880.
 TABLE, PY WD=13
 0., 4.33, 8.67, 13., 17.33, 21.67, 26., 30.33, 34.67, 39., 43.33, 47.67, 52.
 65.67, 68.65, 61.56, 51.49, 49.52, 56.61, 65
 TABLE, PD WD=7
 0, 4, 8, 12, 16, 20, 24
 10, 12, 14, 16, 14, 12, 10
 TABLE, DF WD=16
 0, 1, 2, 3, 4, 5, 6, 7, 8, 9, 10, 11, 12, 13, 14, 15
 5, 44, 160, 380, 480, 512, 440, 376, 307, 270, 148, 76, 40, 22, 9, 3
 TABLE, PD TP=9
 0, 3, 6, 9, 12, 15, 18, 21, 24
 46, 45, 48, 55, 62, 62, 56, 48, 46
 TABLE, PY TP=5
 0, 13, 26, 39, 52
 40, 50, 75, 65, 40
 TABLE, PD LO=17
 0, 1, 5, 3, 4, 5, 6, 7, 5, 9, 10, 5, 12
 13, 5, 15, 16, 5, 18, 19, 5, 21, 22, 5, 24
 450, 360, 372, 330, 450, 660, 810, 798, 804
 690, 708, 699, 702, 750, 708, 570, 450
 TABLE, PW LO=7
 1, 2, 3, 4, 5, 6, 7
 1, 1., 9., 9., 9., 6., 6
 TABLE, PY LO=6
 0, 10, 20, 30, 40, 52
 226, 194, 180, 174, 194, 226
 INITIAL CONDITIONS, E CS=1250, M8 CS=5.E5, EC1HX=1300, EC2HX=800
 PRINTER PLOTS, DISPLAY1
 M CO, VS, TIME
 T2 CO, VS, TIME
 T2 HX, VS, TIME
 TS1HX, VS, TIME
 P2 UT, VS, TIME
 DISPLAY2
 E CS, VS, TIME
 M8 CS, VS, TIME
 T2 CS, VS, TIME
 M2 HY, VS, TIME
 T HY, VS, TIME
 DISPLAY3, P2 TU, VS, TIME, TS2HX, VS, TIME
 TIN= .5, TMAX=336., PRATE=6, PRINT CONTROL=3, INT MODE=3, OUTRATE=4
 SIMULATE

ORIGINAL PAGE IS
 OF POOR QUALITY

FIGURE 8.4-3 PNEUMATIC STORAGE SIMULATION DATA




FIGURE 8.4-4 AVERAGE TEMPERATURE IN HEAT EXCHANGER CELL 2




FIGURE 8.4-5 HEAT EXCHANGER OUTLET TEMPERATURE (CHARGING)




FIGURE 8.4-6 AIR MASS IN PNEUMATIC STORAGE




FIGURE 8.4-7 AIR MASS TEMPERATURE IN PNEUMATIC STORAGE VESSEL




FIGURE 8.4-8 HEAT EXCHANGER OUTLET TEMPERATURE (DISCHARGING)

9.0 SOLAR PHOTOVOLTAIC EXAMPLES

The solar photovoltaic component models added to the SIMWEST library are briefly described and test case results illustrating their use are summarized in this section.

Table 9.0-1 summarizes the characteristics of the solar-photovoltaic components. The environmental data component is designed to read Typical Meteorological Year (TMY) data tapes containing hourly insolation and weather data at 26 U.S. locations. This component can also be used to read other hourly data tapes such as the SOLMET tapes by inputting a user specified format to the model generation program. The solar orientation or tracking component computes the sum of direct beam and global insolation on a flat plate array for fixed orientation and four different beam tracking options. The flat plate and focusing lens collector components provide detailed thermal analyses for determining average solar cell temperature. The collector models, and that of the solar array are based on similar models developed at Sandia Laboratories for the SOLCEL program (Reference [4]). The array component model is a simplified model based on scaling the characteristics of a single solar cell. Array voltage can either be user specified or determined by a maximum power tracker. It should be observed that the above components are coded in SI (metric) units, whereas most of the SIMWEST components are coded in English units. This is generally not a problem since there are at most only a few interconnection variables between the solar-photovoltaic generation components and other SIMWEST components, and these are easily converted using arithmetic components.

The TMY data tapes are currently the best environmental data sources available for simulating typical yearly solar energy system performance. These tapes were extracted from SOLMET data tapes containing rehabilitated hourly solar and meteorological observation data over a period of many years at each observation site. Each Typical Meteorological Year was created by statistical

selection of a typical meteorological month for each calendar month in the long term data base and catenating the 12 months to form a TMY. All of the TMY data files are available for use by a SIMWEST user. He thus has access to a high quality environmental data base for solar energy simulations and system analyses.

TABLE 9.0-1 SOLAR-PHOTOVOLTAIC COMPONENTS

<u>COMPONENT</u>	<u>SYMBOL</u>	<u>PURPOSE</u>
● ENVIRONMENTAL DATA (TAPE)	ED	READ DOE SOLAR INSOLATION AND WEATHER DATA TYPICAL METEOROLOGICAL YEAR TAPE
● SOLAR ORIENTATION (TRACKING)	SO	SOLAR INSOLATION ON TILTED FLAT PLATE ARRAY (FIVE OPTIONS)
● FLAT PLATE COLLECTOR	FP	FLAT PLATE THERMAL MODEL WITH FLUID AND PASSIVE COOLING OPTIONS
● FOCUSING LENS COLLECTOR	FO	FRESNEL LENS THERMAL MODEL WITH FLUID AND PASSIVE COOLING OPTIONS
● PHOTOVOLTAIC ARRAY	PV	CONVERTS SOLAR INSOLATION TO D.C. ELECTRICAL POWER. MAXIMUM POWER TRACKER OR USER SPECIFIED VOLTAGE

9.1 PHOTOVOLTAIC MODEL TEST CASE

The input data for the photovoltaic model test case is shown in Figure 9.1-1. The purpose of this model is to obtain characteristic current voltage curves for the default solar array parameters. Fortran statements are used in the model generation data to let the terminal voltage range between 0 and 204 volts for solar insolation values of 5, 20, and 50 suns ($1 \text{ sun} = 1000 \text{ w/m}^2$). Cell temperature is specified at 25°C for the first simulation and 55°C for the second. Figure 9.1-2 shows the current voltage curves and Figure 9.1-3 shows power voltage cross plots at the lower cell temperature and for the three solar insolation levels. These curves verify the physical characteristics of the solar cell model. It may be noted in these figures that current and output power become negative when the specified voltage exceeds the array open circuit voltage. Individual cell characteristics may be obtained by dividing voltage by 300 (default number of cells in series) and by dividing current by 500 (default number of cells in parallel).

9.2 FLAT PLATE COLLECTOR MODEL

The input data for the flat plate model test case is shown in Figure 9.2-1. The purpose of this model is to illustrate water and wind cooling of the collector and to test the tracking options of the orientation component **S0**. There are six 1-1/2 day simulation runs. The first run uses water cooling ($\text{CMOFP}=2$), a single glass cover over the front plate and insolation on the back. The second run uses passive cooling ($\text{CMOFP}=0$), no plate insolation and fins on the back to cool the collector. In the first two runs, the collector is tilted and has a fixed, southward facing orientation ($\text{M0 S0}=1$). The last four runs are similar to run 2 except different tracking options are utilized.

MODEL DESCRIPTION PHOTO-VOLTAIC CURRENT VOLTAGE CURVES

LOCATION=11 TI

↑ ~~FORTTRAN STATEMENTS~~

ST PV=5000

IF(DY TI,GT,1,5)ST PV=20000

~~IF(DY TI,GT,2,5)ST PV=50000~~

VT PV=8.5*TD TI

LOCATION=53 PV

~~END OF MODEL~~

PRINT

a) Model Generation Input Data

PARAMETER VALUES

CYCLES=0, TO TI=0

↑ ~~DLINES=50~~

TC PV=25

RC PV=1

~~PRINTER PLOTS, DISPLAY:~~

V PV,VS,TIME

I PV,VS,V PV

~~P PV,VS,V PV~~

P PV,VS,TIME

TINC=,5,TMAX=72,PRATE=24,PRINT CONTROL=3,INT MODE=3,OUTRATE=1

~~TITLE=PHOTO-VOLTAIC CELL CURRENT VOLTAGE CURVES~~

SIMULATE

PARAMETER VALUES

~~TC PV=55~~

SIMULATE

b) Simulation Program Input Data

FIGURE 9.1-1 PV TEST CASE INPUT DATA




FIGURE 9.1-2 SOLAR ARRAY CHARACTERISTIC CURRENT - VOLTAGE CURVES




FIGURE 9.1-3 SOLAR ARRAY OUTPUT POWER VERSUS VOLTAGE

MODEL DESCRIPTION	FLAT PLATE TEST CASE
LOCATION=11 TI	
LOCATION=35 ED	INPUTS=TI
LOCATION=53 SO	INPUTS=TI,ED(X1=SB,X2=ST)
LOCATION=57 FP	INPUTS=SO,ED(X4=WD,X3=TA)
END OF MODEL	
PRINT	

a) Model Generation Input Data

```

PARAMETER VALUES
CYCLES=2,01,TO TI=36,TFIFP=10,TFDFP=30,MFMFP=.02,CMDFP=2,NG FP=1,
DLINES=50
HI FP=.01
CW FP=1,CL FP=2,NT FP=10,CC FP=1000,CM FP=10,CPOFP=.01,LA SO=29,733,
TL SO=29,733,AA SO=2
PRINTER PLOTS, DISPLAY!
TLISO,VS,TIME
TC FP,VS,TIME
X2 ED,VS,TIME
P1 FP,VS,TIME
TINC=.5,TMAX=36,PRATE=6,PRINT CONTROL=3,INT MODE=3,OUTRATE=1
TITLE=FLAT PLATE COLLECTOR TEST CASE.
SIMULATE
PARAMETER VALUES
CMDFP=0,HI FP=1,E9,FIRFP=4
SIMULATE
PARAMETER VALUES
MO SO=2
SIMULATE
PARAMETER VALUES
MO SO=3
SIMULATE
PARAMETER VALUES
MO SO=4
SIMULATE
PARAMETER VALUES
MO SO=5
SIMULATE

```

b) Simulation Program Input Data

FIGURE 9.2-1 FLAT PLATE COLLECTOR MODEL INPUT DATA

The model schematic produced by the model generation program is shown in Figure 9.2-2. The component TI is used to furnish time of day and day of year information to SO and to the TMY read component ED. ED supplies direct beam and global insolation to SO, and ambient temperature and wind speed to the collector component FP. Based on collector orientation, SO supplies solar insolation incident to the array, collector tilt angle, and tracking power to FP.

Typical results of the flat plate model runs are shown in Figures 9.2-3 through 9.2-5. Figure 9.2-3 shows the global horizontal insolation obtained from ED during the 36 hour simulation period. The data was for mid-winter and the daily peak levels are thus low to moderate. The array tilt angle daily pattern for horizontal E-W axis tracking is shown in Figure 9.2-4. At noon the array is oriented normal to the sun's incident rays and thus maximizes the insolation gathered during the mid-day peak. The tilt angle approaches 90° as the sun approaches the horizon, and remains fixed at 90° overnight. Comparison of the solar insolation peaks with the various tracking options showed that horizontal E-W axis tracking gave the best results of the single axis tracking systems, and was only slightly inferior to two-axis beam tracking. Solar cell temperature for this case is shown in Figure 9.2-5. The cell temperature is within a few degrees of ambient most of the day and rises in mid-day proportional to the solar insolation received. The results with water cooling are quite similar.

9.3 FRESNEL LENS COLLECTOR MODEL AND INCREMENTAL COSTS

The input data for the Fresnel Lens test case is shown in Figure 9.3-1. The purpose of this model is to illustrate a Fresnel Lens collector model with thermal fluid loops for collector cooling and for solar heating. Three week-long simulations are used to demonstrate incremental cost calculations for subsystem economic design. A variable speed pump is assumed for the collector fluid loop with the flow rate adjusted so that the outlet temperature is 5°C greater than the inlet. The collector consists of a rectangular grid of 120




FIGURE 9.2-2 FLAT PLATE MODEL SCHEMATIC




FIGURE 9.2-3 GLOBAL HORIZONTAL RADIATION VERSUS TIME




FIGURE 9.2-4 TILT ANGLE VERSUS TIME FOR HORIZONTAL E-W AXIS TRACKING




FIGURE 9.2-5 SOLAR CELL TEMPERATURE VERSUS TIME


```

MODEL DESCRIPTION      FRESNEL LENS COLLECTOR WITH THERMAL STORAGE AND LOAD
LOCATION=11      TI
LOCATION=71      ED      INPUTS=TI
LOCATION=45      MA      INPUTS=TS(T=FIN)
FORTRAN STATEMENTS
      TFOFO = FO MA+5.
LOCATION=33      FO      INPUTS=ED(X1=ST,X3=TA,X4=WD),MA(FO=TFI)
LOCATION=73      PV      INPUTS=ED(X1=ST),FO
LOCATION=47      TS      INPUTS=FO(P,1=P),TL
LOCATION=27      TL      INPUTS=TI,ED(X3=TA)
LOCATION=77      LO      INPUTS=PV(P=P,1,P=LO,1)
LOCATION=79      CM
END OF MODEL
PRINT

```

a) Model Generation Input Data

```

TITLE=FRESNEL LENS COLLECTOR (INCREMENTAL COST COMPUTATION)
PARAMETER VALUES
CYCLES=4.01,TO TI=0,CMOFO=2,CW FO=3.75,CL FO=3.9, DLINES=50
NL FO=120,NT FO=24,MFMFO=0.5,CC FO=6.,CM FO=50,HI FO=.01,RC FO=.06
TS TS=5,DH TS=.00879,PD TS=12,LE TS=30,NU TS=.01,NC TL=0.2
C1 MA=.55556,C2 MA=-17.7778, COPFO=0.5
CC PV=100,CM PV=50,LE TS=30,CR CM=15,LE CM=20
AA PV=0.6,NS PV=600,NP PV=5,RAPPV=1.3
VE LO=.05,VE TL=.05
TABLE,HT TS=4
.00879,.025491,.047371,.064072
90,147,147,204
TABLE,TLOTTL=4
-10,0,10,25
4,2,1.5,1
TABLE,TWTTL=4
0,6,18,24
.4,1,1,.4
PRINTER PLOTS,DISPLAY1
RE TL,VS,TIME
E TS,VS,TIME
P1 FO,VS,TIME
FMDFO,VS,TIME
DISPLAY2
TC FO,VS,TIME
P PV,VS,TIME
FO MA,VS,TIME
INITIAL CONDITIONS=E TS=80
TINC=.5,TMAX=168,PRATE=12,PRINT CONTROL=3,INT MODE=3,OUTRATE=1
SIMULATE
PARAMETER VALUES, TS TS=5.5
SIMULATE
PARAMETER VALUES
TS TS=5.,NL FO=126,CW FO=3.94,AA PV=0.63,NS PV=630
SIMULATE

```

b) Simulation Program Input Data

FIGURE 9.3-1 FRESNEL LENS MODEL INPUT DATA

Fresnel lenses each of which focuses solar radiation on a 5 x 5 array of solar cells. Excess thermal energy is conducted to a heat sink surface and then dissipated by natural convection, radiation and heat exchange to the coolant fluid. The collector parameters are chosen for a lens concentration ratio of 25 and series connection of the output from each array. At maximum output the array collects about 10kw of solar radiation and produces about 1.7kw of electrical power. The user should be especially careful in specifying the input parameters to the collector and array components **F0** and **PV**, since inadvertant parameter errors can lead to physically inconsistent configurations, e.g., collector area smaller than the total lens area.

The model schematic produced by the model generation program is shown in Figure 9.3-2. The collector thermal loop is formed by the connections between the collector **F0** the thermal storage **TS** and the multiply and add component **MA**. The **MA** component is used to convert the thermal storage outlet temperature from degrees fahrenheit to degrees centigrade. The output temperature from **MA** is supplied as the inlet temperature to **F0**. The total thermal power gathered by the coolant fluid is computed in **F0** and supplied to **TS**. Similarly, the thermal load fluid loop is represented by a power request from the load component **TL** to **TS** and by thermal power delivered from **TS** to **TL**. The electrical output of the array is computed by **PV** and supplied to a load component **LO** which monitors the electrical energy collected.

Results of the first week simulation run are summarized in Figures 9.3-3 through 9.3-6. The weather was fairly constant during this run and solar insolation was fairly strong all week. Figure 9.3-3 shows that with water cooling cell temperature was held to less than 70°C at peak insolation. In fact, about 60% of the solar energy incident on the array is exchanged to the coolant fluid during peak insolation. The electrical output of the array is shown in Figure 9.3-4. The fluid flow rate of the pump and thermal energy collected exhibit very similar daily patterns. The thermal load for this week is shown in Figure 9.3-5. This load is dependent on both time of day and



FIGURE 9.3-2 FRESNEL LENS MODEL SCHEMATIC




FIGURE 9.3-3 SOLAR CELL TEMPERATURE FOR ONE WEEK SIMULATION




FIGURE 9.3-4 PHOTOVOLTAIC ARRAY OUTPUT FOR ONE WEEK SIMULATION




FIGURE 9.3-5 THERMAL LOAD DEMAND FOR ONE WEEK SIMULATION




FIGURE 9.3-6 THERMAL STORAGE TEMPERATURE FOR ONE WEEK SIMULATION

ambient temperature which yields the complex load pattern shown. Figure 9.3-6 shows the temperature of the thermal storage vessel resulting from the collector and load thermal loops. The daily cycles are predominant with the periods of strong insolation providing sufficient energy to satisfy the load and compensate for thermal losses. Average load is fairly well matched to solar generation during the week since the temperature remains within a 15° channel and does not have an apparent trend away from this range.

One of the most important measures of performance for a solar energy system is the levelized cost of energy, i.e., the life cycle cost to produce one unit of usable energy including generation, storage, transmission and conversion subsystems. Energy cost may be used to size components and select most promising system alternatives, i.e., minimum energy cost is used as a selection or optimization principle. Although SIMWEST does not provide user optimization capability, optimal sizing of a few key parameters, such as the ratio of solar to utility generation and the size of storage relative to generation, is possible and may be accomplished quickly using the concept of incremental energy cost. The idea is to compute the incremental change in levelized energy cost per incremental change in capital cost, for the system parameters of interest. Given an initial system configuration and M sizing parameters to be selected, optimization proceeds as follows:

- 1) Perform M+1 back to back simulations to compute the cost and energy performance of the baseline configuration and M incremental configurations from the baseline.
- 2) Calculate the incremental energy costs for each parameter variation. Then select a new baseline configuration. Since the incremental costs are equal at the minimum cost point, increase or decrease the sizing parameters so as to equalize the new baseline incremental costs.
- 3) Go to 1) and continue adjusting subsystem parameters until either a performance limit is reached or until the incremental costs of the

remaining parameters are equalized. (If two incremental costs are unequal, one can always lower the system energy cost by increasing the subsystem with the smallest incremental cost at the expense of the other subsystem.)

This procedure is recommended as more efficient and economical than using a series of parametric trade studies for subsystem optimization.

The process of computing incremental costs is illustrated for the Fresnel Lens model. In the first simulation the baseline system performance and costs are computed. The second simulation differs from the first in that thermal storage capacity has been increased by 10%, and the third simulation differs from the first in that the solar collector and photovoltaic array area have been increased by 5%. Table 9.3-1 summarizes the incremental cost and simulation results for these runs. Column 1 shows the initial capital cost of the baseline system and the incremental capital costs for the thermal storage and solar array increases. (These costs are meant to be illustrative rather than representative.) Column 2 shows the results of a 20 year levelized cost analysis of the three systems, including maintenance and operating costs, e.g., the change in thermal storage increases costs by \$9.10 per year. Column 3 shows the energy delivered to the loads in a year as estimated from the one week simulations. (Note: the change in storage capacity lowers the average coolant temperature, thus increasing output power.) Column 4 shows the levelized energy costs of the baseline system and of the increments in storage and generation. This column shows that the levelized energy cost will decrease as thermal storage or generation are increased, and that thermal storage is undersized relative to generation since a fixed \$ increase in storage will lower the system energy cost more than the same \$ increase in array area. Column 5 shows the % change in levelized energy cost given a 1% increase in capital investment. This column contains the same basic information as column 4 but provides a better quantitative measure of the economic value of increased storage capacity.

TABLE 9.3-1 INCREMENTAL COST CALCULATIONS

	CC	LC	ED	EC	NIC
Baseline	7392.	1272.	7829.	16.2	----
10% Inc. in Thermal	61.	9.10	110.5	8.2	-.84
5% Inc. in Solar	319.	47.90	365.0	13.1	-.21

NOMENCLATURE:

CC = Initial Capital Cost in \$

LC = Levelized Total Cost/Yr. in \$
 = Capital Cost*Life Cycle*Charge Rate
 + Maintenance Cost + Operating Cost

ED = Useful Energy Delivered/Yr. in KWH
 = Electrical Load + Thermal Load + Net
 Change in Thermal Storage

EC = Levelized Energy Cost in ¢/KWH
 = LC*100/ED

NIC = Normalized Incremental Costs
 = % Change in EC Per % Change in CC
 = $(\Delta LC/LC - \Delta ED/ED)/(\Delta CC/CC)$

APPENDIX: UTILITY SUBROUTINES

This section provides a short description and source code for the utility subroutines called by the SIMWEST library components. These routines are also available to the user and may be called by FORTRAN statements in the user's manual. (See also page 26 of section 2.1.2 on the use of subroutines TBLU1 and TBLU2.)

● FUNCTION AINR

AINR computes the current of a photovoltaic cell given light current AIL, cell voltage V, and temperature T. Newton-Raphson iterations are used to solve the implicit equation (1) for current I:

$$I = AIL + BIO (1. - \exp((V+I*RS)*QBK/(T+273))) \quad (1)$$

● SUBROUTINE CNVC

CNVC computes the convection coefficient HC and Reynolds number RE for air blown over a flat plate (ref. 1).

Inputs: T_A = air temperature in $^{\circ}K$
 T_P = plate temperature in $^{\circ}K$
 CL = length of plate in m
 V = velocity of air in m/s

Equations:

$$\begin{aligned} T_M &= (T_A + T_P)/2 && \text{(mean temp.)} \\ VI &= 9.0 \times 10^{-8} * T_M^{-1.115} \times 10^{-5} && \text{(viscosity)} \\ GR &= 1.386 \times 10^3 - 2.91 * T_M && \text{(Grashof's no.)} \\ CO &= 7.25 \times 10^{-5} * T_M + 4.325 \times 10^{-3} && \text{(conductivity)} \\ RE &= V * CL / VI && (2) \end{aligned}$$

$$H_{FREE} = .116 * CO * GR * |T_A - T_p|^{.333}$$

$$H_{WIND} = \begin{cases} .597 * CO * REE^5 / CL & RE \leq 5 \times 10^5 \\ .032 * CO * (RE^8 - 23000) / CL & \text{otherwise} \end{cases}$$

$$H_C = H_{FREE} + H_{WIND} \quad (3)$$

- SUBROUTINE CUBIC

CUBIC finds the roots of the cubic equation

$$x^3 + AAx + BB = 0 \quad (4)$$

and selects the real root \bar{x} with largest value.

- SUBROUTINE FLUC

FLUC computes the heat transfer coefficient H_F from a collector plate into a fluid coolant. The empirical equations used are for water cooling (ref. 1).

Inputs:

- NT = number of cooling tubes
- DT = diameter of cooling tubes in m
- CW = collector width in m
- COP = conductivity of mounting plate in w/m-K
- THP = mounting plate thickness in m
- FMD = coolant mass flow rate in kg/s
- DEN = coolant density in kg/m^3
- TF = mean coolant temperature in K
- COC = coolant conductivity in w/m-K

Equations:

$$NT1 = NT/CW$$

$$HF1 = 12*NT1^2*COP*THP \quad (\text{conduction coeff.})$$

$$VI = (21.7*(TF - 256)^{-0.8} - .185) \times 10^{-6} \quad (\text{fluid viscosity})$$

$$PR = (.00518*TF - 1.25)^{**}(-1.49) \quad (\text{Prandtl no.})$$

$$RE = 4.*FMD/(\pi*DT*NT*DEN*VI) \quad (\text{Reynolds no.}) \quad (5)$$

If $RE < 2100$,

$$HF2 = 4.36*COC*\pi*NT1$$

If $RE > 10000$

$$HF2 = .023*COC*RE^{-.8}*PR^{-.333}*\pi*NT1$$

If $2100 \leq RE < 10000$

$$X2 = 36.5*PR^{-.33}$$

$$D2 = .0029*PR^{-.33}$$

$$A = (4.36-X2)*1.6 \times 10^{-8} + D2*1.266 \times 10^{-4}$$

$$B = D2 - A*2 \times 10^4$$

$$C = X2 + A*10^8 - D2*10^4$$

$$HF2 = (A*RE^2+B*RE+C)*COC*\pi*NT1$$

$$HF = (1/HF1 + 1/HF2)^{-1} \quad (6)$$

● FUNCTION HTGLAS

HTGLAS computes the top surface heat loss coefficient H_t for a collector with 1 to 3 glass covers (ref. 2).

Inputs:

N = number of glass covers (1,2,3)

T_A = ambient temperature in $^{\circ}K$

T_C = mean cell temperature in $^{\circ}K$

H_C = convection coefficient for air blowing over a heated flat plate in w/m^2-k

e_c, e_g = emittance of cell and glass covers

TLT = collector tilt from horizontal in degrees

Equations:

$$H_t = (N(T_C/C)/((T_C-T_A)/(N+f))^{0.33} + 1/H_C)^{-1} + \sigma (T_C^2 + T_A^2)(T_C + T_A)/(A + (2N+f-1)/e_g - N) \quad (7)$$

with

$$\sigma = 5.688 \times 10^{-8} \text{ w/m}^2\text{-K}^4$$

$$C = 365.9 (1. - .00883*TLT + .0001298*TLT^2)$$

$$f = (1. - .04*H_C + .0005*H_C^2)(1. + .091*N)$$

$$A = 1/(e_c + .05*N(1-e_c))$$

● SUBROUTINE IMPLIC

IMPLIC controls the iteration logic which determines convergence of implicit variables in the user's system model, and prints convergence diagnostics. (See section 3.6 for a discussion of the iteration and diagnostic control logic.)

● SUBROUTINE RADC

RADC computes the infrared radiation coefficient HR between two bodies with surface temperatures T_1 and T_2 . (See section 7.4 of Duffie and Beckman, ref. 3.)

Inputs: T_1, T_2 = surface temperatures in $^{\circ}\text{K}$

e_1, e_2 = emittances for surfaces corresponding to T_1, T_2

$$H_R = 5.688 \times 10^{-8} (T_1^2 + T_2^2)(T_1 + T_2)/(e_1^{-1} + e_2^{-1} - 1) \quad (8)$$

● FUNCTIONS TBLU1, TBLU2

TBLU1 and TBLU2 perform one- and two-dimension linear interpolation. A binary search is used to locate the nearest grid points for unequally spaced data. See section 2.1.2 for subroutine usage within model generation FORTRAN statements.

● SUBROUTINE UNIF

UNIF generates uniformly distributed, pseudo-random number sequences in the range $[0,1]$. This routine may be used to obtain random number sequences with a specified distribution function. (See for example the coding for WD in section 7.47.)

REFERENCES

1. F. Kreith, Principles of Heat Transfer, 3rd Edition, International Textbook Co., 1973.
2. S. A. Klein, M. S. Thesis, "The effects of Thermal Capacitance Upon the Performance of Flat Plate Solar Collectors", University of Wisconsin, 1973.
3. J. A. Duffie and W. A. Beckman, Solar Energy Thermal Processes, Wiley, 1974.

CAINR

FUNCTION AINR(AIL,BIO,QBK,V,RS,T)

C
C
C

NEWTON-RALPHSON TO COMPUTE PHOTO-VOLTAIC CELL CURRENT

$F(A) = A - AIL - BIO * (1. - \exp(QBK * (V + A * RS) / (T + 273)))$

$FP(A) = 1. + BIO * \exp(QBK * (V + A * RS) / (T + 273)) * QBK * RS / (T + 273)$

A=0.

DO 1 J=1,10

ANEW=A-F(A)/FP(A)

IF((ANEW-A).LE..00001)GO TO 2

1 A=ANEW

2 AINR=ANEW

RETURN

END

CNVC

SUBROUTINE CNVC(HC,RE,TP,TA,V,CL)

C
C
C
C
C
C
C
C

COMPUTES CONVECTION COEFFICIENT HC AND REYNOLDS
NUMBER RE FOR AIR BLOWING OVER A FLAT PLATE.
CALLED BY COMPONENT FO.

INPUTS TA -AIR TEMPERATURE,K
 TP -PLATE TEMPERATURE,K
 V -VELOCITY OF AIR,M/S
 CL -LENGTH OF PLATE,M

TM=(TA+TP)*.5
VI=9.E-8*TM-1.115E-5
GR=1386.-2.91*TM
CO=7.25E-5*TM+4.325E-3
RE=V*CL/VI
HFREE=.116*CO*GR*((ABS(TA-TP))**(.333))
HWIND=.597*CO*SQRT(RE)/CL
IF(RE.GT.5.E5)HWIND=.032*CO*(RE**(.8)-23000.)/CL
HC=HFREE+HWIND
RETURN
END

CUBIC

SUBROUTINE CUBIC(AA,BB,ANS)

TER=AA**3/27.

TERM=BB**2/4.+TER

IF(ABS(TERM).GT..0001)GO TO 10

THREE REAL ROOTS, TWO EQUAL

AB=2.*CBRT(-BB/2.)
ABB=-AB/2.

SELECT POSITIVE ROOT

ANS=AMAX1(AB,ABB)

RETURN

10 IF(TERM.LT.0.)GO TO 20

ONE REAL ROOT, TWO CONJUGATE IMAGINARY ROOTS

STER=SQRT(TERM)

AAA=CBRT(-BB/2.+STER)
BBB=CBRT(-BB/2.-STER)

SELECT REAL ROOT

ANS=AAA+BBB

RETURN

THREE REAL, UNEQUAL ROOTS

20 STER=SQRT(-TER)

THETA=ACOS(-BB/2./STER)
TE=2.*SQRT(-AA/3.)

THETA3=THETA/3.
X1=TE*COS(THETA3)

X2=TE*COS(THETA3+2.09439)
X3=TE*COS(THETA3+4.18879)

SELECT SMALLEST POSITIVE ROOT

ANS=AMAX1(X1,X2,X3)

RETURN
END

ORIGINAL PAGE IS
OF POOR QUALITY

CFLUC

SUBROUTINE FLUC(HF,RE,NT,DT,CW,COS,THS,FMD,DEN,TF,COC)

COMPUTES HEAT TRANSFER COEFFICIENT HF TO FLUID
AND REYNOLDS NUMBER.

CALLED BY COMPONENT FO

INPUTS NT -NUMBER OF COOLING TUBES
 DT -DIAMETER OF COOLING TUBES
 CW -COLLECTOR WIDTH,M
 COS -CONDUCTIVITY OF MOUNTING PLATE,W/M-K
 THS -MOUNTING PLATE THICKNESS,M
 FMD -COOLANT MASS FLOW RATE,KG/S
 DEN -COOLANT DENSITY,KG/M3
 TF -MEAN COOLANT TEMPERATURE,K
 COC -COOLANT CONDUCTIVITY,W/M-K

REAL NT,NT1

WRITE(6,108)FMD,DEN,TF,COC

C 108 FORMAT(1H0,5X,*FLUC INPUTS *,4F10.2)

PR=(.00518*TF-1.25)**(-1.49)

NT1=NT/CW

HF1=12.*NT1*NT1*COS*THS

VI=(21.7*(TF-256.))**(-.8)-.185)*1.E-6

RE=4.*FMD/(3.1416*DT*NT*DEN*VI)

IF(RE.GT.2100.)GO TO 1

HF2=4.36*COC*3.1416*NT1

GO TO 5

1 IF(RE.GT.10000.)GO TO 2

X2=36.5*(PR**(.33))

D2=.0029*(PR**(.33))

A=(4.36-X2)*1.6E-8+D2*1.266E-4

B=D2-A*2.E4

C=X2+A*1.E8-D2*1.E4

HF2=(A*RE*RE+B*RE+C)*COC*3.1416*NT1

GO TO 5

2 CONTINUE

HF2=.023*COC*(RE**(.8))*(PR**(.333))*3.1416*NT1

5 CONTINUE

HF=1./(1./HF1+1./HF2)

C WRITE(6,109)HF,RE

C 109 FORMAT(1H0,5X,*FLUC OUTPUTS *,2F10.2)

RETURN

END

CHTGLAS

FUNCTION HTGLAS(NG,TA,TC,HCI,EC,EG,TLT)

TOP HEAT LOSS COEFFICIENT HT FOR GLASS COVERS, CALLED BY FP

INPUTS

NG=NUMBER OF GLASS COVERS (1,2,3)

TA=AMBIENT TEMPERATURE,K

TC=MEAN CELL TEMPERATURE,K

HCI=CONVECTION COEFFICIENT FOR AIR BLOWING OVER
A HEATED FLAT PLATE, W/M²-K

EC,EG=EMITTANCE OF CELL AND GLASS COVERS

TLT=COLLECTOR TILT FROM HORIZONTAL IN DEGREES

REAL NG

SIGMA=5.688E-8

C=365.9*(1.-.00883*TLT+.0001298*TLT*TLT)

F=(1.-.04*HCI+.0005*HCI*HCI)*(1.+.091*NG)

A=1./(EC+.05*NG*(1.-EC))

G=NG*(TC/C)/(((TC-TA)/(NG+F))*0.33) + 1./HCI

B=SIGMA*(TC*TC+TA*TA)*(TC+TA)/(A+(2.*NG+F-1.)/EG-NG)

HTGLAS=1./G+B

RETURN

END

CIMPLIC

```

SUBROUTINE IMPLIC(CYCLES,D LINES)
COMMON/CIMPL/IMPL,ICNT /CORDER/ NOX,NOV /COLD/VOLD
COMMON /CV/ V /CNAMEV/ NAMEV /CTIME/ TIME
DIMENSION V(1),NAMEV(1),VOLD(1)
C ***** UNIVAC VERSION CODE ONLY
C IF(CYCLES.LE.0.) GO TO 40
C *****
IF(IMPL.GT.0)GO TO 10
SP=0
ITERS=CYCLES
ITERS= MAX0(1,MIN0(ITERS,20))
ILINES= ABS(D LINES)
ITNO= 0
IMPL=1
DO 5 I=1,NOV
5 VOLD(I) = 0.
10 CONTINUE
C ***** CDC VERSION CODE ONLY
IF(CYCLES.GE.1.) GO TO 15
IMPL=2
IF(ICNT.GE.ILINES) IMPL=3
RETURN
C *****
15 IF(IMPL.GT.1) GO TO 20
ITNO= ITNO+1
IF(ITNO.GE.ITERS) IMPL=2
ICON=1
DO 30 I=1,NOV
IF(ABS(V(I)).LT. 1.E-6) GO TO 30
IF( ABS(VOLD(I)-V(I)) .GT. 0.03*ABS(V(I)) )ICON=0
VOLD(I)= V(I)
30 CONTINUE
IF(ICON.EQ.1) IMPL=2
IF(IMPL.EQ.2 .AND. ICNT.GE.ILINES) IMPL=3
RETURN
C
C
20 ITNO=0
IF(IMPL.GT.2) GO TO 40
IF(ICON.EQ.1) GO TO 40
IF(D LINES.LT.0.) GO TO 40
ICK=0
DO 50 I=1,NOV
IF( ABS(V(I)).LT.1.0E-6) GO TO 50
IF( ABS(VOLD(I)-V(I)) .LT. 0.05*ABS(V(I)) )GO TO 50
IF(ICK.EQ.0) WRITE (6,100) TIME
100 FORMAT(1H0,10X,5HTIME=,F9.2)
WRITE(6,200) NAMEV(I),VOLD(I),V(I)
200 FORMAT(1H ,10X,A6,28H NONCONVERGENCE. OLD VALUE=,F12.3,
1 13H NEW VALUE=,F12.3)
ICK=1
50 CONTINUE
IF(ICK.EQ.1) ICNT=ICNT+1
40 IMPL=4
RETURN
END

```

CRADC

SUBROUTINE RADC(HR,T1,T2,E1,E2)

C
C
C
C
C
C
C
COMPUTES INFRARED RADIATION COEFFICIENT HR
CALLED BY COMPONENT FO

INPUTS T1,T2 -SURFACE TEMPERATURES,K
E1,E2 -CORRESPONDING SURFACE EMITTANCES

$HR = 5.688E-8 * (T1^4 + T2^4) * (T1 + T2) / (1./E1 + 1./E2 - 1.)$

RETURN

END

CTBLU1

FUNCTION TBLU1(X,XT,FT,NDX,NX)

PURPOSE ONE DIMENSION LINEAR INTERPOLATION

CALL SEQUENCE

X - VALUE OF INDEPENDENT VARIABLE
XT - ARRAY OF LENGTH ABS(NX) CONTAINING X VALUES
FT - ARRAY OF TABLE VALUES CORRESPONDING TO XT
NDX - INDICATOR FOR STEP SPACING
IF NDX.EQ.0 THEN XT CONTAINS EQUAL SPACED DATA
IF NDX.NE.0 THEN XT CONTAINS UNEQUAL SPACED DATA
NX - ABS(NX) IS THE ARRAY LENGTH
IF NX.LT.0 THEN TRUNCATE OUTSIDE TABLE RANGE
IF NX.GE.0 THEN EXTRAPOLATE OUTSIDE TABLE RANGE

WRITTEN BY A.W.WARREN

VERSION 1, APRIL 1977

DIMENSION XT(1),FT(1)

NA=IABS(NX)

IF(NA.GT.1)GO TO 5

TBLU1=FT(1)

RETURN

5 IF(NDX.NE.0) GO TO 100

EQUI-SPACED TABLE INTERPOLATION

X0= XT(1)

H= XT(2)-XT(1)

XI= (X-X0)/H +1.

I=XI

IF(I.GT.0) GO TO 10

TBLU1= FT(1)

IF(NX.GE.0)TBLU1= FT(1) + (XI-1.)*(FT(2)-FT(1))

RETURN

10 IF(I.LT.NA) GO TO 20

TBLU1=FT(NA)

IF(NX.GE.0) TBLU1= FT(NA) + (XI-NA)*(FT(NA)-FT(NA-1))

RETURN

20 TBLU1= FT(1) + (XI-1)*(FT(I+1)-FT(1))

RETURN

UNEQUAL SPACED TABLE INTERPOLATION

100 IF(X.GE.XT(1)) GO TO 30

TBLU1=FT(1)

IF(NX.GE.0) TBLU1= FT(1) + (X-XT(1))*(FT(2)-FT(1))/(XT(2)-XT(1))

RETURN

30 IF(X.LT.XT(NA)) GO TO 40

TBLU1= FT(NA)

IF(NX.GE.0) TBLU1=FT(NA)+(X-XT(NA))*(FT(NA)-FT(NA-1))/(XT(NA)

1 - XT(NA-1))

RETURN

40 I=1

IGE= NA

50 II=(IGE+1)/2

IF(X.LT.XT(II)) GO TO 60

```
I= II
GO TO 70
60 IGE= II
70 IF(I+1.LT.IGE) GO TO 50
TBLU1= FT(I) + (FT(I+1)-FT(I))*(X - XT(I))/(XT(I+1)-XT(I))
RETURN
END
```


CTBLU2

FUNCTION TBLU2(X,Y,XT,YT,FT,IX,IY,NX,NY,MX,MY)

PURPOSE TWO DIMENSION LINEAR INTERPOLATION

METHOD BINARY SEARCH TO FIND NEAREST GRID POINTS.
TBLU1 IS USED TO REDUCE THE INTERPOLATION DIMENSION.

CALL SEQUENCE

X,Y - POINT AT WHICH INTERPOLATION IS DESIRED
XT,YT- ARRAYS CONTAINING INDEPENDENT VARIABLE GRID POINTS
FT - TWO DIMENSION ARRAY OF VALUES SUCH THAT FT(I,J)
CORRESPONDS TO XT(I),YT(J).
IX,IY- INDICATORS FOR GRID SPACING
IF IX=0 THEN XT CONTAINS EQUAL SPACED VALUES
IF IX.NE.0 THEN XT CONTAINS UNEQUAL SPACED VALUES
NX,NY- ABS(NX),ABS(NY) ARE THE ARRAY DIMENSIONS FOR XT,YT
IF NX.LT.0 THEN TRUNCATE OUTSIDE XT RANGE
IF NX.GT.0 THEN EXTRAPOLATE OUTSIDE XT RANGE
LIKEWISE FOR NY AND YT VALUES.
MX,MY- DUMMY ARGUMENTS.SET EQUAL TO ABS(NX), ABS(NY).

WRITTEN BY A.W. WARREN

VERSION 1, JUNE 1977

DIMENSION XT(1),YT(1),FT(1)

NA = IABS(NX)

MX = NA

NB = IABS(NY)

MY = NB

IF(NA.GT.1)GO TO 10

TBLU2 = TBLU1(Y,YT,FT,IY,NY)

RETURN

10 IF(NB.GT.1)GO TO 20

TBLU2 = TBLU1(X,XT,FT,IX,NX)

RETURN

Y OUTSIDE YT TABLE RANGE

20 IF(Y.GT. YT(1))GO TO 100

E = (Y-YT(1))/(YT(2)-YT(1))

FF1 = TBLU1(X,XT,FT(1),IX,NX)

TBLU2 = FF1

IF(NY.GT.0)TBLU2 = FF1+ E*(TBLU1(X,XT,FT(NA+1),IX,NX) -FF1)

RETURN

100 IF(Y.LT. YT(NB))GO TO 200

E = (YT(NB)-Y)/(YT(NB)-YT(NB-1))

NB1 = NA*(NB-1)+1

FF1 = TBLU1(X,XT,FT(NB1),IX,NX)

TBLU2 = FF1

IF(NY.GT.0)TBLU2 = FF1+ E*(TBLU1(X,XT,FT(NB1-NA),IX,NX) -FF1)

RETURN

YT GRID SEARCH AND INTERPOLATION

200 IF(IY.NE.0)GO TO 240

I = (Y - YT(1))/(YT(2)-YT(1)) + 1.

GO TO 300

```

240 I=1
    IGE = NB
250 II = (IGE+I)/2
    IF(Y.LT. YT(II))GO TO 260
    I= II
    GO TO 270
260 IGE = II
270 IF(I+1 .LT. IGE)GO TO 250

```

```

C
300 E = (Y-YT(I))/(YT(I+1)-YT(I))
    I1= NA*(I-1)+1
    FF1 = TBLU1(X,XT,FT(I1),IX,NX)
    TBLU2 = FF1 + E*(TBLU1(X,XT,FT(I1+NA),IX,NX) -FF1)
    RETURN
    END

```

CUNIF

```
SUBROUTINE UNIF(U,IX)
COMMON /CIMPL/ IMPL,ICNT,ITEST
DATA Y/253967./
IF(IMPL.EQ.0 .AND. ITEST.EQ.1) IX=431469
IF (IX.EQ.1) IX = 431469
X= AMOD( IX*Y,16777216.)
U= X/16777215.
IX=X
RETURN
END
```